

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Pierson Middle-High School							
SAHAR-0183	2005B	Room 2140	Classroom Faucet	Non-Potable	10/7/2020	47	Placarded for Non-Drinking Use Until Remediated
SAHAR-0180	2008	Boys Bathroom	Bathroom Faucet	Non-Potable	10/7/2020	17	Placarded for Non-Drinking Use Until Remediated
SAHAR-0058	1032	Girls Bathroom	Bathroom Faucet	Non-Potable	10/7/2020	27	Placarded for Non-Drinking Use Until Remediated
SAHAR-0057	1032	Girls Bathroom	Bathroom Faucet	Non-Potable	10/7/2020	39	Placarded for Non-Drinking Use Until Remediated
SAHAR-0035	4008A	Library Work Room	Kitchen Faucet (Cold)	Potable	10/7/2020	44	Removed From Service, Pending Remediation