

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM Appendix D

Page 1 of 5

CLIENT INFORMANTION

Name:	Brunswick Central School District
Address:	3992 NY 2 Troy NY 12180
Client Rep:	Whitney Colvin

Date of Sampling:	11/10/20
Samples Taken By:	Tim LeVan
Samples Taken By:	Whitney Colvin

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Tamarac JR SR High School
BLDG ADDRESS:	3992 NY 2 Troy NY 12180
CONTACT NAME & NUMBERS:	Whitney Colvin 518-859-9950

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1950	1970	2001	2020	

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Lead test Results ug/L from 11/10/20	Lead test Results ug/L from	Lead test Results ug/L from	Remediation
128	MHS-01-BF1-P-128	A-Corridor girls room	Sink faucet 1		1950	X	1.2			
129	MHS-01-BF2-P-129	A-Corridor girls room	Sink faucet 2	Gerber	1950	X	1.6			
130	MHS-01-BF3-P-130	A-Corridor girls room	Sink faucet 3	Neoper	1950	X	1.0			
131	MHS-01-BF1-P-131	A-Corridor Boys room	Sink faucet 1	Gerber	1950	X	2.0			
132	MHS-01-BF2-P-132	A-Corridor Boys room	Sink faucet 2	Delta	1950	X	2.0			
133	MHS-01-BF3-P-133	A-Corridor Boys room	Sink faucet 3	Delta	1950	X	3.5			
134	MHS-01-DW-P-134	A-Corridor main lobby	Water fountain	Elkay	1950	X	<1.0			
135	MHS-01-DW-P-135	A-Corridor main lobby	Bottle filler	Elkay	2017	X	<1.0			
136	MHS-01-FS-P-136	142	Sink faucet	Delta	1950	X	<1.0			
137	MHS-01-DW-P-137	B-Corridor	Water fountain	ELKAY	1950	X	1.2			
138	MHS-01-BF-P-138	B-Corridor Men's room	Sink faucet	KOHLER	1950	X	2.4			
139	MHS-01-BF-P-139	B-Corridor Women's room	Sink faucet	Delta	1950	X	3.7			
140	MHS-01-BF1-P-140	MS girls locker room	Sink faucet 1		1970	X	10.8			
141	MHS-01-BF-P-141	MS girls locker room	Sink faucet 2		1970	X	1.0			
142	MHS-01-DW-P-142	MS Gym corridor	Water fountain	ELKAY	1970	X	<1.0			
143	MHS-01-GI-P-143	MS Gym storage room	Ice Machine	SCOTSMAN	1970	X	<1.0			
144	MHS-01-BF-P-144	MS Boys locker room	Sink faucet 1		1970	X	7.2			
145	MHS-01-BF-P-145	MS Boys locker room	Sink faucet 2		1970	X	<1.0			
146	MHS-01-BF-P-146	6th grade girls room	Sink faucet	TRIDENT	1970	X	2.4			
147	MHS-01-BF-P-147	6th grade boys room	Sink faucet	DELTA	1970	X	2.8			
148	MHS-01-DW-P-148	6th grade wing	Bottle filler	Murdock	1970	X	5.0			
149	MHS-01-DW-P-149	MS Cafeteria	Water fountain	ELKAY	2020	X	1.4			
150	MHS-01-DW-P-150	MS Cafeteria	Bottle filler	ELKAY	2020	X	1.3			
151	MHS-01-KF-P-151	MS Serving area	Sink Faucet		2020	X	1.5			
152	MHS-01-KF-P-152	MS Serving area	Steamer filler		2020	X	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Time:	
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)				
Lab:PACE Analytical				
Contact:				
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody				