

**Washington School  
Drinking Water Testing  
305 S. Hutchinson St, Harvard, IL 60033**

Map #	Location/Room #	Site Code	Collection Date	First Draw Results PPB	Flush Draw Results PPB	Notes
1	kitchen	K-1	2/28/2017	<2.00	<2.00	
2	kitchen	K-2	2/28/2017	<2.00	<2.00	
3	corridor	DF-1	2/28/2017	<2.00	<2.00	
4	Nurse	N-1	2/28/2017	<2.00	<2.00	
5	Room 1	C-1	2/28/2017	24.8	7.46	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room 1	CF-1	3/7/2017	<2.00	<2.00	
6	Room 2	C-2	2/28/2017	22.3	6.08	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room 2	CF-2	3/7/2017	<2.00	<2.00	
7	Room 7	C--7	2/28/2017	18	10.8	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room7	CF-7	3/7/2017	<2.00	<2.00	
8	corridor	DF-2	2/28/2017	<2.00	<2.00	
9	Room 3	C-3	2/28/2017	3.31	2.09	Fixture removed on 3/30/17
	Room 3	CF-3	3/7/2017	<2.00	<2.00	
10	Room 6	C-6	2/28/2017	5.63	2.09	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room 6	CF-6	3/7/2017	<2.00	<2.00	
11	Room 5	C-5	2/28/2017	4.83	2.52	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room 5	CF-5	3/7/2017	2.56	<2.00	
12	Room 4	C-4A	2/28/2017	8.7	3.23	Removed from service upon receipt of test results 3/16/17, Fixture removed on 3/30/17
	Room 4	CF-4A	3/7/2017	<2.00	<2.00	
13	Room 4	C-4B	2/28/2017	<2.00	<2.00	