

## Taconic Hills Central School

73 Rt 11 A

Craryville ,NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03200

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School

Owner: Taconic Hills Central School

Sample Loc: 73 Rt 11A Craryville

Sample Pt: S259 B&amp;G office CWT

Collect Date: 03/26/2015

Collect Time: 07:10

Collected by: ELLWOODS BURGER

Receipt Temp: 20 C see note 1

Water Source: Drilled Well

Chlorinated: NA Field Residual Chlorine:

Potability: Yes

Grab/Comp: Grab

## Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.33	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

## Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

## Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson

Environmental Laboratory Supervisor and contact person

If you have questions, please call.

(518) 525-5480/5479

Reviewed by Brian Collins

These results relate to samples as received.

**Taconic Hills Central School**

73 Rt 11 A

Craryville ,NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03201

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: E260 2nd Flr Teachers lunch rm CWT

Collect Date: 03/26/2015  
 Collect Time: 07:30  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.32	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved in lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.



**Taconic Hills Central School**  
**73 Rt 11 A**

**Craryville ,NY 12521**

**Printed On** 4/2/2015 Page 1 of 1

**Sample ID:** AU03202  
**Date Received:** 03/26/2015  
**Time Received:** 12:33  
**Date Finalized:** 04/02/2015  
**PO Number:**  
**Your Ref:**

**Customer:** Taconic Hills Central School  
**Owner:** Taconic Hills Central School  
**Sample Loc:** 73 Rt 11A Craryville  
**Sample Pt:** E229 Class 2nd Flr elementary CWT

**Collect Date:** 03/26/2015  
**Collect Time:** 07:40  
**Collected by:** ELLWOODS BURGER  
**Receipt Temp:** 20 C see note 1

**Water Source:** Drilled Well  
**Chlorinated:** NA **Field Residual Chlorine:**

**Potability:** Yes  
**Grab/Comp:** Grab

### Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.15	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

#### Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
P	Sample preserved in lab	Z	Analysis is not state-certified	C	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits		

**Legend:** < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

**MCL =** Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

#### Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.

## Taconic Hills Central School

73 Rt 11 A

Craryville, NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03203

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
Owner: Taconic Hills Central School  
Sample Loc: 73 Rt 11A Craryville  
Sample Pt: S201 High School 2nd Flr class CWT

Collect Date: 03/26/2015  
Collect Time: 07:53  
Collected by: ELLWOODS BURGER  
Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
Grab/Comp: Grab

## Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.20	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

## Qualifiers Key:

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

## Comments:

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
Environmental Laboratory Supervisor and contact person  
If you have questions, please call.  
(518) 525-5480/5479

Reviewed by Brian Collins

These results relate to samples as received.



**Taconic Hills Central School**

73 Rt 11 A

Craryville ,NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03204

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: 2nd Flr High School teachers lunchrm CWT

Collect Date: 03/26/2015  
 Collect Time: 08:00  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.23	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.

**Taconic Hills Central School**

73 Rt 11 A

Craryville, NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03205

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: 1st Flr boardroom S104 Kitchen CWT

Collect Date: 03/26/2015  
 Collect Time: 08:05  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**Laboratory Report**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.19	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.



**Taconic Hills Central School**

73 Rt 11 A

Craryville, NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03206

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: Community rm S101 1st Flr CWT

Collect Date: 03/26/2015  
 Collect Time: 08:10  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.28	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

**Legend:** < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.

**Taconic Hills Central School**

73 Rt 11 A

Craryville, NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03207

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: E160 1st Flr elementary conference CWT

Collect Date: 03/26/2015  
 Collect Time: 08:17  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.18	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.



**Taconic Hills Central School**

73 Rt 11 A

Craryville ,NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03208

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: E103C elementary nurse office exam B

Collect Date: 03/26/2015  
 Collect Time: 08:24  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.16	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved in lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.

**Taconic Hills Central School**

73 Rt 11 A

Craryville ,NY 12521

Printed On 4/2/2015

Page 1 of 1

Sample ID: AU03209

Date Received: 03/26/2015

Time Received: 12:33

Date Finalized: 04/02/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School  
 Owner: Taconic Hills Central School  
 Sample Loc: 73 Rt 11A Craryville  
 Sample Pt: E146 elementary Art room CWT

Collect Date: 03/26/2015  
 Collect Time: 08:33  
 Collected by: ELLWOODS BURGER  
 Receipt Temp: 20 C see note 1

Water Source: Drilled Well  
 Chlorinated: NA Field Residual Chlorine:

Potability: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.26	1.3		mg/L	SM3111B	CRW	4/1/2015
Lead	0.001	0.015		mg/l	SM3113B	BP	3/31/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
P Sample preserved in lab	Z Analysis is not state-certified	C Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-) Matrix spike recovery outside acceptance limits	

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
 Environmental Laboratory Supervisor and contact person  
 If you have questions, please call.  
 (518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.



**Taconic Hills Central School**

73 Rt 11 A

Craryville ,NY 12521

Printed On 3/25/2015

Page 1 of 1

Sample ID: AU02570

Date Received: 03/11/2015

Time Received: 10:57

Date Finalized: 03/25/2015

PO Number:

Your Ref:

Customer: Taconic Hills Central School

Owner: Taconic Hills Central School

Sample Loc: 73 Rt 11A Craryville

Sample Pt: Elementary Kitchen CWT

Collect Date: 03/10/2015

Collect Time: 10:06

Collected by: ELWOOD S. BURGER

Receipt Temp: 21 C see note 1

Water Source: Drilled Well

Chlorinated: Yes Field Residual Chlorine: Yes

Potability: Yes

Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Copper	0.18	1.3		mg/L	SM3111B	NSS/CV	3/18/2015
Lead	<0.001	0.015		mg/l	SM3113B	BP	3/12/2015

**Qualifiers Key:**

X Exceeds maximum contamination limit

T Temperature outside specifications

P Sample preserved in lab

S(+/-) Lab control sample outside acceptance limits

R Duplication outside acceptance limits

A Sample contained air bubble or headspace

Z Analysis is not state-certified

M(+/-) Matrix spike recovery outside acceptance limits

H Hold time exceeded

B Analyte detected in blank

C Incorrect bottle received

Legend: &lt; Less Than, &gt; Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus (total & ortho), should be received on ice to indicate the chilling process was begun. ELAP requirements specify that temperatures equal to or less than 4 degrees C are required for potable samples and equal to or less than 6 degrees C for non-potable samples. Samples should not be frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



John Wilson  
Environmental Laboratory Supervisor and contact person  
If you have questions, please call.  
(518) 525-5480/5479

**Reviewed by Brian Collins**

These results relate to samples as received.