

Radon Testing Results - Riddle High School

Action Level is 4.0 pCi/L

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Riddle High School	ROOM 8	5035177	2/1/2021	Detector Kit	1.5
Riddle High School	ROOM 6	4964595	2/1/2021	Detector Kit	0.8
Riddle High School	ROOM 5	5035096	2/1/2021	Detector Kit	1.1
Riddle High School	ROOM 4	4971365	2/1/2021	Detector Kit	1.5
Riddle High School	VP OFFICE	4971594	2/1/2021	Detector Kit	1.0
Riddle High School	GYM	4971740	2/1/2021	Detector Kit	1.7
Riddle High School	GYM	5034821	2/1/2021	Detector Kit	1.2
Riddle High School	GYM	5034855	2/1/2021	Detector Kit	1.6
Riddle High School	GYM	5035184	2/1/2021	Detector Kit	1.3
Riddle High School	GYM DUP	4971743	2/1/2021	Duplicate	1.5
Riddle High School	GYM BLANK	5034879	2/1/2021	Blank	<0.3
Riddle High School	PRINCIPAL	5035393	2/1/2021	Detector Kit	1.2
Riddle High School	MAIN OFFICE	5035219	2/1/2021	Detector Kit	1.1
Riddle High School	TEACHERS LOUNGE	4971155	2/1/2021	Detector Kit	0.8
Riddle High School	ROOM 3	4971230	2/1/2021	Detector Kit	1.0
Riddle High School	COUNSELING	5029620	2/1/2021	Detector Kit	1.6
Riddle High School	ROOM 1	5035023	2/1/2021	Detector Kit	1.0
Riddle High School	BASEMENT	4971539	2/1/2021	Detector Kit	1.6
Riddle High School	BASEMENT	5035191	2/1/2021	Detector Kit	5.2
Riddle High School	BASEMENT	4964502	2/1/2021	Detector Kit	1.3
Riddle High School	LIBRARY	5034984	2/1/2021	Detector Kit	0.8
Riddle High School	LIBRARY	5029645	2/1/2021	Detector Kit	1.1
Riddle High School	LIBRARY	5035372	2/1/2021	Detector Kit	1.1
Riddle High School	LIBRARY DUP	4948912	2/1/2021	Duplicate	1.0
Riddle High School	ROOM 13	5035396	2/1/2021	Detector Kit	1.3
Riddle High School	ROOM 14	4971494	2/1/2021	Detector Kit	1.4
Riddle High School	ROOM 15	4971725	2/1/2021	Detector Kit	1.8

Radon Testing Results - Riddle High School

Action Level is 4.0 pCi/L

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Riddle High School	ROOM 16	5035364	2/1/2021	Detector Kit	1.8
Riddle High School	ROOM 17A	4971263	2/1/2021	Detector Kit	1.9
Riddle High School	ROOM 17B	4971641	2/1/2021	Detector Kit	1.0
Riddle High School	ROOM 18	4971680	2/1/2021	Detector Kit	2.2
Riddle High School	ROOM 19	4971511	2/1/2021	Detector Kit	2.0
Riddle High School	ROOM 20	4971473	2/1/2021	Detector Kit	1.3
Riddle High School	MAT ROOM	4937431	2/1/2021	Detector Kit	<0.3
Riddle High School	MAT ROOM	4971302	2/1/2021	Detector Kit	<0.3
Riddle High School	MAT BLANK	5035319	2/1/2021	Blank	<0.3
Riddle High School	D.O.	4971526	2/1/2021	Detector Kit	<0.3
Riddle High School	D.O.	4941227	2/1/2021	Detector Kit	<0.3
Riddle High School	D.O.	5035117	2/1/2021	Detector Kit	0.4
Riddle High School	D.O.	4971659	2/1/2021	Detector Kit	<0.3
Riddle High School	RM 17	5035163	2/1/2021	Detector Kit	2.1
Riddle High School	D.O.	5035060	2/1/2021	Detector Kit	<0.3
Riddle High School	D.O. BLANK	5030059	2/1/2021	Blank	<0.3
Riddle High School	WELDING	4971327	2/1/2021	Detector Kit	0.3
Riddle High School	WELDING DUP	5035125	2/1/2021	Duplicate	0.4
Riddle High School	WOOD	4971446	2/1/2021	Detector Kit	0.9
Riddle High School	WOOD	5035269	2/1/2021	Detector Kit	0.9
Riddle High School	WOOD	4971706	2/1/2021	Detector Kit	1.0
Riddle High School	WOOD DUP	4971658	2/1/2021	Duplicate	1.0
Riddle High School	WOOD BLANK	5035102	2/1/2021	Blank	<0.3
Riddle High School	IRISH	5035107	2/1/2021	Detector Kit	11.4
Riddle High School	IRISH	5035358	2/1/2021	Detector Kit	8.9
Riddle High School	IRISH DUP	5029944	2/1/2021	Duplicate	8.9
Riddle High School	IRISH BLANK	5035154	2/1/2021	Blank	<0.3