

|                              | 6/22/2016 | 8/2/16- Lead | 8/3/16- Copper |
|------------------------------|-----------|--------------|----------------|
| HS Main entrance             | ND        |              |                |
| old gym boys locker room     | 0.09450   | 0.00636      | 0.0262         |
| new gym boys locker room     | 0.05260   | 0.00953      | 1.13           |
| elementary room 2- Meghan    | 0.01830   | 0.0266       | 0.0281         |
| old gym girls locker room    | 0.01710   | 0.0285       | 0.0397         |
| elementary hallway DF        | 0.01710   | 0.0244       | 0.0299         |
| elementary library           | 0.01430   | 0.0178       | 0.122          |
| new gym lobby - north        | 0.01420   | 0.0129       | 0.705          |
| elementary room 6 - Jill     | 0.01360   |              |                |
| elementary entrance          | 0.01130   |              |                |
| elementary room 5 - Christie | 0.00992   |              |                |
| new gym girls locker room    | 0.00863   |              |                |
| new gym cafeteria sink       | 0.00422   |              |                |
| elementary room 3 - Sue      | 0.00350   |              |                |
| HS hallway                   | 0.00241   |              |                |
| new gym lobby -south         | 0.00117   |              |                |
| shop DF                      | 0.00061   |              |                |

.020 EPA limit for the 1 cup sample size we used

.015 EPA limit for the 1 liter sample size the city uses

1.3 EPA limit for copper