



# NORTH BRUNSWICK TOWNSHIP PUBLIC SCHOOLS

Administrative Offices:  
Linwood School, 25 Linwood Place  
Post Office Box 6016  
North Brunswick, N.J. 08902  
Telephone (732) 289-3000  
[www.nbtschools.org](http://www.nbtschools.org)

Janet Ciarrocca  
Acting Superintendent of Schools  
jciarrocca@nbtschools.org  
732-289-3030

Rosa Hock  
Business Administrator/Board Secretary  
rhock@nbtschools.org  
732- 289-3020

Brian Falkowski, Ed.D.  
Assistant Business Administrator  
bfalkowski@sboffice.com  
732-289-3022

May 18, 2022

North Brunswick Township Public Schools  
John Adams Elementary School  
1450 Redmond Street  
North Brunswick, NJ 08902

Dear John Adams Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, John Adams Elementary School tested our school's drinking water for lead.

In accordance with the Department of Education regulations, John Adams Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a “DO NOT DRINK – SAFE FOR HANDWASHING ONLY” sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within North Brunswick Township Public Schools. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the forty-eight (48) samples taken, all but one (1) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlet(s) that tested above the 15 µg/l for lead, the actual lead level, and what remedial action North Brunswick Township Public Schools has taken to reduce the levels of lead at this location.

Location	First Draw Result in µg/l (ppb)	Remedial Action
Hall by Main Office ID # NB-1-B-02A	24.4	Outlet Permanently Removed from service.* *This outlet has been shut off from service since March 2020.

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily as a result of the corrosion or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning, can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.nbtschools.org](http://www.nbtschools.org). For more information about water quality in our schools, contact Paul Carroll at the North Brunswick Board of Ed, 732 289-3027.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your healthcare provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Rosa Hock

Business Administrator/Board Secretary

- c: J. Ciarrocca, Superintendent
- A. Kingsley, John Adams Principal
- P. Carroll, Supervisor of Buildings & Grounds