

Water Testing Results - Riddle High School
Lead Action Level is 20 parts per billion (ppb)
Copper Action Level is 1300 parts per billion (ppb)

Fixture Location/Description	Test Date	Result Copper	Result Lead
Annex Room 19	7/12/2016	284	30
Annex Room 18	7/12/2016	208	4
Annex Mens Bathroom	7/12/2016	177	3
Annex Drinking Fountain N	7/12/2016	177	3
Annex Womens Bathroom	7/12/2016	171	4
Annex Drinking Fountain S	7/12/2016	148	2
Gym Girls Locker Room Drinking Fountain	7/12/2016	651	113
Gym Girls Locker Room Sink	7/12/2016	141	2
Gym Boys Locker Room Drinking Fountain	7/12/2016	175	5
Gym Boys Locker Room Sink	7/12/2016	208	3
Gym Boys Locker Room Coaches Sink	7/12/2016	307	10
Gym Junior High Locker Room Drinking Fountain	7/12/2016	19	40
Gym Junior High Locker Room Sink	7/12/2016	ND	ND
Gym North Boys Bathroom Sink	7/12/2016	35	15
Gym South Boys Bathroom Sink	7/12/2016	24	6
Gym Girls Bathroom Sink	7/12/2016	12	11
Shop Bathroom Sink	7/12/2016	370	4
Shop Bathroom Drinking Fountain	7/12/2016	233	8
Shop Sink	7/12/2016	266	7
Shop Eye Wash Station	7/12/2016	187	ND
Girls Bathroom Sink	7/12/2016	23	3
Boys Bathroom Sink	7/12/2016	252	12
Main Hallway Drinking Fountain SouthEast	7/12/2016	16	4
Main Hallway Drinking Fountain SouthWest	7/12/2016	ND	13
Biology Calsroom Sink NW	7/12/2016	213	5
Biology Calsroom Sink NE	7/12/2016	263	4
Biology Calsroom Sink E	7/12/2016	986	36
Biology Calsroom Sink SW	7/12/2016	399	30
Physics Classroom Sink W	7/12/2016	20	8
Physics Classroom Sink NW	7/12/2016	1446	64

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

Water Testing Results - Riddle High School
Lead Action Level is 20 parts per billion (ppb)
Copper Action Level is 1300 parts per billion (ppb)

Fixture Location/Description	Test Date	Result Copper	Result Lead
<i>Original test results continued....</i>			
Physics Classroom Sink NE	7/12/2016	253	61
Physics Classroom Sink E	7/12/2016	826	506
Physics Classroom Sink EyeWashStation	7/12/2016	202	46
Gym Drinking Fountain	7/12/2016	206	ND
Main Drinking Fountain W	7/12/2016	ND	4
Main Drinking Fountain E	7/12/2016	ND	4
Staff Room Sink	7/12/2016	30	15
Café Hand Wash Sink	7/12/2016	38	13
Café Dish Wash Sink	7/12/2016	32	6
Café Dish Wash Sink E	7/13/2016	26	15
FACulty Room Sink SW	7/13/2016	48	8
FACulty Room Sink NW	7/13/2016	25	9
FACulty Room Sink NE	7/13/2016	66	7
FACulty Room Sink SE	7/13/2016	54	11
Office Sink	7/13/2016	184	2
Office Bathroom Sink	7/13/2016	232	7
Alt Womens Bathroom Sink	7/13/2016	339	6
Alt Mens Bathroom Sink	7/13/2016	56	ND
RETEST			
Annex Room 19	8/17/2016	ND	3
Gym Girls Locker Room Drinking Fountain	8/17/2016	184	10
Gym Junior High Locker Room Drinking Fountain	8/17/2016	18	7
Biology Classroom Sink E	8/17/2016	36	ND
Biology Classroom Sink SW	8/17/2016	79	2
Physics Classroom Sink NW	8/17/2016	234	17
Physics Classroom Sink NE	8/17/2016	94	10
Physics Classroom Sink E	8/17/2016	11	2
Physics Classroom Eye Wash Station	8/17/2016	32	5

Lab Sheets reporting in mg/L - Convert mg/L to ppb by Multiplying by 1,000