

Water Testing Results - Riddle Elementary School
Lead Action Level is 20 parts per billion (ppb)
Copper Action Level is 1300 parts per billion (ppb)

Fixture Location/Description	Test Date	Result Copper	Result Lead
Office South Sink	7/7/2016	32	29
Office Bathroom Sink	7/7/2016	17	23
Lower Hallway Sink	7/7/2016	ND	13
Café Sink South	7/7/2016	353	7
Café Drinking Fountain	7/7/2016	474	ND
Café Handwashing Sink	7/7/2016	143	8
Café Washing Sink	7/7/2016	169	23
Staff Room Sink	7/7/2016	64	110
Staff Room Bathroom Sink	7/7/2016	45	13
Room 1 South Bathroom sink	7/7/2016	94	9
Room 1 Drinking Fountian	7/7/2016	15	12
Room 1 Sink	7/7/2016	27	114
Room 1 North Bathroom Sink	7/7/2016	73	9
Room 2 South Bathroom Sink	7/7/2016	34	19
Room 2 Room Sink	7/7/2016	ND	16
Room 2 North Bathroom Sink	7/7/2016	48	13
Room 3 South Bathroom Sink	7/7/2016	72	13
Room 3 Drinking Fountain	7/7/2016	ND	9
Room 3 Room Sink	7/7/2016	69	146
Room 3 North Bathroom Sink	7/7/2016	21	13
Room 4 South Bathroom Sink	7/7/2016	93	10
Room 4 Drinking Fountain	7/7/2016	ND	8
Room 4 Room Sink	7/7/2016	13	48
Room 4 North Bathroom Sink	7/7/2016	84	14
Room 5 South Bathroom Sink	7/7/2016	111	17
Room 5 Drinking Fountain	7/7/2016	28	13
Room 5 Room Sink	7/7/2016	383	485
Room 5 North Bathroom Sink	7/7/2016	69	33
Room 6 South Bathroom Sink	7/7/2016	36	21
Room 6 Drinking Fountian	7/7/2016	ND	17
Room 6 Room Sink	7/7/2016	17	14
Room 6 North Bathroom Sink	7/7/2016	495	119
Room 7 South Bathroom Sink	7/7/2016	125	35
Room 7 Drinking Fountain	7/7/2016	ND	12
Room 7 Room Sink	7/7/2016	67	16
Room 7 North Bathroom Sink	7/7/2016	552	86
Room 8 South Bathroom Sink	7/7/2016	754	488
Room 8 Drinking Fountain	7/7/2016	36	20
Room 8 Room Sink	7/7/2016	1057	453
Room 8 North Bathroom Sink	7/7/2016	75	38
Breezway Drinking Fountain 1/2	7/7/2016	ND	8
Breezway Drinking Fountain 4/5	7/7/2016	ND	8
Breezway Drinking Fountain 6	7/7/2016	ND	12
Breezway Drinking Fountain 7	7/7/2016	ND	13
Gym Drinking Fountain West	7/7/2016	ND	7
Gym Drinking Fountain East	7/7/2016	ND	9
Gym Girls Locker Room Sink	7/7/2016	41	38
Gym Boys Locker Room Sink	7/7/2016	22	174
Hallway Drinking Fountian North	7/7/2016	ND	11
Hallway Drinking Fountian South	7/7/2016	11	12
Room 9 Drinking Fountain	7/7/2016	276	42
Room 9 Room Sink	7/7/2016	196	131
Room 10 Drinking Fountian	7/7/2016	43	9
Room 10 Room Sink	7/7/2016	160	29

ND = Non Detect - Lead level is below the set detection limits of 2 ppb

Water Testing Results - Riddle Elementary School
Lead Action Level is 20 parts per billion (ppb)
Copper Action Level is 1300 parts per billion (ppb)

Fixture Location/Description	Test Date	Result Copper	Result Lead
<i>Original test results continued</i>			
Room 11 Drinking Fountian	7/7/2016	44	19
Room 11 Room Sink	7/7/2016	216	21
Room 12 Drinking Fountain	7/7/2016	115	233
Room 12 Room Sink	7/7/2016	209	149
Room 13 Drinking Fountian	7/7/2016	68	13
Room 13 Room Sink	7/7/2016	159	41
Room 14 Drinking Fountian	7/7/2016	38	8
Room 14 Room Sink	7/7/2016	245	23
Room 15 Drinking Fountian	7/7/2016	13	13
Room 15 Room Sink	7/7/2016	143	39
Room 16 Drinking Fountian	7/7/2016	76	16
Room 16 Room Sink	7/7/2016	109	10
Room 17 Drinking Fountian	7/7/2016	61	11
Room 17 Room Sink	7/7/2016	133	26
Room 18 Drinking Fountain	7/7/2016	14	10
Room 18 Room Sink	7/7/2016	726	193
Room 19 Drinking Fountain	7/7/2016	12	37
Room 19 Room Sink	7/7/2016	136	47
RETESTS			
Office South Sink	8/17/2016	ND	ND
Office Bathroom Sink	8/17/2016	ND	ND
Café Washing Sink	8/17/2016	53	2
Staff Room Sink	8/17/2016	ND	4
Room 1 Room Sink	8/17/2016	ND	16
Room 3 Room Sink	8/17/2016	ND	ND
Room 4 Room Sink	8/17/2016	ND	ND
Room 5 Room Sink	8/17/2016	ND	ND
Room 5 North Bathroom Sink	8/17/2016	ND	ND
Room 6 South Bathroom Sink	8/17/2016	12	10
Room 6 North Bathroom Sink	8/17/2016	ND	5
Room 7 South Bathroom Sink	8/17/2016	17	ND
Room 7 North Bathroom Sink	8/17/2016	ND	2
Room 8 South Bathroom Sink	8/17/2016	ND	2
Room 8 Room Sink	8/17/2016	ND	ND
Room 8 North Bathroom Sink	8/17/2016	34	5
Gym Girls Locker Room Sink	8/17/2016	ND	23
Room 9 Drinking Fountain	8/17/2016	15	6
Room 9 Room Sink	8/17/2016	19	7
Room 10 Room Sink	8/17/2016	11	3
Room 12 Drinking Fountain	8/17/2016	ND	2
Room 12 Room Sink	8/17/2016	11	4
Room 13 Room Sink	8/17/2016	10	25
Room 14 Room Sink	8/17/2016	69	8
Room 15 Room Sink	8/17/2016	ND	3
Room 17 Room Sink	8/17/2016	ND	3
Room 18 Room Sink	8/17/2016	18	5
Room 19 Drinking Fountain	8/17/2016	ND	3
Room 19 Room Sink	8/17/2016	41	218
2nd RETESTS			
Gym Girls Locker Room Sink	9/8/2016	ND	ND
Room 19 Room Sink	9/8/2016	17	ND

Lab Sheets reporting in mg/L - Convert mg/L to ppb by Multiplying by 1,000