

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID #399073400

Client: Goodridge School
 Northwest Service CO-OP
 114 First Street West
 Thief River Falls, MN 56701

Report Number: 18-14034
Sample Receipt Date: 10/26/18
Sample Prep. Date: 10/26/18
Sample Prep. Time: 11:00
Report Issue Date: 10/29/18

Twin City Water Clinic Inc.
 617 13th Avenue South
 Hopkins, MN 55343
 Phone: (952)935-3556
 Fax: (952)935-5077

Laboratory Sample ID	Analyte	Sample Location	Parameter	Sample Collection		Sample Analysis		Test Results	Units
				Date	Time	Date	Time		
18-14034	Lead	Preschool DF	Drinking Water	10/24/18	6:30	10/29/18	13:18	<2.0	µg/L
18-14035	Lead	4th Grade DF	Drinking Water	10/24/18	6:35	10/29/18	13:54	<2.0	µg/L
18-14036	Lead	Kindergarten DF	Drinking Water	10/24/18	6:40	10/29/18	13:59	<2.0	µg/L

X No samples were subcontracted; or the above test result(s) with "*" designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant level: Lead, 15.0 µg / L

Sample Collected by: Client TCWC
 Sample Temp.: 17 ° C

Notes: DF = drinking fountain
 Discussion:

Approved By: 

Bill Van Arsdale
 Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID #399073400

Client: Goodridge School ISD 561
 Northwest Service CO-OP
 114 First Street West
 Thief River Falls, MN 56701

Report Number: 18-08803
Sample Receipt Date: 07/11/18
Sample Prep. Date: 07/11/18
Sample Prep. Time: 12:30
Report Issue Date: 07/13/18

Twin City Water Clinic Inc.
 617 13th Avenue South
 Hopkins, MN 55343
 Phone: (952)935-3556
 Fax: (952)935-5077

Laboratory Sample ID	Analyte	Sample Location	Parameter	Sample Collection Date	Time	Sample Analysis Date	Time	Test Results	Units
18-08803	Lead	Public Kitchen	Drinking Water	7/10/18	06:40	07/12/18	11:44	<2.0	µg/L
18-08804	Lead	School Kitchen 1 S	Drinking Water	7/10/18	06:50	07/12/18	11:49	<2.0	µg/L
18-08805	Lead	School Kitchen 2	Drinking Water	7/10/18	06:51	07/12/18	11:54	<2.0	µg/L
18-08806	Lead	School Kitchen 3	Drinking Water	7/10/18	06:52	07/12/18	11:59	<2.0	µg/L
18-08807	Lead	School Kitchen 4 N	Drinking Water	7/10/18	06:53	07/12/18	12:04	<2.0	µg/L
18-08808	Lead	Jims Room	Drinking Water	7/10/18	08:15	07/12/18	12:09	<2.0	µg/L
18-08809	Lead	Para 1 South	Drinking Water	7/10/18	08:21	07/12/18	12:14	<2.0	µg/L
18-08810	Lead	Para 1 North	Drinking Water	7/10/18	08:22	07/12/18	12:19	<2.0	µg/L
18-08811	Lead	Bottom Floor DF	Drinking Water	7/10/18	07:10	07/12/18	12:24	<2.0	µg/L
18-08812	Lead	2nd Floor DF	Drinking Water	7/10/18	08:45	07/13/18	11:18	<2.0	µg/L
18-08813	Lead	West Lounge sink	Drinking Water	7/10/18	08:50	07/13/18	11:23	<2.0	µg/L
18-08814	Lead	East Lounge sink	Drinking Water	7/10/18	08:52	07/13/18	11:28	<2.0	µg/L
18-08815	Lead	3rd Floor DF	Drinking Water	7/10/18	09:00	07/13/18	11:33	<2.0	µg/L
18-08816	Lead	Lobby DF	Drinking Water	7/10/18	09:10	07/13/18	11:37	<2.0	µg/L
18-08817	Lead	1st Grade DF	Drinking Water	7/10/18	09:15	07/13/18	11:42	<2.0	µg/L
18-08818	Lead	2nd Grade DF	Drinking Water	7/10/18	09:25	07/13/18	11:58	<2.0	µg/L
18-08819	Lead	3rd Grade DF	Drinking Water	7/10/18	09:35	07/13/18	12:14	<2.0	µg/L

X No samples were subcontracted; or the above test result(s) with "*" designation were produced by a subcontracted laboratory. [laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Approved methods used in analyzing the samples listed above have the following reporting levels:

SM3113 - Lead, 2.0 µg / L
 Maximum contaminant level: Lead, 15.0 µg / L

Sample Collected by: Client TCWC

Sample Temp.: 28 ° C

Notes: Sample location flushed before sample collection.

Discussion: DF = drinking fountain

Approved By:

Bill Van Arsdale
 Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.