

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: April 22, 2021
 Sample ID: 21037
 Date Analyzed: 4/19/21 – 4/20/21
 WO Number: 210406037

Customer:	Gloversville Enlarged School District	Collection Date: 4/6/21
Address:	234 Lincoln Street, Gloversville, New York 12078	Collection Time: See Chart
Sample Location:	Boulevard Elementary School	Collected by: Robert Rockwell
Sample Point:	See Chart	Potable: Yes
Water Source:	Municipal Water	Grab/Composite: Grab
Chlorinated:	Yes	Receipt Temp: Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

All test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

<= Less than
 >= Greater than
 ≈= Approximately
 ND = Not Detected at reporting limit
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10709

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: April 22, 2021

Sample ID: 21037

Date Analyzed: 4/19/21 - 4/20/21

WO Number: 210406037

Customer: Gloversville Enlarged School District

Collection Date: 4/6/21

Address: 234 Lincoln Street, Gloversville, New York 12078

Collection Time: See Chart

Sample Location: Boulevard Elementary School

Collected by: Robert Rockwell

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Boulevard School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifiers	Method
121	Room # 227 sink #2	10:06 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
30	Room # 227 sink #3	10:06 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
126	Room # 227 sink #4	10:06 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
36	Room # 227 sink #5	10:06 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
26	Room # 227 sink #6	10:06 AM	4/6/21	1.3	15.0		EPA 200.8 REV 5.4
99	Room # 225 sink	10:07 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
98	Hall drinking fountain outside Room # 228 (cooler)	10:07 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
84	Room # 224 sink	10:08 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
60	Room # 223 sink	10:08 AM	4/6/21	1.2	15.0		EPA 200.8 REV 5.4
43	Room # 222 sink	10:09 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
158	Room # 221 sink	10:10 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
24	Room # 218 sink	10:11 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
57	Room # 220 sink	10:12 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
45	Room # 217 sink	10:12 AM	4/6/21	1.1	15.0		EPA 200.8 REV 5.4
70	Room # 219 sink	10:15 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
31	Room # 216 sink	10:15 AM	4/6/21	1.2	15.0		EPA 200.8 REV 5.4
12	Room 226 sink	10:07 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: April 22, 2021

Sample ID: 21037

Date Analyzed: 4/19/21 - 4/20/21

WO Number: 210406037

Customer: Gloversville Enlarged School District

Collection Date: 4/6/21

Address: 234 Lincoln Street, Gloversville, New York 12078

Collection Time: See Chart

Sample Location: Boulevard Elementary School

Collected by: Robert Rockwell

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Boulevard School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifiers	Method
6	Boy's water fountain - low	9:36 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
38	Boy's locker room hall fountain	9:45 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
1	Library office sink	9:45 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
93	Nurses office sink	9:46 AM	4/6/21	1.4	15.0		EPA 200.8 REV 5.4
27	Room # 100 sink	9:46 AM	4/6/21	1.0	15.0		EPA 200.8 REV 5.4
109	Room # 107 fountain	9:47 AM	4/6/21	2.9	15.0		EPA 200.8 REV 5.4
34	Room # 107 sink	9:47 AM	4/6/21	2.3	15.0		EPA 200.8 REV 5.4
58	Room # 106 sink	9:39 AM	4/6/21	3.8	15.0		EPA 200.8 REV 5.4
111	Room # 106 fountain	10:00 AM	4/6/21	5.2	15.0		EPA 200.8 REV 5.4
47	Room # 101 sink	10:00 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
100	Room # 102 sink	10:01 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
54	Room # 102 fountain	10:01 AM	4/6/21	1.5	15.0		EPA 200.8 REV 5.4
28	Room # 105 sink	10:02 AM	4/6/21	3.5	15.0		EPA 200.8 REV 5.4
19	Room # 104 sink	10:02 AM	4/6/21	3.9	15.0		EPA 200.8 REV 5.4
79	Room # 104 fountain	10:03 AM	4/6/21	3.5	15.0		EPA 200.8 REV 5.4
86	Room # 103 sink	10:04 AM	4/6/21	2.2	15.0		EPA 200.8 REV 5.4
61	Room # 103 fountain	10:04 AM	4/6/21	1.8	15.0		EPA 200.8 REV 5.4
114	Second floor reading room sink	10:04 AM	4/6/21	9.3	15.0		EPA 200.8 REV 5.4
52	Room # 206 sink	10:04 AM	4/6/21	4.1	15.0		EPA 200.8 REV 5.4
32	Room # 201 sink	10:05 AM	4/6/21	2.7	15.0		EPA 200.8 REV 5.4
18	Room # 205 sink	10:05 AM	4/6/21	1.1	15.0		EPA 200.8 REV 5.4
29	Room # 202 sink	10:05 AM	4/6/21	2.9	15.0		EPA 200.8 REV 5.4
49	Room # 203 sink	10:05 AM	4/6/21	1.5	15.0		EPA 200.8 REV 5.4
72	Room # 227 sink #1	10:05 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: April 22, 2021

Sample ID: 21037

Date Analyzed: 4/19/21 - 4/20/21

WO Number: 210406037

Customer: Gloversville Enlarged School District

Collection Date: 4/6/21

Address: 234 Lincoln Street, Gloversville, New York 12078

Collection Time: See Chart

Sample Location: Boulevard Elementary School

Collected by: Robert Rockwell

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Ambient

Sample #	Boulevard School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
17	Fountain/cooler by Kitchen	9:24 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
21	Kitchen cooler	9:25 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
37	Kitchen sink	9:25 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
2	Room # 23 Sink	9:26 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
44	Room #26 sink	9:26 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
5	Room # 122 fountain	9:28 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
11	Room # 122 sink	9:28 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
76	Room # 125 fountain	9:29 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
64	Room # 125 sink	9:29 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
23	Room # 124 fountain	9:30 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
56	Room # 124 sink	9:30 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
14	Room # 121 sink	9:31 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
41	Room # 121 fountain	9:31 AM	4/6/21	ND	15.0		EPA 200.8 REV 5.4
33	Room # 167 sink	9:33 AM	4/6/21	1.9	15.0		EPA 200.8 REV 5.4
16	Lower hallway fountain by Room # 167	9:33 AM	4/6/21	1.1	15.0		EPA 200.8 REV 5.4
46	Higher hallway fountain by Room # 167	9:33 AM	4/6/21	1.4	15.0		EPA 200.8 REV 5.4
25	Room #117 sink	9:43 AM	4/6/21	6.1	15.0		EPA 200.8 REV 5.4
9	Room # 116 sink	9:42 AM	4/6/21	6.9	15.0		EPA 200.8 REV 5.4
35	Room # 110 sink	9:41 AM	4/6/21	3.9	15.0		EPA 200.8 REV 5.4
22	Room # 111 sink	9:40 AM	4/6/21	4.1	15.0		EPA 200.8 REV 5.4
39	Room # 115 sink	9:39 AM	4/6/21	4.5	15.0		EPA 200.8 REV 5.4
4	Room # 114 sink	9:38 AM	4/6/21	5.8	15.0		EPA 200.8 REV 5.4
87	Room # 112 sink	9:38 AM	4/6/21	4	15.0		EPA 200.8 REV 5.4
53	Room #113 sink	9:37 AM	4/6/21	2.6	15.0		EPA 200.8 REV 5.4