



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

November 8, 2016

Mr. Wayne McGuire  
Chautauqua Lake Central School District  
Director of Facilities  
100 North Erie Street  
Mayville, New York 14757

**Re: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. McGuire:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Ripley Central School District, including:

- Baseball and Softball Buildings, 12 North State Street, Ripley, New York

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on 9/29/2016. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 5 sources of potable water in the Baseball and Softball Buildings have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Ripley Central School District.

Sincerely,  
Stohl Environmental, LLC.

A handwritten signature in black ink, appearing to read 'William K. Sisco', is written over a horizontal line.

William K. Sisco  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**Mr. Wayne McGuire  
Ripley Central School District  
Director of Facilities  
100 North Erie Street  
Mayville, New York 14757**

**Prepared by:**



**ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES**

**4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219**

**☎ (716) 312-0070 📠 (716) 312-8092**

**[www.stohlenvironmental.com](http://www.stohlenvironmental.com)**

**Conditions as of September 29, 2016**



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## **Summary Tabulation**

### **Lead in Drinking Water Investigation**

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by Ripley Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Baseball and Softball Buildings, 12 North State Street, Ripley, New York

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from all outlets in the Baseball and Softball Buildings. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

### Sampling Protocol:

In accordance with NYS regulations, *Subpart 67-4: Lead Testing in School Drinking Water*, and the EPA guidance document, *'3Ts for Reducing Lead in Drinking Water in Schools'*, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Service Connection Sampling:** Samples were collected at the service connection as follows:
  - **Service Connection Sample:** As detailed in EPA guidance documents, this sample is not a first-draw sample. The cold water tap closest to the service connection was opened, and the sample was collected immediately after a change in water temperature was detected, or after 30 seconds.
  - **Water Main Sample:** This sample was collected at the same location as the Service Connection sample; however, it was collected after water was allowed to run an additional 3 minutes after the temperature change, but not more than 3 minutes and 30 seconds.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Baseball Building	9/29/2016	4	1	3	0	0
Softball Building	9/29/2016	3	1	2	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples				
Sample #	Sample Type	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
120.4-1	First Draw	Baseball Building North Restroom Sink	Sink	45.6
120.4-2	First Draw	Baseball Building Exterior Hose Bib	Hose Bib	18.0
120.4-4	First Draw	Baseball Building Exterior Hose Bib	Hose Bib	111
120.3-1	First Draw	Softball Building Bathroom Sink	Sink	163
120.3-3	First Draw	Softball Building Exterior Bubbler	Bubbler	69.5



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
www.stohlenvironmental.com

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

#### **1.4 Laboratory Analytical Reports by Building**



9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

## CERTIFICATE OF ANALYSIS

**Client:** Stohl Environmental  
4169 Allendale Pkwy; Suite 100  
Blasdell NY 14219

**Report Date:** 11/3/2016  
**Report No.:** 521087 - Lead Water  
**Project:** Ripley CSD - Ripley CSD Baseball 9/29/16  
**Project No.:** 2016L-120.4

**Client:** STO708

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:** 6047638  
**Client No.:** 120.4-1

**Location:** North Restroom-S

**Result(ppb):** 45.6

**Lab No.:** 6047639  
**Client No.:** 120.4-2

**Location:** Exterior-HB

**Result(ppb):** 18.0

**Lab No.:** 6047640  
**Client No.:** 120.4-3

**Location:** Interior Restroom-S

**Result(ppb):** 14.1

**Lab No.:** 6047641  
**Client No.:** 120.4-4

**Location:** Exterior-HB

**Result(ppb):** 111

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 10/4/2016

**Date Analyzed:** 11/03/2016

**Signature:**

**Analyst:** Chad Shaffer

**Approved By:**

Frank E. Ehrenfeld, III  
Laboratory Director



## CERTIFICATE OF ANALYSIS

**Client:** Stohl Environmental  
4169 Allendale Pkwy; Suite 100  
Blasdell NY 14219

**Client:** STO708

**Report Date:** 11/3/2016  
**Report No.:** 521087 - Lead Water  
**Project:** Ripley CSD - Ripley CSD Baseball 9/29/16  
**Project No.:** 2016L-120.4

### Appendix to Analytical Report:

**Customer Contact:** Lab Results Final

**Analysis:** AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

**iATL Customer Service:** customerservice@iatl.com

**iATL Office Manager:** cdavis@iatl.com

**iATL Account Representative:** Shirley Clark

**Sample Login Notes:** See Batch Sheet Attached

**Sample Matrix:** Water

**Exceptions Noted:** See Following Pages

#### General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at [www.iATL.com](http://www.iATL.com) and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

#### Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

#### Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at [customerservice@iatl.com](mailto:customerservice@iatl.com).

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.



9000 Commerce Parkway Suite B  
Mt. Laurel, New Jersey 08054  
Telephone: 856-231-9449  
Email: customerservice@iatl.com

## CERTIFICATE OF ANALYSIS

**Client:** Stohl Environmental  
4169 Allendale Pkwy; Suite 100  
Blasdell NY 14219

**Report Date:** 11/3/2016  
**Report No.:** 521086 - Lead Water  
**Project:** Ripley CSD - Ripley CSD Softball 9/29/16  
**Project No.:** 2016L-120.3

**Client:** STO708

### LEAD WATER SAMPLE ANALYSIS SUMMARY

**Lab No.:** 6047635  
**Client No.:** 120.3-1

**Location:** Bathroom-S

**Result(ppb):** 163

**Lab No.:** 6047636  
**Client No.:** 120.3-2

**Location:** Exterior-HB

**Result(ppb):** 3.90

**Lab No.:** 6047637  
**Client No.:** 120.3-3

**Location:** Exterior-B

**Result(ppb):** 69.5

Please refer to the Appendix of this report for further information regarding your analysis.

**Date Received:** 10/4/2016

**Date Analyzed:** 11/03/2016

**Signature:**

**Analyst:** Chad Shaffer

**Approved By:**

Frank E. Ehrenfeld, III  
Laboratory Director



## CERTIFICATE OF ANALYSIS

**Client:** Stohl Environmental  
4169 Allendale Pkwy; Suite 100  
Blasdell NY 14219

**Client:** STO708

**Report Date:** 11/3/2016  
**Report No.:** 521086 - Lead Water  
**Project:** Ripley CSD - Ripley CSD Softball 9/29/16  
**Project No.:** 2016L-120.3

### Appendix to Analytical Report:

**Customer Contact:** Lab Results Final

**Analysis:** AAS-GF - ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

**iATL Customer Service:** customerservice@iatl.com

**iATL Office Manager:** cdavis@iatl.com

**iATL Account Representative:** Shirley Clark

**Sample Login Notes:** See Batch Sheet Attached

**Sample Matrix:** Water

**Exceptions Noted:** See Following Pages

#### General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at [www.iATL.com](http://www.iATL.com) and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

#### Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D, USEPA 40CFR 141.11B, 2010

- USEPA 200.9Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7000B:7421 - Pb(AAS-GF, RL <2 ppb/sample)

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 2.0 PPB

#### Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at [customerservice@iatl.com](mailto:customerservice@iatl.com).

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.5 Laboratory Certifications





## Department of Health

ANDREW M. CUOMO  
Governor

HOWARD A. ZUCKER, M.D., J.D.  
Commissioner

SALLY DRESLIN, M.S., R.N.  
Executive Deputy Commissioner

LAB ID: 11021

April 01, 2016

MR. FRANK E. EHRENFELD III  
INTERNATIONAL ASBESTOS TESTING LABS  
9000 COMMERCE PARKWAY  
SUITE B  
MT LAUREL, NJ 08054

Certificate Expiration Date:  
April 01, 2017

Dear Mr. Ehrenfeld Iii,

Enclosed are certificate(s) of approval issued to your environmental laboratory for the current permit year. The certificate(s) supersede(s) any previously issued one(s) and is(are) in effect through the expiration date listed. Please carefully examine the certificate(s) to insure that the categories, subcategories, analytes, and methods for which your laboratory is approved are correct. In addition, verify that your laboratory's name, address, lead technical director, and identification number are accurate.

Pursuant to NYCRR Subpart 55-2.2, original certificates must be posted conspicuously in the laboratory and copies shall be made available to any client of the laboratory upon request.

Pursuant to NYCRR Subpart 55-2.6, any misrepresentation of the fields of accreditation (category - method - analyte) for which your laboratory is approved may result in denial, suspension, or revocation of your certification. Any use of the Environmental Laboratory Approval Program (ELAP) or National Environmental Laboratory Accreditation Program (NELAP) name, reference to the laboratory's approval status, and/or using the NELAP logo in any catalogs, advertising, business solicitations, proposals, quotations, laboratory analytical reports, or other materials must include the laboratory's ELAP identification number and distinguish between testing for which the laboratory is approved and testing for which the laboratory is not approved.

If you have any questions, please contact ELAP at the New York State Department of Health (NYS DOH), Wadsworth Center, PO Box 509, Albany NY, 12201-0509; by phone at (518) 485-5570; by facsimile at (518) 485-5568; and by email at [elap@health.ny.gov](mailto:elap@health.ny.gov).

Sincerely,

Michael P. Ryan, M.T. (ASCP), Ph.D.  
Director, Division of Laboratory Quality Certification  
Environmental Laboratory Approval Program



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FRANK E. EHRENFELD III  
INTERNATIONAL ASBESTOS TESTING LABS  
9000 COMMERCE PARKWAY SUITE B  
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total                      ASTM D3559-90, 96, 03 & 08 (D)

**Miscellaneous**

Asbestos                      EPA 100.1  
                                      EPA 100.2

NEW  
YORK  
STATE

Department  
of Health

**Serial No.: 54134**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MR. FRANK E. EHRENFELD III**  
**INTERNATIONAL ASBESTOS TESTING LABS**  
**9000 COMMERCE PARKWAY SUITE B**  
**MOUNT LAUREL, NJ 08054**

**NY Lab Id No: 11021**

*is hereby APPROVED as an Environmental Laboratory for the category*  
**ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE**  
*All approved subcategories and/or analytes are listed below:*

**Characteristic Testing**

TCLP EPA 1311

**Metals I**

Lead, Total EPA 7000B

**Miscellaneous**

Asbestos in Friable Material Item 198.1 of Manual  
EPA 600/M4/82/020  
Asbestos in Non-Friable Material-PLM Item 198.6 of Manual (NOB by PLM)  
Asbestos in Non-Friable Material-TEM Item 198.4 of Manual  
Lead in Dust Wipes EPA 7000B  
Lead in Paint EPA 7000B

**Sample Preparation Methods**

EPA 3050B

**Serial No.: 54135**

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017  
Issued April 01, 2016

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MR. FRANK E. EHRENFELD III  
INTERNATIONAL ASBESTOS TESTING LABS  
9000 COMMERCE PARKWAY SUITE B  
MOUNT LAUREL, NJ 08054

NY Lab Id No: 11021

*is hereby APPROVED as an Environmental Laboratory for the category  
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS  
All approved subcategories and/or analytes are listed below:*

**Metals I**

Lead, Total NIOSH 7082

**Miscellaneous**

Asbestos 40 CFR 763 APXA No. III

NIOSH 7402

Fibers NIOSH 7400 A RULES

NEW YORK STATE  
Department  
of Health

Serial No.: 54136

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
Buffalo, New York 14219  
(P) 716-312-0070 (F) 716-312-8092  
[www.stohlenvironmental.com](http://www.stohlenvironmental.com)

---

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.6 Chains of Custody

## Chain of Custody Document

Submitted to: (Lab Name)

Schneider /ATL

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES  
4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219  
☎ (716) 312-0070 ■ (716) 312-8892  
[www.stohlenEnvironmental.com](http://www.stohlenEnvironmental.com)

STOHL Job #

2016L-120.4

**Client:** Ripley CSD

**Contact: Wayne McGuire**

**Building:** Ripley CSD Baseball

Location: 12 N State St, Ripley, NY 14775

**LEAD**

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9

X

## Turnaround

## 5 Days

[illegible]

### Notes:

Please e-mail lab results to [labs@stohlen.com](mailto:labs@stohlen.com)

☐ If checked, also e-mail results to:

**Sampled By:** Sean Hanley

Print Name

Stohl Env: Sean Hanley

Date: 9/29/2016

Relinquished By:

Print Name

Stohl Env: Eric Henderson Jr.

Date: 9/30/2016

Received (Name / Lab):

Date:

Time:

Sample Login (Name / Lab):

Date:

Time:

**Analysis (Name / Lab):**

Date:

Time)

QA/QC Review (Name / Lab):

Date:

Time

Archived / Released:

QA/QC InterLAB Use:

Date:

Time:

Page 1 of 1

N1) Acidified 10/11/16 @ 23:00

ATL - By

