

FACT SHEET

TESTING FOR LEAD IN SCHOOLS

Senate Bill 0550

Public Act 00-0922 (Senate Bill 0550)- signed into Law by Governor Bruce Rauner on January 16, 2017, established lead testing requirements and protocols for all water sources used for cooking and drinking within some schools and day care facilities as well as requirements for water providers to compile a lead materials inventory and provide notification during water distribution work. A brief summary of the bill is included below:

SCHOOLS RESPONSIBILITY

Multiple ways for schools to pay for testing and mitigation: life safety funds, property tax levy tort liability, inter-fund transfers.

Schools are required to test all sources used for cooking and drinking in all schools where K thru 5th graders are present that were built before 1/1/2000.

Schedule Deadline:

- 12/31/2017 (constructed prior to 1/1/1987)
- 12/31/2018 (constructed between 1/1/1987—1/1/2000)
- No Action (constructed after 1/1/2000, IDPH to determine by 6/30/2019 if necessary)

Sampling protocol shall consist of 2 consecutive samples.

- The first 250 ml sample shall be a first draw sample. Water must have sat for minimum of 8 hours and a maximum of 18 hours.
- Second sample is 250 ml, taken 30 seconds after first. Leave water run entire time between 1st & 2nd sample.

Exceptions:

- Schools that have performed testing that is equal to or greater than (2 or >2 consecutive samples) can apply to IDPH for a waiver. Must send IDPH results within 120 days of receipt of results from laboratory.
- If multiple faucets use the same drain, only 1, second sample must be taken.





Caution!!!

Additional Requirements

- *Schools must use an IEPA approved laboratory for the testing.*
- *Schools must provide IDPH with sample results within 7 days of receipt of sample results (could have lab send results directly to schools and IDPH).*

If a sample exceeds 5 ppb of lead, school must notify parents of students the following:

- *Location and source exceeding 5 ppb*
- *Ways to mitigate risk*
- *Hazards of lead in drinking water (USEPA website)*

If a sample results are less than 5 ppb, schools shall use school website at a minimum to notify parents of students

Within 90 days from the effective date of this bill, IDPH must provide mitigation strategies for schools on their website.



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

November 08, 2017

Alan Olson
Pecatonica School District Unit 321
1300 Main Street
Pecatonica, IL 61063

Dear Alan Olson:

Please find enclosed the analytical results for the sample(s) the laboratory received on **10/19/17 9:30 am** and logged in under work order **7103921**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com



**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-01
Name: ED 1 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/17/17 06:30
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 16:39	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-02
Name: ED 1 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:31
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.13	ug/L		11/02/17 13:06	11/02/17 16:40	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-03
Name: ED 2 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/17/17 06:33
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.37	ug/L		11/02/17 13:06	11/02/17 16:41	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-04
Name: ED 2 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:34
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.51	ug/L		11/02/17 13:06	11/02/17 16:49	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-05
Name: ED 3 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/17/17 06:44
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.48	ug/L		11/02/17 13:06	11/02/17 16:51	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-06
Name: ED 3 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:44
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.70	ug/L		11/02/17 13:06	11/02/17 16:52	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-07
Name: ED 4 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/17/17 06:48
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 16:53	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-08
Name: ED 4 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:48
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.11	ug/L		11/02/17 13:06	11/02/17 16:54	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-09
Name: ED 9 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/17/17 07:21
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.28	ug/L		11/02/17 13:06	11/02/17 16:55	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-10
Name: ED 9 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 07:21
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	4.51	ug/L		11/02/17 13:06	11/02/17 16:56	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-11
Name: EK-S 1 FIRST
Alias: PECATONICA 321

KITCHEN
SINK

Sampled: 10/17/17 06:55
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.82	ug/L		11/02/17 13:06	11/02/17 16:58	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-12
Name: EK-S 1 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:55
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	11.7	ug/L		11/02/17 13:06	11/02/17 17:06	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-13
Name: EK-S 2 FIRST
Alias: PECATONICA 321

Kitchen Sink

Sampled: 10/17/17 06:57
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	6.83	ug/L		11/02/17 13:06	11/02/17 17:07	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-14
Name: EK-S 2 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:57
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:08	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-15
Name: EK-S 3 FIRST
Alias: PECATONICA 321

Kitchen Sink

Sampled: 10/17/17 06:59
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	9.02	ug/L		11/02/17 13:06	11/02/17 17:09	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-16
Name: EK-S 3 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 06:59
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:11	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-17
Name: EK-S 4 FIRST
Alias: PECATONICA 321

*kitchen
sink*

Sampled: 10/17/17 07:02
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	97.1	ug/L		11/02/17 13:06	11/02/17 17:12	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-18
Name: EK-S 4 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 07:02
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	37.6	ug/L		11/02/17 13:06	11/02/17 17:13	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-19
Name: ES 3 FIRST
Alias: PECATONICA 321

Sampled: 10/17/17 07:06
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	18.3	ug/L		11/02/17 13:06	11/02/17 17:14	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-20
Name: ES 3 SECOND
Alias: PECATONICA 321

Sampled: 10/17/17 07:06
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	3.49	ug/L		11/02/17 13:06	11/02/17 17:22	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-21
Name: ES 2 FIRST
Alias: PECATONICA 321

Sampled: 10/18/17 05:46
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	7.30	ug/L		11/02/17 13:06	11/02/17 17:23	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-22
Name: ES 2 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 05:56
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	5.65	ug/L		11/02/17 13:06	11/02/17 17:25	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-23
Name: M K-S 1 FIRST
Alias: PECATONICA 321

Kitchen Sink

Sampled: 10/18/17 06:23
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.72	ug/L		11/02/17 13:06	11/02/17 17:26	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-24
Name: M K-S 1 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:23
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:27	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-25
Name: M K-S 2 FIRST
Alias: PECATONICA 321

*kitchen
Sink*

Sampled: 10/18/17 06:25
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	6.45	ug/L		11/02/17 13:06	11/02/17 17:28	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-26
Name: M K-S 2 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:25
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:29	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-27
Name: M K-S 3 FIRST
Alias: PECATONICA 321

*kitchen
Sink*

Sampled: 10/18/17 06:27
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	34.9	ug/L		11/02/17 13:06	11/02/17 17:30	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-28
Name: M K-S 3 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:27
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	3.18	ug/L		11/02/17 13:06	11/02/17 17:39	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-29
Name: MD 1 FIRST
Alias: PECATONICA 321

*Drinking
Fountain*

Sampled: 10/18/17 06:32
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:40	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-30
Name: MD 1 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:30
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:41	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-31
Name: MS 1 FIRST
Alias: PECATONICA 321

Sampled: 10/18/17 06:41
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	136	ug/L		11/02/17 13:06	11/02/17 17:42	KMC	EPA 200.8
------	-----	------	--	----------------	----------------	-----	-----------

Sample: 7103921-32
Name: MS 1 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:41
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.42	ug/L		11/02/17 13:06	11/02/17 17:43	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-33
Name: MS 2 FIRST
Alias: PECATONICA 321

Sampled: 10/18/17 07:07
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.76	ug/L		11/02/17 13:06	11/02/17 17:45	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-34
Name: MS 2 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 07:07
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	2.13	ug/L		11/02/17 13:06	11/02/17 17:46	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-35
Name: MD 2 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 06:55
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	4.91	ug/L		11/02/17 13:06	11/02/17 17:47	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-36
Name: MD 2 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:55
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.61	ug/L		11/02/17 13:06	11/02/17 17:55	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-37
Name: MD 3 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 07:00
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.63	ug/L		11/02/17 13:06	11/02/17 17:56	KMC	EPA 200.8

Sample: 7103921-38
Name: MD 3 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 07:00
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.03	ug/L		11/02/17 13:06	11/02/17 17:58	KMC	EPA 200.8

Sample: 7103921-39
Name: MD 4 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 07:03
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 17:59	KMC	EPA 200.8

Sample: 7103921-40
Name: MD 4 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 07:03
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:00	KMC	EPA 200.8

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-41
Name: E CR 1 FIRST
Alias: PECATONICA 321

Sampled: 10/18/17 07:11
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	13.8	ug/L		11/02/17 13:06	11/02/17 18:01	KMC	EPA 200.8

Sample: 7103921-42
Name: E CR 1 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 07:11
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.24	ug/L		11/02/17 13:06	11/02/17 18:02	KMC	EPA 200.8

Sample: 7103921-43
Name: ED 5 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 06:04
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:03	KMC	EPA 200.8

Sample: 7103921-44
Name: ED 5 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:04
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:12	KMC	EPA 200.8

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-45
Name: ED 6 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 06:06
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:13	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-46
Name: ED 6 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:06
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:14	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-47
Name: ED 7 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 05:57
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:15	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-48
Name: ED 7 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 05:57
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:16	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

**PDC Laboratories, Inc.**

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

ANALYTICAL RESULTS

Sample: 7103921-49
Name: ED 8 FIRST
Alias: PECATONICA 321

DRINKING
FOUNTAIN

Sampled: 10/18/17 06:00
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		11/02/17 13:06	11/02/17 18:18	KMC	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-50
Name: ED 8 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 06:00
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.07	ug/L		11/02/17 13:06	11/02/17 18:19	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-51
Name: ES 1 FIRST
Alias: PECATONICA 321

Sampled: 10/18/17 05:53
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.64	ug/L		11/02/17 13:06	11/02/17 18:20	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------

Sample: 7103921-52
Name: ES 1 SECOND
Alias: PECATONICA 321

Sampled: 10/18/17 05:53
Received: 10/19/17 09:30
Matrix: Drinking Water - Regular Sample
PO #: 4530 PSCD321

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

Total Metals - PIA

Lead	1.77	ug/L		11/02/17 13:06	11/02/17 18:28	KMC	EPA 200.8
------	------	------	--	----------------	----------------	-----	-----------



PDC Laboratories, Inc.

2231 West Altorfer Drive

Peoria, IL 61615

(800) 752-6651

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615
PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD

ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT Pecatonica School District 321		P.O. NUMBER 4530 PSCD321		SCHOOL NAME Pecatonica 321		MEANS SHIPPED UPS		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # 7103921-52 LOGGED BY: <i>[Signature]</i> LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING	
ADDRESS PO Box 419 1300 Main Street		PHONE NUMBER 815-238-1256		EMAIL alanson@pecschools.com		DATE SHIPPED					
CITY STATE ZIP Pecatonica IL 61063		SAMPLER (PLEASE PRINT) Alan Olson		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER:		LEAD 200.8					
CONTACT PERSON Alan Olson		SAMPLER'S SIGNATURE <i>[Signature]</i>									
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT					DATE/TIME LAST USED
E D 1 First	10/17/17	6:30 am	250 ml	DW	1	X					10/16/17 5:00pm
E D 1 Second	10/17/17	6:31am	250 ml	DW	1	X					10/16/17 5:00pm
E D 2 First	10/17/17	6:33am	250 ml	DW	1	X					10/16/17 5:00pm
E D 2 Second	10/17/17	6:34am	250 ml	DW	1	X					10/16/17 5:00pm
E D 3 First	10/17/17	6:44am	250 ml	DW	1	X					10/16/17 5:00pm
E D 3 Second	10/17/17	6:44am	250 ml	DW	1	X					10/16/17 5:00pm
E D 4 First	10/17/17	6:48am	250 ml	DW	1	X					10/16/17 5:00pm
E D 4 SECOND	10/17/17	6:48AM	250 ml	DW	1	X					10/16/17 5:00pm
E D 9 FIRST	10/17/17	7:21AM	250 ml	DW	1	X					10/16/17 5:00pm
E D 9 SECOND	10/17/17	7:21AM	250 ml	DW	1	X					10/16/17 5:00pm
ESI First/Second		10/18/17	8:53am								
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) - NORMAL - RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE FAX # IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt of the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
RELINQUISHED BY: (SIGNATURE) <i>[Signature]</i>		DATE 10/18/17	RECEIVED BY: (SIGNATURE)		DATE		COMMENTS: (FOR LAB USE ONLY)				
RELINQUISHED BY: (SIGNATURE)		TIME 9:30 Am	RECEIVED BY: (SIGNATURE)		TIME		8				
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT				
RELINQUISHED BY: (SIGNATURE)		TIME	RECEIVED BY: (SIGNATURE)		TIME		CHILL PROCESS STARTED PRIOR TO RECEIPT				
		DATE			DATE		SAMPLE(S) RECEIVED ON ICE				
		TIME			TIME		PROPER BOTTLES RECEIVED IN GOOD CONDITION				
							BOTTLES FILLED WITH ADEQUATE VOLUME				
							SAMPLES RECEIVED WITHIN HOLD TIME(S)				
							(EXCLUDES TYPICAL FIELD PARAMETERS)				
							DATE AND TIME TAKEN FROM SAMPLE BOTTLE				

PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615
PHONE: (800) 752-6661 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD

ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Pecatonica School District 321		P.O. NUMBER 4530 PSCD321	SCHOOL NAME Pecatonica 321	MEANS SHIPPED UPS	3 ANALYSIS REQUESTED LEAD 200.8		4 (FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
ADDRESS PO Box 419 1300 Main Street		PHONE NUMBER 815-238-1256	EMAIL alanolson@pecschools.com		DATE SHIPPED			
CITY STATE ZIP Pecatonica IL 61063		SAMPLER (PLEASE PRINT) Alan Olson		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER:				
CONTACT PERSON Alan Olson		SAMPLER'S SIGNATURE 						
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE/TIME LAST USED	
E K-S 1 FIRST		10/17/17	6:55AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 1 SECOND		10/17/17	6:55AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 2 FIRST		10/17/17	6:57AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 2 SECOND		10/17/17	6:57AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 3 FIRST		10/17/17	6:59AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 3 SECOND		10/17/17	6:59AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 4 FIRST		10/17/17	7:02AM	250 ml	DW	1	X	10/16/17 5:00PM
E K-S 4 SECOND		10/17/17	7:02AM	250 ml	DW	1	X	10/16/17 5:00PM
E S 3 FIRST		10/17/17	7:06AM	250 ml	DW	1	X	10/16/17 5:00PM
E S 3 SECOND		10/17/17	7:06AM	250 ml	DW	1	X	10/16/17 5:00PM
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE FAX # IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-5.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature. _____				
RELINQUISHED BY: (SIGNATURE) 		DATE 10/18/17	RECEIVED BY: (SIGNATURE) 		DATE 10/19/17		COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: 20 °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE	
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE			
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE			

PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615
PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Pecatonica School District 321		P.O. NUMBER 4530 PSCD321		SCHOOL NAME Pecatonica 321		MEANS SHIPPED UPS		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)	
ADDRESS PO Box 419 1300 Main Street		PHONE NUMBER 815-238-1256		EMAIL alanolson@pecschools.com		DATE SHIPPED						LOGIN # LOGGED BY: LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING	
CITY STATE ZIP Pecatonica IL 61063		SAMPLER (PLEASE PRINT) Alan Olson		SAMPLER'S SIGNATURE <i>Alan Olson</i>		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWGL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER:		LEAD 200.8				DATE/TIME LAST USED	
CONTACT PERSON Alan Olson		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED							
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED		MATRIX TYPE		BOTTLE COUNT		DATE/TIME LAST USED	
E S 2 FIRST		10/18/17		5:46am		250 ml		DW		1		10/17/17 5:00PM	
E S 2 SECOND		10/18/17		5:56am		250 ml		DW		1		10/17/17 5:00PM	
M K-S 1 FIRST		10/18/17		6:23am		250 ml		DW		1		10/17/17 8:00PM	
M K-S 1 SECOND		10/18/17		6:23am		250 ml		DW		1		10/17/17 8:00PM	
M K-S 2 FIRST		10/18/17		6:25am		250 ml		DW		1		10/17/17 8:00PM	
M K-S 2 SECOND		10/18/17		6:25am		250 ml		DW		1		10/17/17 8:00PM	
M K-S 3 FIRST		10/18/17		6:27am		250 ml		DW		1		10/16/17 8:00PM	
M K-S 3 SECOND		10/18/17		6:27am		250 ml		DW		1		10/17/17 8:00PM	
M D 1 FIRST		10/18/17		6:32am		250 ml		DW		1		10/17/17 8:00PM	
M D 1 SECOND		10/18/17		6:30am		250 ml		DW		1		10/17/17 8:00PM	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0-15.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.									
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:									
7 RELINQUISHED BY: (SIGNATURE) <i>Alan Olson</i>		DATE 10/18/17		TIME 9:30 AM		RECEIVED BY: (SIGNATURE)		DATE		TIME		8 COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME		SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME			
								10/19/17		930		10 °C Y OR N Y OR N Y OR N Y OR N	

PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615
PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD

ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Pecatonica School District 321		P.O. NUMBER 4530 PSCD321		SCHOOL NAME Pecatonica 321		MEANS SHIPPED UPS		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS PO Box 419 1300 Main Street		PHONE NUMBER 815-238-1256		EMAIL alanolson@pecschools.com		DATE SHIPPED				LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
CITY STATE ZIP Pecatonica IL 61063		SAMPLER (PLEASE PRINT) Alan Olson		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER: _____							
CONTACT PERSON Alan Olson		SAMPLER'S SIGNATURE <i>Alan Olson</i>									
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED		MATRIX TYPE	BOTTLE COUNT	LEAD 200.8		DATE/TIME LAST USED	
M S 1 FIRST		10/18/17	6:41 am	250	ml	DW	1	X			10/17/17 4:00PM
M S 1 SECOND		10/18/17	6:41am	250	ml	DW	1	X			10/17/17 4:00PM
M S 2 FIRST		10/18/17	7:07am	250	ml	DW	1	X			10/17/17 8:00PM
M S 2 SECOND		10/18/17	7:07am	250	ml	DW	1	X			10/17/17 8:00PM
M D 2 FIRST		10/18/17	6:55am	250	ml	DW	1	X			10/17/17 8:00PM
M D 2 SECOND		10/18/17	6:55am	250	ml	DW	1	X			10/17/17 8:00PM
M D 3 FIRST		10/18/17	7:00am	250	ml	DW	1	X			10/17/17 8:00PM
M D 3 SECOND		10/18/17	7:00am	250	ml	DW	1	X			10/17/17 8:00PM
M D 4 FIRST		10/18/17	7:03am	250	ml	DW	1	X			10/17/17 8:00PM
M D 4 SECOND		10/18/17	7:03am	250	ml	DW	1	X			10/17/17 8:00PM
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis. If the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:							
7 RELINQUISHED BY: (SIGNATURE) <i>Alan Olson</i>		DATE 10/18/17	TIME 9:30 AM	RECEIVED BY: (SIGNATURE)		DATE		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT			
		DATE	TIME			DATE		SAMPLE(S) RECEIVED ON ICE			
		DATE	TIME			DATE		PROPER BOTTLES RECEIVED IN GOOD CONDITION			
		DATE	TIME			DATE		BOTTLES FILLED WITH ADEQUATE VOLUME			
		DATE	TIME			DATE		SAMPLES RECEIVED WITHIN HOLD TIME(S)			
		DATE	TIME			DATE		(EXCLUDES TYPICAL FIELD PARAMETERS)			
		DATE	TIME			DATE		DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615
PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD

ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Pecatonica School District 321		P.O. NUMBER		SCHOOL NAME Pecatonica 321		MEANS SHIPPED UPS		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS PO Box 419 1300 Main Street		PHONE NUMBER 815-238-1256		EMAIL alanolson@pecschools.com		DATE SHIPPED				LOGIN # LOGGED BY: LAB PROJ. # TEMPLATE: PROJ. MGR: KURT STEPPING	
CITY STATE ZIP Pecatonica IL 61063		SAMPLER (PLEASE PRINT) Alan Olson		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCH- LEACHATE OTHER:							
CONTACT PERSON Alan Olson		SAMPLER'S SIGNATURE									
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED		MATRIX TYPE	BOTTLE COUNT	LEAD 200.8		DATE/TIME LAST USED	
E CR 1 FIRST		10/17/17	7:11AM	250	ml	DW	1	X			10/16/17 5:00PM
E CR 1 SECOND		10/17/17	7:11AM	250	ml	DW	1	X			10/16/17 5:00PM
E D 5 FIRST		10/18/17	6:04	250	ml	DW	1	X			10/17/17 5:00PM
E D 5 SECOND		10/18/17	6:04	250	ml	DW	1	X			10/17/17 5:00PM
E D 6 FIRST		10/18/17	6:06	250	ml	DW	1	X			10/17/17 5:00PM
E D 6 SECOND		10/18/17	6:06	250	ml	DW	1	X			10/17/17 5:00PM
E D 7 FIRST		10/18/17	5:57	250	ml	DW	1	X			10/17/17 5:00PM
E D 7 SECOND		10/18/17	5:57	250	ml	DW	1	X			10/17/17 5:00PM
E D 8 FIRST		10/18/17	6:00	250	ml	DW	1	X			10/17/17 5:00PM
E D 8 SECOND		10/18/17	6:00	250	ml	DW	1	X			10/17/17 5:00PM
ESI First/Second		10/18/17	5:53 AM								
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:							
7 RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME	SAMPLE TEMPERATURE UPON RECEIPT 20 °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N PROPER BOTTLES RECEIVED IN GOOD CONDITION Y OR N BOTTLES FILLED WITH ADEQUATE VOLUME Y OR N SAMPLES RECEIVED WITHIN HOLD TIME(S) Y OR N (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE 10/19/17 930			
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)		DATE	TIME				