

SECTION 009113 - ADDENDA

1.1 PROJECT INFORMATION

- A. Project Name: Roof Structure and Ventilation Improvements Coffin Elementary School.
- B. Owner: Brunswick School Department.
- C. Bid Administrator: Scott Smith.
- D. Architect: CHA Architects.
- E. Architect Project Number: 065974.
- F. Date of Addendum: 1 July 2021.

1.2 NOTICE TO BIDDERS

- A. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is changed to the following, at same time and location.
 - 1. **Bid Date: 8 July 2021.**

1.3 THE FOLLOWING QUESTIONS HAVE BEEN RECEIVED BY BIDDERS BY PHONE OR BY E-MAIL

- A. **Question:** Need air distribution requirements for the duct sock along with color and fabric type. <https://www.ductsox.com/design/air-dispersion> In the ductwork documentation requirement it talks about fire dampers, backdraft dampers(BDD), counter balance dampers (CBD), and access doors. They are not labeled on the drawing. Also it makes more sense to come out of the equipment as rectangular all the way to the ductsox transition instead of going from Rec->round across roof-> and back multiple times. Also on the return duct keep as rectangular all the way to the return grill.

Answer: Ductsox information is in the specifications. Other items listed in specifications which are not called out on drawings are not needed. Ductwork layout is intentional, and changes will not be considered at this time. Should the need arise, alternative layouts can be considered at a later date.

- B. **Question:** Bid documents refer to bid being delivered to 46 Brunswick Street. I am assuming this is meant to be 46 Federal Street.

Answer: Correct, thank you for noticing the error.

END OF ADDENDUM #2