



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

March 02, 2020

Kevin Lawton
Cairo Durham CSD
Main Street
PO Box 780
Cairo, NY 12413

TEL: (518) 622-8534

Work Order No: 200220004

PO#: 19-00129

RE:

H.S/M.S

Dear Kevin Lawton:

Adirondack Environmental Services, Inc received 52 samples on 2/19/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Monica Higdon
Laboratory Manager

ELAP#: 10709

Adirondack Environmental Services, Inc**CASE NARRATIVE****CLIENT:** Cairo Durham CSD**Date:** 02-Mar-20**Project:****Lab Order:** 200220004

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted**The results relate only to the items tested. Information supplied by the client is assumed to be correct.**

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-001**Collection Date:** 2/19/2020**Client Sample ID:** E252**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:26:38 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-002**Collection Date:** 2/19/2020**Client Sample ID:** E253**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:37:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-003**Collection Date:** 2/19/2020**Client Sample ID:** E254**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:41:33 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-004**Collection Date:** 2/19/2020**Client Sample ID:** E255**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:45:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-005**Collection Date:** 2/19/2020**Client Sample ID:** TOS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:49:01 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:** H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-006**Collection Date:** 2/19/2020**Client Sample ID:** HSOS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/21/2020 5:52:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-007**Collection Date:** 2/19/2020**Client Sample ID:** NOBS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 6:01:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-008**Collection Date:** 2/19/2020**Client Sample ID:** NOS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	3.7	1.0		µg/L	1	2/24/2020 6:05:44 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-009**Collection Date:** 2/19/2020**Client Sample ID:** MSTLS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	3.9	1.0		µg/L	1	2/24/2020 6:09:30 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-010**Collection Date:** 2/19/2020**Client Sample ID:** PSBRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	7.1	1.0		µg/L	1	2/24/2020 6:13:14 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-011**Collection Date:** 2/19/2020**Client Sample ID:** A3BRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.8	1.0		µg/L	1	2/24/2020 6:16:58 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-012**Collection Date:** 2/19/2020**Client Sample ID:** A3GRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 6:28:10 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-013**Collection Date:** 2/19/2020**Client Sample ID:** A3AB1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 6:31:54 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-014**Collection Date:** 2/19/2020**Client Sample ID:** PSGRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.6	1.0		µg/L	1	2/24/2020 6:35:38 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-016**Collection Date:** 2/19/2020**Client Sample ID:** C-12 BRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 6:50:35 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:** H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-017**Collection Date:** 2/19/2020**Client Sample ID:** HSWSS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	3.0	1.0		µg/L	1	2/24/2020 6:54:20 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-018**Collection Date:** 2/19/2020**Client Sample ID:** C-14 GRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 6:58:05 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-019**Collection Date:** 2/19/2020**Client Sample ID:** MSCOS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	6.6	1.0		µg/L	1	2/24/2020 7:01:51 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-020**Collection Date:** 2/19/2020**Client Sample ID:** MSKS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	3.3	1.0		µg/L	1	2/24/2020 7:05:35 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-021**Collection Date:** 2/19/2020**Client Sample ID:** B-12 GRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.6	1.0		µg/L	1	2/24/2020 7:16:48 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD

LabWork Order: 200220004

Project:

PO#: 19-00129

H.S/M.S

Lab SampleID: 200220004-022

Collection Date: 2/19/2020

Client Sample ID: B-12 BRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/20/2020)

Lead	3.1	1.0		µg/L	1	2/24/2020 7:35:29 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-023

Collection Date: 2/19/2020

Client Sample ID: MSCRC

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/20/2020)

Lead	33.6	1.0	X	µg/L	1	2/24/2020 7:39:13 PM
------	------	-----	---	------	---	----------------------

Lab SampleID: 200220004-024

Collection Date: 2/19/2020

Client Sample ID: E-3 BRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 7:42:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-025

Collection Date: 2/19/2020

Client Sample ID: E-3 GRS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 7:46:43 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-026

Collection Date: 2/19/2020

Client Sample ID: RRCS

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/20/2020)

Lead	1.8	1.0		µg/L	1	2/24/2020 7:50:28 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-027**Collection Date:** 2/19/2020**Client Sample ID:** RRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 7:54:14 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-028**Collection Date:** 2/19/2020**Client Sample ID:** HSKDSL**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 7:57:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-029**Collection Date:** 2/19/2020**Client Sample ID:** HSKDSR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 8:01:43 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-030**Collection Date:** 2/19/2020**Client Sample ID:** HSKIM**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 8:05:28 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-031**Collection Date:** 2/19/2020**Client Sample ID:** HSKBS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.1	1.0		µg/L	1	2/24/2020 8:16:40 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-032**Collection Date:** 2/19/2020**Client Sample ID:** HSKISF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 8:27:54 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-033**Collection Date:** 2/19/2020**Client Sample ID:** HSKISB**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.4	1.0		µg/L	1	2/24/2020 8:31:39 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-034**Collection Date:** 2/19/2020**Client Sample ID:** HSKK**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	23.3	1.0	X	µg/L	1	2/24/2020 8:35:24 PM
------	------	-----	---	------	---	----------------------

Lab SampleID: 200220004-035**Collection Date:** 2/19/2020**Client Sample ID:** HSKSS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.1	1.0		µg/L	1	2/24/2020 8:39:09 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-036**Collection Date:** 2/19/2020**Client Sample ID:** HSCBRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 8:42:54 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-037**Collection Date:** 2/19/2020**Client Sample ID:** HSCGRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 8:46:39 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-038**Collection Date:** 2/19/2020**Client Sample ID:** HSE5S**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.2	1.0		µg/L	1	2/24/2020 8:50:24 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-039**Collection Date:** 2/19/2020**Client Sample ID:** E1S**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:01:37 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-040**Collection Date:** 2/19/2020**Client Sample ID:** E2SC**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:05:22 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-041**Collection Date:** 2/19/2020**Client Sample ID:** E2SIR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:16:37 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:**
H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-042**Collection Date:** 2/19/2020**Client Sample ID:** A3AB2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.7	1.0		µg/L	1	2/24/2020 9:27:52 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-043**Collection Date:** 2/19/2020**Client Sample ID:** HSHBR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	2.1	1.0		µg/L	1	2/24/2020 9:31:37 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-044**Collection Date:** 2/19/2020**Client Sample ID:** HSHGR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:35:22 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-045**Collection Date:** 2/19/2020**Client Sample ID:** HSHLR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	2.5	1.0		µg/L	1	2/24/2020 9:46:36 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-046**Collection Date:** 2/19/2020**Client Sample ID:** HSHMR**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:50:21 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Mar-20

CLIENT: Cairo Durham CSD**LabWork Order:** 200220004**Project:** H.S/M.S**PO#:** 19-00129**Lab SampleID:** 200220004-047**Collection Date:** 2/19/2020**Client Sample ID:** HSOB**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 9:54:07 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200220004-048**Collection Date:** 2/19/2020**Client Sample ID:** HSPHS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.1	1.0		µg/L	1	2/24/2020 9:57:52 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200220004-049**Collection Date:** 2/19/2020**Client Sample ID:** MSOB1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	1.0	1.0		µg/L	1	2/24/2020 10:01:38 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200220004-050**Collection Date:** 2/19/2020**Client Sample ID:** MSOB2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 10:05:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200220004-051**Collection Date:** 2/19/2020**Client Sample ID:** MSGLRS**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	ND	1.0		µg/L	1	2/24/2020 10:09:08 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc**Date:** 02-Mar-20**CLIENT:** Cairo Durham CSD**LabWork Order:** 200220004**Project:****PO#:** 19-00129

H.S/M.S

Lab SampleID: 200220004-052**Collection Date:** 2/19/2020**Client Sample ID:** MSB7S**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/20/2020)

Lead	6.0	1.0		µg/L	1	2/24/2020 10:20:25 PM
------	-----	-----	--	------	---	-----------------------



Experience is the solution

314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

CHAIN OF CUSTODY RECORD

AES Work Order #

200220004

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: CAIRO-DURHAM		Address: P.O. BOX 780 CAIRO, N.Y. 12413						
Send Report To: K. LAWTON		Project Name (Location): H.S. 1005		Samplers: (Names) S. PRINELLA				
Client Phone No: 622-8543		Client Email: FAX 622-9566		PO Number:		Samplers: (Signature) 		
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=a.m. P=p.m.	Sample Type Matrix	Comp	Grab	Number of Cont's	Analysis Required
01 E252	E-2 SINK 2	2-19-20	8:30	(A) PW		X	1	LEAD
02 E253	E-2 SINK 3	2-19-20	8:30	(A) PW		X	1	LEAD
03 E254	E-2 SINK 4	2-19-20	8:30	(A) PW		X	1	LEAD
04 E255	E-2 SINK 5	2-19-20	8:30	(A) PW		X	1	LEAD
05 TOS	TRANS. OFFICE SINK	2-19-20	8:30	(A) PW		X	1	LEAD
06 HSOS	H.S. OFFICE SINK	2-19-20	8:30	(A) PW		X	1	LEAD
07 NOBS	NURSE OFF. BATH SINK	2-19-20	8:35	(A) PW		X	1	LEAD
08 NOS	NURSE OFF. SINK	2-19-20	8:35	(A) PW		X	1	LEAD
09 MSTS	M.S. TEACH LOUNGE SINK	2-19-20	8:35	(A) PW		X	1	LEAD
10	WCS SINK	2-19-20	8:40	(A) PW		X	1	LEAD
10 PSBRS	POPE SER. BOYS RM. SINK	2-19-20	8:40	(A) PW		X	1	LEAD
11 A3BRS	A-3 Boy Room Sink	2-19-20	8:40	(A) PW		X	1	Lead
12 A3GRS	A-3 Girls Room Sink	2-19-20	8:40	(A) PW		X	1	Lead
13 A3ABI	A-3 Adult Bath 1	2-19-20	8:45	(A) PW		X	1	Lead

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other: _____		CC Report To / Special Instructions/Remarks: PLEASE FAX RESULTS TO: NYS DOH 1-607-432-0089 PWS # 1916150	
Turnaround Time Request: <input type="checkbox"/> 1 Day <input type="checkbox"/> 3 Day <input checked="" type="checkbox"/> Normal <input type="checkbox"/> 2 Day <input type="checkbox"/> 5 Day <small>Note: Samples received after 3:30 pm are considered next business day</small>			
Relinquished by: (Signature) 		Received by: (Signature) 	Date/Time
Relinquished by: (Signature)		Received by: (Signature)	Date/Time
Relinquished by: (Signature) 		Received for Laboratory by: 	Date/Time 2/19/20 1:09 PM
TEMPERATURE Ambient or Chilled Notes: _____	AES Bottles Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	PROPERLY PRESERVED Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	RECEIVED WITHIN HOLDING TIMES Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

WHITE - Lab Copy

YELLOW - Sampler Copy

Adirondack Environmental Service



200220004



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

CHAIN OF CUSTODY RECORD

AES Work Order #

200220004

Experience is the solution

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: CAIRO-DURHAM		Address: P.O. BOX 780 CAIRO N.Y. 12413	
Send Report To: K. LAWTON		Project Name (Location): H.S./M.S.	
Client Phone No: 622-8543		Client Email: FAX 622-9566	
PO Number:		Samplers: (Names) J. PINNELLA	
PO Number:		Samplers: (Signature) <i>[Signature]</i>	

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=a.m. P=p.m.	Sample Type			Number of Cont's	Analysis Required
				Matrix	Comp	Grab		
14	PSGRS Pup. Ser. BR. Sink	2-19-20	9	A	PW		✓ 1	Lead
15	BLRS M.S. Boys Locker RM. Sink	2-19-20	9:10	A	PW		✓ 1	Lead
16	C-12BRS C-12 Boys Room Sink	2-19-20	9:10	A	PW		✓ 1	Lead
17	HSWSS H.S. Wood Shop Sink	2-19-20	9:15	A	PW		✓ 1	Lead
18	C-14GRS C-14 Girls RM. Sink	2-19-20	9:15	A	PW		✓ 1	Lead
19	MSCOS M.S. Cafe outside Spicet	2-19-20	9:20	A	PW		✓ 1	Lead
20	MSKS M.S. Cafe ^{KITCHEN} Sink	2-19-20	9:20	A	PW		✓ 1	Lead
21	B-12GRS B-12 Girls Room Sink	2-19-20	9:25	A	PW		✓ 1	Lead
22	B-12BRS B-12 Boys Room Sink	2-19-20	9:25	A	PW		✓ 1	Lead
23	MSCRC M.S. custodial RM. cafe	2-19-20	9:30	A	PW		✓ 1	Lead
24	E-3BRS E-3 boys RM. Sink	2-19-20	9:30	A	PW		✓ 1	Lead
25	E-3GRS E-3 Girls RM. Sink	2-19-20	9:30	A	PW		✓ 1	Lead
26	RRCS Recieve RM outside spicet	2-19-20	9:40	A	PW		✓ 1	Lead
27	RRS Recieve RM Sink	2-19-20	9:40	A	PW		✓ 1	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____		CC Report To / Special Instructions/Remarks: PLEASE FAX RESULTS TO: NYSDOH 1-607-432-0089 PWS# 1916150	
Turnaround Time Request: <input type="checkbox"/> 1 Day <input type="checkbox"/> 3 Day <input checked="" type="checkbox"/> Normal <input type="checkbox"/> 2 Day <input type="checkbox"/> 5 Day <small>Note: Samples received after 3:30 pm are considered next business day</small>			
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature) <i>[Signature]</i>	
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature) <i>[Signature]</i>	
Relinquished by: (Signature) <i>[Signature]</i>		Received for Laboratory by: <i>[Signature]</i>	
Date/Time 2/19/20 1:09 PM			
TEMPERATURE Ambient or Chilled Notes: _____		AES Bottles Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Notes: _____	
PROPERLY PRESERVED Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Notes: _____		RECEIVED WITHIN HOLDING TIMES Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Notes: _____	

WHITE - Lab Copy

YELLOW - Sampler Copy

PINK - Generator Copy

Adirondack Environmental Services, Inc.



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

CHAIN OF CUSTODY RECORD

AES Work Order #

200220004

Experience is the solution

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: CAIRO-DURHAM CSD		Address: P.O. BOX 780 CAIRO, N.Y. 12413						
Send Report To: K. LAUTON		Project Name (Location): HIGH SCHOOL / H.S.			Samplers: (Names): S. PINNELLA			
Client Phone No: 622-8543		Client Email: FAX 622-9566		PO Number:		Samplers: (Signature): <i>[Signature]</i>		
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=a.m. P=p.m.	Sample Type			Number of Cont's	Analysis Required
				Matrix	Comp	Grab		
28 HSKDSL	H.S. KIT. DEEPSINK LEFT	2-19-20	8:15	(A) P	PW		X 1	LEAD
029 HSKDSR	H.S. KIT. DEEP SINK RIGHT	2-19-20	8:15	(K) P	PW		X 1	LEAD
030 HSKIM	H.S. KIT. ICE MAKER	2-19-20	8:15	(A) P	PW		X 1	LEAD
031 HSKBS	H.S. KIT. BATH SINK	2-19-20	8:15	(A) P	PW		X 1	LEAD
032 HSKISF	H.S. KIT ISLAND SINK FRONT	2-19-20	8:15	(A) P	PW		X 1	LEAD
033 HSKISB	H.S. KIT ISLAND SINK BACK	2-19-20	8:20	(A) P	PW		X 1	LEAD
034 HSKK	H.S. KIT. KETTLE	2-19-20	8:20	(A) P	PW		X 1	LEAD
035 HSKSS	H.S. KIT. SMALL SINK	2-19-20	8:20	(A) P	PW		X 1	LEAD
036 HSCORS	H.S. CAFE BOYS RM. SINK	2-19-20	8:20	(A) P	PW		X 1	LEAD
037 HSCORS	H.S. CAFE GIRLS RM. SINK	2-19-20	8:40	(A) P	PW		X 1	LEAD
038 HSESS	E5 SINK	2-19-20	8:50	(A) P	PW		X 1	LEAD
039 HEB	E-1 SINK	2-19-20	8:50	(A) P	PW		X 1	LEAD
040 E2SC	E2 SINK CENTER	2-19-20	8:50	(A) P	PW		X 1	LEAD
041 E2SIR	E2 SINK 1 RIGHT	2-19-20	8:50	(A) P	PW		X 1	LEAD

Shipment Arrived Via: FedEx UPS Client AES Other: _____		CC Report To / Special Instructions/Remarks: PLEASE FAX RESULTS TO: NYS DOH 1-607-432-0089 PWS # 1916150	
Turnaround Time Request: <input type="checkbox"/> 1 Day <input type="checkbox"/> 3 Day <input checked="" type="checkbox"/> Normal <input type="checkbox"/> 2 Day <input type="checkbox"/> 5 Day <small>Note: Samples received after 3:30 pm are considered next business day</small>			
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature) <i>[Signature]</i>	Date/Time 2/19/20 11:09 PM
Relinquished by: (Signature)		Received by: (Signature)	Date/Time
Relinquished by: (Signature)		Received for Laboratory by:	Date/Time
TEMPERATURE Ambient or Chilled Notes: _____	AES Bottles Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	PROPERLY PRESERVED Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Notes: _____	RECEIVED WITHIN HOLDING TIMES Y <input checked="" type="checkbox"/> N <input type="checkbox"/> Notes: _____

WHITE - Lab Copy

YELLOW - Sampler Copy

PINK - Generator Copy

Adirondack Environmental Services, Inc.



314 North Pearl Street
Albany, New York 12207
518-434-4546/434-0891 FAX

CHAIN OF CUSTODY RECORD

AES Work Order #

200220004

Experience is the solution

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: CAIRO-DURHAM		Address: P.O. Box 780 CAIRO N.Y. 12413							
Send Report To: K. LAWTON		Project Name (Location): HS-MS				Samplers: (Names): S. PINNELLA			
Client Phone No: 622-8543		Client Email: 622-9566		PO Number:		Samplers: (Signature): <i>[Signature]</i>			
AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=a.m. P=p.m.	Sample Type			Number of Cont's	Analysis Required	
				Matrix	Comp	Grab			
42	A3AB2 A-3 Adult Bath 2	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	Lead
43	HSHBR H.S. ^{Hall} Boys RM	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	Lead
44	HSHGR H.S. Hall Girls RM	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	Lead
45	HSHLR H.S. Hall Ladies RM	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	Lead
46	HSHMR H.S. Hall Men's RM	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	Lead
47	MSOBA U.S. OFF. BATH SINK	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	LEAD
48	HSPHS HS MHS. SINK	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	LEAD
49	MSOBA U.S. OFF. BATH 1	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	LEAD
50	MSOBA2 U.S. OFF. BATH 2	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	LEAD
51	MSGIRS U.S. GIRL LOCKER ^{ROOM}	2-19-20	8	<input checked="" type="radio"/> P	PW		x	1	LEAD
52	MSB7S MS B-7 SINK	2-19-20	9	<input checked="" type="radio"/> P	PW		x	1	LEAD
				A					
				P					
				A					
				P					
				A					
				P					

Shipment Arrived Via:

FedEx UPS Client AES Other: _____

Turnaround Time Request:

☐ 1 Day ☐ 3 Day ☒ Normal
☐ 2 Day ☐ 5 Day

Note: Samples received after 3:30 pm are considered next business day

CC Report To / Special Instructions/Remarks:

PLEASE FAX RESULTS TO:
NYSDOH 1-607-432-0089
PWS: #1916150

Relinquished by: (Signature)

Received by: (Signature)

Date/Time

Relinquished by: (Signature)

Received by: (Signature)

Date/Time

Relinquished by: (Signature)

Received for Laboratory by:

Date/Time

2/19/20 1:09 PM

TEMPERATURE

Ambient or Chilled

AES Bottles

☒ Y ☐ N

PROPERLY PRESERVED

☒ Y ☐ N

RECEIVED WITHIN HOLDING TIMES

☒ Y ☐ N

Notes:

Notes:

Notes:

WHITE - Lab Copy

YELLOW - Sampler Copy

PINK - Generator Copy

Adirondack Environmental Services, Inc.



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.