



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 408170

Matrix Drinking Water
Received 03/11/21
Reported 03/12/21

Attn:
Project: Silver Creek CSD
Location: 1 Dickinson Street
Number: 2001357

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
408170-001	1C-51B	E199N Bubbler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
408170-002	1C-52B	E199N Bubbler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	8.31	5.00	µg/L	03/12/21	DLJ
408170-003	1C-52BF	E119N Bottle Fill					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
408170-004	1C-1B	E299B Bubbler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
408170-005	1C-53B	E299N Bubbler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
408170-006	1C-54B	E299N Bubbler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
408170-007	1C-54BF	E299N Bottle Fill					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ

408170-03/12/21 06:05 PM

Reviewed By: **Jennifer Lee**
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	408170
-----------------	--------

Matrix Drinking Water
Received 03/11/21
Reported 03/12/21

Attn:
Project: Silver Creek CSD
Location: 1 Dickinson Street
Number: 2001357

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified

State	Certificate Number
New York	ELAP 61370
Virginia	VELAP 11110

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117
 804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
 www.slabin.com • info@slabin.com

R 7

408170

V:\408\408170

fghraizi
UPS

3/11/2021 10:17:27 AM
1Z2E28999070253251

Submitting Co. Labella Associates		State of Collection NY	Cert. Required <input type="checkbox"/> YES <input type="checkbox"/> NO
300 Pearl Street Suite 130		Acct #	Phone 716.710.3056
Buffalo, NY 14202		Email dbanach@labellapc.com	
Project Name	Silver Creek CSD	PO #	
Project Location	1 Dickinson Street	Special Instructions:	
Project Number	2201357	Analyze by method EPA 200.9 REV 2.2	
Collected By	Derek Banach		

Turn Around Time **	Matrix	Tests/Analytes (Select ALL that Apply) Blank spaces are for additional analytes			
<input type="checkbox"/> 2 Hour * <input type="checkbox"/> Same day * <input type="checkbox"/> 1 business day <input type="checkbox"/> 2 business days <input type="checkbox"/> 3 business days <input checked="" type="checkbox"/> 5 business days <small>* not available for all tests ** past 3 PM the TAT will begin next business day Please schedule rush tests in advance</small>	<input type="checkbox"/> Air <input type="checkbox"/> Paint <input type="checkbox"/> Soil <input type="checkbox"/> Wipe <input type="checkbox"/> Bulk <input type="checkbox"/> Waste Water <input type="checkbox"/> Ground Water <input checked="" type="checkbox"/> Drinking Water <input type="checkbox"/> TSP / PM10 <input type="checkbox"/> _____	Asbestos in Bulk	Metals Total	TCLP	Microbiology
		<input type="checkbox"/> PLM <input type="checkbox"/> PLM Qualitative <input type="checkbox"/> 400 Point Count <input type="checkbox"/> 1000 Point Count <input type="checkbox"/> Gravimetric Prep	<input checked="" type="checkbox"/> Lead <input type="checkbox"/> RCRA 8 Metals <input type="checkbox"/> Chromium VI <input type="checkbox"/> Mercury <input type="checkbox"/> _____	<input type="checkbox"/> Lead <input type="checkbox"/> RCRA 8 Metals <input type="checkbox"/> Full TCLP <small>(w/ organics 10 Day)</small>	<input type="checkbox"/> BACT (MPN/PA) <input type="checkbox"/> Mold Direct Exam <input type="checkbox"/> Allergens
		Asbestos in Air	Gravimetric	Miscellaneous	Sub-Contract
		<input type="checkbox"/> PCM <input type="checkbox"/> PCM-B Rules	<input type="checkbox"/> Total Dust NIOSH 0500 <input type="checkbox"/> Resp. Dust NIOSH 0600	<input type="checkbox"/> Silica FTIR (7602) <input type="checkbox"/> _____	<input type="checkbox"/> TEM Chatfield <input type="checkbox"/> TEM AHERA <input type="checkbox"/> TEM 7402 <input type="checkbox"/> Silica XRD (7500)

Sample #	Date Sampled	Time Sampled	Sample Identification (Employee, Bldg, Material, Type ¹)	Wipe Area	Time ²		Flow Rate ³		Total Air ⁴
					Start	Stop	Start	Stop	
			see Attached						
			Box 3						

For Aqueous and Solid samples ensure enough sample is sent for duplicate and spike analysis

¹Type: A=Area, B=Blank, P=Personal, E=Excursion ²Beginning/End of Sample Period ³Liters/Minute ⁴Volume in Liters [time in min x flow in L/min]

Relinquished By: Derek Banach Signature: [Signature] Date/Time 3/8/21 Sam

! ALL SHADED FIELDS MUST BE FILLED TO AVOID DELAYS !



LaBella

Powered by partnership.

300 Pearl Street, Suite 130 | Buffalo, NY 14202 | p 716-551-6281 | f 716-551-6282
www.labellapc.com

School	Silver Creek CSD					
Date	3/6/2021					
Sample #	Location	Outlet Type	Time	Manufacturer	Model #	Notes
1C-51B	E199N	Bubbler	8:07 AM			
1C-52B	E199N	Bubbler	8:08 AM			
1C-52BF	E199N	Bottle Fill	8:08 AM			
1C-1B	E299B	Bubbler	8:12 AM			
1C-53B	E299N	Bubbler	8:21 AM			
1C-54B	E299N	Bubbler	8:22 AM			
1C-54BF	E299N	Bottle Fill	8:22 AM			