

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	1	FAUCET	1F-1	E212	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	2	FAUCET	1F-2	E211	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	3	FAUCET	1F-3	E210	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	4	FAUCET	1F-4	E209	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	5	FAUCET	1F-5	E208	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	6	FAUCET	1F-6	E207	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	7	FAUCET	1F-7	E295-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	8	FAUCET	1F-8	E296-boys bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	9	FAUCET	1F-9	slop sink	10/11/2016	G		106	MAD/DS	* missed when flushing.
SCCSD	10	FAUCET	1F-10	E205	10/11/2016	G		18.4	MAD/DS	
SCCSD	11	FAUCET	1F-11	E204	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	12	FAUCET	1F-12	E203	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	13	FAUCET	1F-13	E202	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	14	FAUCET	1F-14	E201	10/11/2016	G		18.1	MAD/DS	
SCCSD	15	FAUCET	1F-15	E200	10/11/2016	G		17.5	MAD/DS	
SCCSD	16	FAUCET	1F-16	E219	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	17	FAUCET	1F-17	E219B-boys bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	18	FAUCET	1F-18	E219C-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	19	FAUCET	1F-19	E218	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	20	FAUCET	1F-20	E218-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	21	FAUCET	1F-21	E217	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	22	FAUCET	1F-22	E217-bathroom	10/11/2016	G		18.7	MAD/DS	
SCCSD	23	FAUCET	1F-23	E216	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	24	FAUCET	1F-24	E216-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	25	FAUCET	1F-25	E215	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	26	FAUCET	1F-26	E215-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	27	FAUCET	1F-27	E214	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	28	FAUCET	1F-28	E214-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	29	FAUCET	1F-29	E213	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	30	FAUCET	1F-30	E213-bathroom	10/11/2016	G		16.3	MAD/DS	
SCCSD	31	FAUCET	1F-31	E114	10/11/2016	G		15.7	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	32	FAUCET	1F-32	E113	10/11/2016	G		16	MAD/DS	
SCCSD	33	FAUCET	1F-33	E112	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	34	FAUCET	1F-34	E111	10/11/2016	G		16.1	MAD/DS	
SCCSD	35	FAUCET	1F-35	E110	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	36	FAUCET	1F-36	E109	10/11/2016	G		23.9	MAD/DS	
SCCSD	37	FAUCET	1F-37	E195-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	38	FAUCET	1F-38	E196-boys bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	39	FAUCET	1F-39	slop sink	10/11/2016	G		21.7	MAD/DS	
SCCSD	40	FAUCET	1F-40	E107	10/11/2016	G		31.9	MAD/DS	
SCCSD	41	FAUCET	1F-41	E105A-boys bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	42	FAUCET	1F-42	E105	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	43	FAUCET	1F-43	E105B-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	44	FAUCET	1F-44	E101C-bathroom	10/11/2016	G		22.4	MAD/DS	
SCCSD	45	FAUCET	1F-45	E102B-bathroom	10/11/2016	G		17.4	MAD/DS	
SCCSD	46	FAUCET	1F-46	E102	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	47	FAUCET	1F-47	E101-copy room	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	48	FAUCET	1F-48	E124E-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	49	FAUCET	1F-49	E124E	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	50	BUBBLER	1A-15	E124-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	51	FAUCET	1F-51	E119C-slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	52	FAUCET	1F-52	E120	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	53	FAUCET	1F-53	E120A-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	54	FAUCET	1F-54	E119	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	55	FAUCET	1F-55	E119A-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	56	FAUCET	1F-56	E118	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	57	FAUCET	1F-57	E118A-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	58	FAUCET	1F-58	M414 slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	59	FAUCET	1F-59	M415	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	60	FAUCET	1F-60	M417	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	61	FAUCET	1F-61	ADA bathrm. Elem.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	62	FAUCET	1F-62	2000 wing bathrm.	10/11/2016	G		<15ppb	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	63	FAUCET	1F-63	M426	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	64	FAUCET	1F-64	M429-bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	65	FAUCET	1F-65	M429	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	66	FAUCET	1F-66	M432	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	67	FAUCET	1F-67	M433	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	68	FAUCET	1F-68	M433 - island	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	69	FAUCET	1F-69	M434-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	70	FAUCET	1F-70	M434-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	71	FAUCET	1F-71	Tub sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	72	FAUCET	1F-72	E129B-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	73	FAUCET	1F-73	E127B-boys bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	74	FAUCET	1F-74	Boys bathroom hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	75	FAUCET	1F-75	girls bathroom hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	76	COOLER	1C-19	Elem. Hallway 2nd f	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	77	FAUCET	1F-77	E125 sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	78	FAUCET	1F-78	E125 sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	79	FAUCET	1F-79	H262	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	80	FAUCET	1F-80	H263-slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	81	FAUCET	1F-81	H251B-girls shower	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	82	FAUCET	1F-82	H253-boys shower	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	83	FAUCET	1F-83	H254 - slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	84	FAUCET	1F-84	M300	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	85	FAUCET	1F-85	M303	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	86	FAUCET	1F-86	M304	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	87	FAUCET	1F-87	M305	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	88	FAUCET	1F-88	M306 -1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	89	FAUCET	1F-89	M306-2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	90	FAUCET	1F-90	M308	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	91	FAUCET	1F-91	M309	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	92	FAUCET	1F-92	boys #1 sink jr. wing	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	93	FAUCET	1F-93	boys #2 sink jr.wing	10/11/2016	G		<15ppb	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	94	FAUCET	1F-94	boys #3 sink jr. wing	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	95	FAUCET	1F-95	girls #1 sink jr. wing	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	96	FAUCET	1F-96	girls #2 sink jr. wing	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	97	FAUCET	1F-97	girls #3 sink jr. wing	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	98	FAUCET	1F-98	slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	99	FAUCET	1F-99	M310	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	100	FAUCET	1F-100	slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	101	FAUCET	1F-101	girls bathrm. 90 win	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	102	FAUCET	1F-102	boys bathrm.90 win	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	103	FAUCET	1F-103	M314 - sink #1	10/11/2016	G		16.7	MAD/DS	
SCCSD	104	FAUCET	1F-104	M314 - sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	105	FAUCET	1F-105	M314 - sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	106	FAUCET	1F-106	M314 - sink #4	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	107	FAUCET	1F-107	M314 - sink #5	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	108	FAUCET	1F-108	slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	109	FAUCET	1F-109	H178 - sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	110	FAUCET	1F-110	H178 - sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	111	FAUCET	1F-111	H178A - storage	10/11/2016	G		23.1	MAD/DS	
SCCSD	112	FAUCET	1F-112	H180 - island	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	113	FAUCET	1F-113	H171 - boys sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	114	FAUCET	1F-114	H171 - boys sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	115	FAUCET	1F-115	H173 - girls sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	116	FAUCET	1F-116	H173 - girls sink #2	10/11/2016	G		15.7	MAD/DS	Bathroom
SCCSD	117	FAUCET	1F-117	H173 - girls sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	118	FAUCET	1F-118	H174-island	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	119	FAUCET	1F-119	H174-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	120	FAUCET	1F-120	H174-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	121	FAUCET	1F-121	H175-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	122	FAUCET	1F-122	H175-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	123	FAUCET	1F-123	H175-sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	124	FAUCET	1F-124	H175-sink #4	10/11/2016	G		<15ppb	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	125	FAUCET	1F-125	H175-sink #5	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	126	FAUCET	1F-126	H175-sink #6	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	127	FAUCET	1F-127	H175-sink #7	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	128	FAUCET	1F-128	H175-sink #8	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	129	FAUCET	1F-129	H177B-boys bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	130	FAUCET	1F-130	H175C-girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	131	FAUCET	1F-131	M315-sink #1	10/11/2016	G		42.9	MAD/DS	science room
SCCSD	132	FAUCET	1F-132	M315-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	133	FAUCET	1F-133	M315-sink #3	10/11/2016	G		16.8	MAD/DS	
SCCSD	134	FAUCET	1F-134	M315-sink #4	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	135	FAUCET	1F-135	M315-sink #5	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	136	FAUCET	1F-136	H267 - girls bathrm.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	137	FAUCET	1F-137	H270-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	138	FAUCET	1F-138	H270-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	139	FAUCET	1F-139	H270-handwash #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	140	FAUCET	1F-140	H270-handwash #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	141	FAUCET	1F-141	H271A-handwash #	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	142	FAUCET	1F-142	H279A-girls bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	143	FAUCET	1F-143	H279B-boys bathrm	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	144	FAUCET	1F-144	H223	10/11/2016	G		230	MAD/DS	*missed when flushing
SCCSD	145	FAUCET	1F-145	H237-girls locker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	146	FAUCET	1F-146	H237-girls locker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	147	FAUCET	1F-147	H271A-sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	148	FAUCET	1F-148	H270-sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	149	FAUCET	1F-149	H219B boys snk.#1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	150	FAUCET	1F-150	H219B boys snk.#2	10/11/2016	G		32.8	MAD/DS	Bathroom
SCCSD	151	FAUCET	1F-151	H219B boys snk.#3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	152	FAUCET	1F-152	H219A girls snk.#1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	153	FAUCET	1F-153	H219A girls snk.#2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	154	FAUCET	1F-154	H219A girls snk.#3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	155	FAUCET	1F-155	H223A	10/11/2016	G		23.6	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	156	FAUCET	1F-156	H121	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	157	FAUCET	1F-157	H.S. Main office girl:	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	158	FAUCET	1F-158	H.S. Main office boy	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	159	FAUCET	1F-159	H105	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	160	FAUCET	1F-160	H102	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	161	FAUCET	1F-161	H127D	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	162	FAUCET	1F-162	H127B	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	163	FAUCET	1F-163	H128B	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	164	FAUCET	1F-164	H221-slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	165	FAUCET	1F-165	H157-slop sink	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	166	FAUCET	1F-166	H142-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	167	FAUCET	1F-167	H142-sink #2	10/11/2016	G		19.8	MAD/DS	
SCCSD	168	FAUCET	1F-168	H145-sink #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	169	FAUCET	1F-169	H145-sink #2	10/11/2016	G		27.8	MAD/DS	
SCCSD	170	FAUCET	1F-170	H145-sink #3	10/11/2016	G		25.9	MAD/DS	
SCCSD	171	FAUCET	1F-171	H141-sink #1	10/11/2016	G		19.1	MAD/DS	
SCCSD	172	FAUCET	1F-172	H149-sink #1	10/11/2016	G		18.7	MAD/DS	
SCCSD	173	FAUCET	1F-173	H149-sink #2	10/11/2016	G		32.8	MAD/DS	
SCCSD	174	FAUCET	1F-174	H149-sink #3	10/11/2016	G		33.3	MAD/DS	
SCCSD	175	FAUCET	1F-175	H154-sink #1	10/11/2016	G		26.9	MAD/DS	
SCCSD	176	FAUCET	1F-176	H154-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	177	FAUCET	1F-177	H154-sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	178	FAUCET	1F-178	H155-sink #1	10/11/2016	G		24.4	MAD/DS	
SCCSD	179	FAUCET	1F-179	H155-sink #2	10/11/2016	G		17.7	MAD/DS	
SCCSD	180	FAUCET	1F-180	H155-sink #3	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	181	FAUCET	1F-181	H156-sink #1	10/11/2016	G		23.4	MAD/DS	
SCCSD	182	FAUCET	1F-182	H156-sink #2	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	183	FAUCET	1F-183	H156-sink #3	10/11/2016	G		18.8	MAD/DS	
SCCSD	184	FAUCET	1F-184	H101 basement	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	185	FAUCET	1F-185	BG111	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	186	FAUCET	1F-186	BG girls bathroom	10/11/2016	G		<15ppb	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	187	FAUCET	1F-187	BG Boys bathroom	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	188	FAUCET	1F-188	BG102 garage	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	189	FAUCET	1F-189	concession kitchen	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	190	FAUCET	1F-190	concession boys	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	191	FAUCET	1F-191	concession girls	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	192	SERVICE	1S-1	receiving	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	193	MAIN	1M-1	receiving	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	194	COOLER	1C-1	elem. Hallway 2nd.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	195	COOLER	1C-2	elem. Hallway 1st.	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	196	COOLER	1C-3	2000 wing hallway	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	197	COOLER	1C-4	elem. Gym girls side	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	198	COOLER	1C-5	elem. Gym boys side	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	199	COOLER	1C-6	H253-boys locker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	200	COOLER	1C-7	H251-girls locker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	201	COOLER	1C-8	junior wing hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	202	COOLER	1C-9	senior wing hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	203	COOLER	1C-10	crow common hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	204	COOLER	1C-11	band/choral hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	205	COOLER	1C-12	H.S. gym girls	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	206	COOLER	1C-13	H.S. gym boys	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	207	COOLER	1C-14	H.S. lobby hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	208	COOLER	1C-15	H.S. bus. wing hall	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	209	COOLER	1C-16	H001-basement	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	210	COOLER	1C-17	BG102-maint. area	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	211	COOLER	1C-18	concession stand	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	212	ICE maker	1E-1	H265-ice maker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	213	ICE maker	1E-2	H271-ice maker	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	214	BUBBLER	1A-1	E218-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	215	BUBBLER	1A-2	E217-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	216	BUBBLER	1A-3	E216-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	217	BUBBLER	1A-4	E215-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	

Silver Creek Central District  
 Test Dates: 9/24/16 9/26/16  
 Test Results Rec'd.: 10/11/16

Lead Water Testing Results  
 Acceptable Levels Are Less  
 Than 15 Parts Per Billion (ppb)

Sample Location Key:  
 E - Elementary  
 M - Middle School  
 H - High School

Name	Sample #	Outlet Type	Sample ID	Sample Location/Room	Date Rec'd.	Sample Type Classification	Flush Length (N/A)	Lead (ppb)	Collector	Notes
SCCSD	218	BUBBLER	1A-5	E214-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	219	COOLER	1C-20	Elem. Hallway 1st fl	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	220	BUBBLER	1A-7	E120-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	221	BUBBLER	1A-8	E119-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	222	BUBBLER	1A-9	E118-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	223	BUBBLER	1A-10	M415-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	224	BUBBLER	1A-11	M429-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	225	BUBBLER	1A-12	M432-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	226	BUBBLER	1A-13	M433-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	227	BUBBLER	1A-14	M434-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	228	BUBBLER	1A-16	M407-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	229	BUBBLER	A1-17	M406-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	230	BUBBLER	A1-18	M405-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	231	BUBBLER	A1-19	M404-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	232	FAUCET	1F-192	slop sink elem. 2nd	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	233	FAUCET	1F-193	M407	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	234	FAUCET	1F-194	M406	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	235	FAUCET	1F-195	M405	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	236	FAUCET	1F-196	M404	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	237	FAUCET	1F-197	M410	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	238	BUBBLER	A1-20	M410-BUBBLER	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	239	FAUCET	1F-198	H136	10/11/2016	G		32.4	MAD/DS	
SCCSD	240	FAUCET	1F-199	H148	10/11/2016	G		19.6	MAD/DS	
SCCSD	241	FAUCET	1F-200	H149-sink #4	10/11/2016	G		16.5	MAD/DS	
SCCSD	242	FAUCET	1F-201	H173 - slop sink	10/11/2016	G		15.1	MAD/DS	
SCCSD	243	COOLER	1C-21	H306 #1	10/11/2016	G		<15ppb	MAD/DS	
SCCSD	244	COOLER	1C-22	H306 #2	10/11/2016	G		<15ppb	MAD/DS	