

Public Notice: School Lead Water Sample Results

Information concerning the lead level results for drinking water samples taken at

name of school

Maine law requires schools to test all drinking water faucets that could be used for drinking or cooking purposes for the presence of lead. This law further requires that parents and staff are made aware of all of the sample results.

During the period of _____ to _____
begin date *end date*

Water samples were collected from _____ water fixtures.
locations

Any sites producing elevated levels of lead (exceeding 4 parts per billion, or ppb), and therefore the faucets of most concern, are listed in the table on the following page(s).

Results for all drinking water outlets tested can be viewed here:

Enter website address or physical location

Statewide test results for Maine schools can also be found the on Maine DWP website at: www.medwp.com/schools.html

How does lead get into the water? When lead is present in water, it typically leaches, or dissolves, into water flowing through plumbing and fixtures *inside* a building from sources such as solder, pipes, or the faucets themselves. The school's well water or water provided by your local water district are unlikely sources of lead.

What are the Health Effects of exposure to lead in drinking water? Infants and children who drink water containing high levels of lead can experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink water containing excess levels of lead over many years could develop kidney problems or high blood pressure.

What level of lead is safe? No level of lead is safe. Because of the potential serious health risks, both the Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control and Prevention (CDC) agree that there is no known safe level of lead in a child's blood.

Please be aware that this sampling is done under conditions that are optimal for identifying lead in water. By having the water sit unused for many hours, lead that might be leaching from pipes or fittings is more easily discovered. However, *these levels are likely not the level of lead present in the drinking water throughout the school day.*

What can I do? Here are a few steps you can take to reduce the risk of your child being exposed to lead through school drinking water:

- Provide your child with bottled water or water from your home to reduce their usage of school drinking water outlets. Be sure to sample your home water for lead, too.
- Remind your child to let the water run for 30 seconds before drinking or filling a water bottle at school, which will lower any possible lead concentration.
- Consult your doctor if you have any specific health concerns.

School Fixtures with Elevated Lead Results (exceeding 4 parts per billion)

**Additional tables may be attached if your school has more than 20 collection sites with elevated lead levels.*

	Collection Date	Collection Site	Concentration (ppb)
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			

What is Being Done:

To correct the problem(s), we have taken these actions:

Future plans for the reduction of high lead levels in our drinking water include:

These actions are expected to be completed on:

(Date)



Information about Lead in Drinking Water for Students, Staff, and Parents



Health Effects of Lead

If too much lead enters your body from drinking water or other sources, serious health problems can occur, including damage to the brain and kidneys and interference with the production of oxygen-carrying red blood cells.

The greatest risk of lead exposure is to infants, young children, and pregnant women: During pregnancy, the fetus receives lead from the mother, which may affect brain development. In children, the continuing effects of lead on the brain have been linked to lowered IQ. Furthermore, lead is stored in the bones and can be released later in life, so, adults who were exposed to high levels of lead earlier in life may still encounter kidney problems and high blood pressure.

Sources of Lead

Lead can be found in many places; knowing the sources of lead can help limit your contact with it. Although most of the reported cases of lead poisoning in Maine have been a result of lead paint dust, exposure can also occur through drinking and cooking with water that has lead, as it can dissolve into water from solder or brass faucets, fittings, and valves. Exposure to lead can also come from jobs and hobbies that utilize materials containing lead, as well as from things you buy such as toys and antiques.

How Lead Got into Your Water

The most likely source of lead in your water is leaching from lead solder on your pipes or out of brass plumbing materials found in faucets, fittings, and valves.

Steps You Can Take to Protect Yourself from Lead in Drinking Water

- Run the water for at least 30 seconds or until it becomes noticeably colder before using it for drinking or cooking. The longer water sits in piping, the greater the chance that lead might leach in.
- Use cold water for drinking and cooking as well as for preparing baby formula. Hot water dissolves lead more quickly than cold water.
- Clean your faucet aerator (screen) regularly.
- Consider using bottled water or a water filter for drinking and cooking.

* Remember: Boiling the water does *not* reduce lead levels.

Find Out More

For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at <http://www.epa.gov/lead>, or contact the Maine Childhood Lead Poisoning Prevention Program (866-292-3474) or your health care provider. Your doctor can answer questions about having your child tested for lead.



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Mt View Middle School
575 Mount View Rd
Thorndike, ME 04986

Date Printed: 12/06/2022
Work Order #: 2211-03906
Client Job #: 569
Date Received: 11/18/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



A & L LABORATORY



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER


DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-001	1st floor middle- Fountain	I	DWF	11/17/2022 06:10AM	<1	ppb			DG-NH	11/28/2022 08:30PM
2211-03906-002	1st floor middle- Bottle fill station	I	DWF	11/17/2022 06:10AM	<1	ppb			DG-NH	11/28/2022 08:34PM
2211-03906-003	M104- Science utility sink #1	I	OT	11/17/2022 06:12AM	56.4	ppb			JLR-NH	12/02/2022 03:48PM
2211-03906-004	M104- Science utility sink #2	I	OT	11/17/2022 06:12AM	<1	ppb			DG-NH	11/28/2022 08:37PM
2211-03906-005	M104- Science utility sink #3	I	OT	11/17/2022 06:12AM	2.3	ppb			DG-NH	11/28/2022 08:41PM
2211-03906-006	M104- Science utility sink #4	I	OT	11/17/2022 06:12AM	1.7	ppb			DG-NH	11/28/2022 08:45PM
2211-03906-007	M104- Science utility sink #5	I	OT	11/17/2022 06:13AM	3.0	ppb			DG-NH	11/28/2022 08:48PM
2211-03906-008	M104- Science utility sink #6	I	OT	11/17/2022 06:13AM	2.4	ppb			DG-NH	11/28/2022 08:52PM
2211-03906-009	M104- Science utility sink #7	I	OT	11/17/2022 06:13AM	1.4	ppb			DG-NH	11/28/2022 08:56PM
2211-03906-010	M108- Kitchen sink #1	I	KF	11/17/2022 06:15AM	<1	ppb			DG-NH	11/28/2022 09:14PM
2211-03906-011	M108- Kitchen sink #2	I	KF	11/17/2022 06:15AM	<1	ppb			DG-NH	11/28/2022 09:17PM
2211-03906-012	M108- Kitchen sprayer #1	I	KF	11/17/2022 06:16AM	<1	ppb			DG-NH	11/28/2022 09:21PM
2211-03906-013	M108- Kitchen sprayer #2	I	KF	11/17/2022 06:16AM	<1	ppb			DG-NH	11/28/2022 09:24PM
2211-03906-014	M108- Kitchen bathroom handwash sink	I	KF	11/17/2022 06:17AM	<1	ppb			DG-NH	11/28/2022 09:28PM
2211-03906-015	M223- Mens bathroom handwash sink 2 bay #1	I	OT	11/17/2022 06:22AM	<1	ppb			DG-NH	11/28/2022 09:32PM
2211-03906-016	M223- Mens bathroom handwash sink 2 bay #2	I	OT	11/17/2022 06:22AM	<1	ppb			DG-NH	11/28/2022 09:35PM
2211-03906-017	M224- Womens bathroom handwash sink 2 bay #1	I	OT	11/17/2022 06:21AM	<1	ppb			DG-NH	11/28/2022 09:39PM



Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-018	M224- Womens bathroom handwash sink 2 bay #2	I	OT	11/17/2022 06:21AM	1.8	ppb			DG-NH	11/28/2022 09:53PM
2211-03906-019	M222- Kitchen sink	I	KF	11/17/2022 06:24AM	<1	ppb			DG-NH	11/28/2022 09:57PM
2211-03906-020	M222- Sprayer	I	KF	11/17/2022 06:24AM	1.5	ppb			JLR-NH	12/02/2022 03:51PM
2211-03906-021	M204- Science utility sink #1	I	OT	11/17/2022 06:26AM	21.6	ppb			DG-NH	11/28/2022 10:08PM
2211-03906-022	M204- Science utility sink #2	I	OT	11/17/2022 06:27AM	1.2	ppb			DG-NH	11/28/2022 10:12PM
2211-03906-023	M204- Science utility sink #3	I	OT	11/17/2022 06:27AM	3.1	ppb			DG-NH	11/28/2022 10:15PM
2211-03906-024	M204- Science utility sink #4	I	OT	11/17/2022 06:27AM	2.5	ppb			DG-NH	11/28/2022 10:19PM
2211-03906-025	M204- Science utility sink #5	I	OT	11/17/2022 06:28AM	889	ppb			JLR-NH	12/02/2022 03:54PM
2211-03906-026	M204- Science utility sink #6	I	OT	11/17/2022 06:28AM	2.8	ppb			DG-NH	11/28/2022 10:22PM
2211-03906-027	M204- Science utility sink #7	I	OT	11/17/2022 06:28AM	4.7	ppb			DG-NH	11/28/2022 10:26PM
2211-03906-028	M216- Mens bathroom handwash sink 3 bay #1	I	OT	11/17/2022 06:29AM	2.0	ppb			DG-NH	11/28/2022 10:37PM
2211-03906-029	M216- Mens bathroom handwash sink 3 bay #3	I	OT	11/17/2022 06:30AM	2.4	ppb			DG-NH	11/28/2022 10:40PM
2211-03906-030	M215-Womens bathroom handwash sink 3 bay #2	I	OT	11/17/2022 06:31AM	2.5	ppb			DG-NH	11/28/2022 10:44PM
2211-03906-031	M215-Womens bathroom handwash sink 3 bay #3	I	OT	11/17/2022 06:31AM	2.1	ppb			DG-NH	11/28/2022 10:48PM
2211-03906-032	M215/ 216- Fountain	I	DWF	11/17/2022 06:32AM	<1	ppb			DG-NH	11/28/2022 10:59PM
2211-03906-033	M215/ 216- Bottle fill station	I	DWF	11/17/2022 06:32AM	<1	ppb			DG-NH	11/28/2022 11:02PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY



A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER


DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-034	Mid 3rd floor-Mens BR handwash sink 3 bay #1	I	OT	11/17/2022 06:35AM	1.4	ppb			DG-NH	11/28/2022 11:06PM
2211-03906-035	Mid 3rd floor-Mens BR handwash sink 3 bay #2	I	OT	11/17/2022 06:35AM	2.2	ppb			DG-NH	11/28/2022 11:09PM
2211-03906-036	Mid 3rd floor-Mens BR handwash sink 3 bay #3	I	OT	11/17/2022 06:35AM	1.7	ppb			DG-NH	11/28/2022 11:24PM
2211-03906-037	Mid 3rd floor- Womens BR handwash sink 3 bay #1	I	OT	11/17/2022 06:36AM	2.4	ppb			DG-NH	11/28/2022 11:27PM
2211-03906-038	Mid 3rd floor- Womens BR handwash sink 3 bay #2	I	OT	11/17/2022 06:36AM	2.0	ppb			DG-NH	11/28/2022 11:31PM
2211-03906-039	Mid 3rd floor- Womens BR handwash sink 3 bay #3	I	OT	11/17/2022 06:36AM	1.9	ppb			DG-NH	11/28/2022 11:35PM
2211-03906-040	Mid 3rd floor- Fountain	I	DWF	11/17/2022 06:37AM	<1	ppb			DG-NH	11/28/2022 11:38PM
2211-03906-041	Mid 3rd floor- Bottle fill station	I	DWF	11/17/2022 06:38AM	<1	ppb			DG-NH	11/28/2022 11:42PM
2211-03906-042	M304- Science utility sink #1	I	OT	11/17/2022 06:40AM	928	ppb			JLR-NH	12/02/2022 03:57PM
2211-03906-043	M304- Science utility sink #2	I	OT	11/17/2022 06:39AM	<1	ppb			DG-NH	11/28/2022 11:53PM
2211-03906-044	M304- Science utility sink #3	I	OT	11/17/2022 06:39AM	3.7	ppb			DG-NH	11/28/2022 11:57PM
2211-03906-045	M304- Science utility sink #4	I	OT	11/17/2022 06:40AM	1.4	ppb			DG-NH	11/29/2022 12:07AM
2211-03906-046	M304- Science utility sink #5	I	OT	11/17/2022 06:41AM	12.9	ppb			DG-NH	11/29/2022 12:11AM
2211-03906-047	M304- Science utility sink #6	I	OT	11/17/2022 06:41AM	1.1	ppb			DG-NH	11/29/2022 12:15AM
2211-03906-048	M304- Science utility sink #7	I	OT	11/17/2022 06:41AM	<1	ppb			DG-NH	11/29/2022 12:18AM
2211-03906-049	Middle gym mens locker room- Handwash sink #1	I	OT	11/17/2022 06:00AM	<1	ppb			DG-NH	11/29/2022 12:22AM



Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-050	Middle gym mens locker room- Handwash sink #2	I	OT	11/17/2022 06:00AM	<1	ppb			DG-NH	11/29/2022 12:25AM
2211-03906-051	Middle gym mens locker room- Shower #1	I	OT	11/17/2022 06:00AM	96.4	ppb			JLR-NH	12/02/2022 04:01PM
2211-03906-052	Middle gym mens locker room- Shower #2	I	OT	11/17/2022 06:00AM	33.0	ppb			DG-NH	11/29/2022 12:29AM
2211-03906-053	Middle gym mens locker room- Shower #3	I	OT	11/17/2022 06:01AM	27.2	ppb			JLR-NH	12/02/2022 04:04PM
2211-03906-054	Middle gym womens locker room- Handwash #1	I	OT	11/17/2022 05:56AM	2.1	ppb			DG-NH	11/29/2022 12:33AM
2211-03906-055	Middle gym womens locker room- Handwash #2	I	OT	11/17/2022 05:57AM	1.4	ppb			JLR-NH	11/29/2022 01:29PM
2211-03906-056	Middle gym womens locker room- Shower #1	I	OT	11/17/2022 05:57AM	464	ppb			JLR-NH	12/02/2022 04:07PM
2211-03906-057	Middle gym womens locker room- Shower #2	I	OT	11/17/2022 05:57AM	28.4	ppb			JLR-NH	11/29/2022 01:32PM
2211-03906-058	Middle gym womens locker room- Shower #3	I	OT	11/17/2022 05:58AM	222	ppb			JLR-NH	11/29/2022 01:35PM
2211-03906-059	Hall off kitchen nurse station-Mens BR HW sink	I	OT	11/17/2022 05:53AM	<1	ppb			JLR-NH	11/29/2022 01:38PM
2211-03906-060	Hall off kitchen nurse station-Womens BR HW sink	I	OT	11/17/2022 05:54AM	<1	ppb			JLR-NH	11/29/2022 01:41PM
2211-03906-061	Hall off kitchen C117-Kitchen sink	I	KF	11/17/2022 05:51AM	<1	ppb			JLR-NH	11/29/2022 01:43PM
2211-03906-062	Hall off kitchen C117-Coffee maker	I	KF	11/17/2022 05:51AM	2.1	ppb			JLR-NH	12/06/2022 12:15AM
2211-03906-063	Hall off kitchen C117-Fridge	I	KF	11/17/2022 05:48AM	<1	ppb			JLR-NH	11/29/2022 01:46PM
2211-03906-064	Hall off kitchen Mens BR-Handwash sink #1	I	OT	11/17/2022 05:45AM	1.1	ppb			JLR-NH	11/29/2022 01:49PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-065	Hall off kitchen-Mens BR- Handwash sink #2	I	OT	11/17/2022 05:45AM	1.2	ppb			JLR-NH	11/29/2022 01:52PM
2211-03906-066	Hall off kitchen- Mens BR- Handwash sink #3	I	OT	11/17/2022 05:45AM	<1	ppb			JLR-NH	11/29/2022 01:55PM
2211-03906-067	Hall off kitchen-Womens BR- Handwash sink #1	I	OT	11/17/2022 05:44AM	<1	ppb			JLR-NH	11/29/2022 02:10PM
2211-03906-068	Hall off kitchen- Womens BR- Handwash sink #2	I	OT	11/17/2022 05:44AM	<1	ppb			JLR-NH	11/29/2022 02:13PM
2211-03906-069	Hall off kitchen- Womens BR- Handwash sink #3	I	OT	11/17/2022 05:44AM	<1	ppb			JLR-NH	11/29/2022 02:16PM
2211-03906-070	Hall off kitchen- Fountain-Low	I	DWF	11/17/2022 05:42AM	<1	ppb			JLR-NH	11/29/2022 02:19PM
2211-03906-071	Hall off kitchen-Fountain-High	I	DWF	11/17/2022 05:42AM	<1	ppb			JLR-NH	11/29/2022 02:21PM
2211-03906-072	Hall off kitchen-Bottle fill station	I	DWF	11/17/2022 05:43AM	<1	ppb			JLR-NH	11/29/2022 02:27PM
2211-03906-073	Mid/ Ele- Cafeteria handwash #1	I	KF	11/17/2022 05:40AM	<1	ppb			JLR-NH	11/29/2022 02:30PM
2211-03906-074	Mid/ Ele- Cafeteria handwash #2	I	KF	11/17/2022 05:40AM	<1	ppb			JLR-NH	11/29/2022 02:33PM
2211-03906-075	Kitchen- Handwash sink #1	I	KF	11/17/2022 05:25AM	<1	ppb			JLR-NH	11/29/2022 02:45PM
2211-03906-076	Kitchen- Handwash sink #2	I	KF	11/17/2022 05:26AM	<1	ppb			JLR-NH	12/05/2022 10:34AM
2211-03906-077	Kitchen- Handwash sink #3	I	KF	11/17/2022 05:27AM	<1	ppb			JLR-NH	11/29/2022 02:48PM
2211-03906-078	Kitchen- Handwash sink #4	I	KF	11/17/2022 05:27AM	<1	ppb			JLR-NH	11/29/2022 02:57PM
2211-03906-079	Kitchen- Handwash sink #5	I	KF	11/17/2022 05:28AM	<1	ppb			JLR-NH	11/29/2022 03:00PM
2211-03906-080	kitchen- Prep sink #1	I	KF	11/17/2022 05:29AM	1.4	ppb			JLR-NH	11/29/2022 03:02PM
2211-03906-081	Kitchen- Prep sink #2	I	KF	11/17/2022 05:30AM	1.4	ppb			JLR-NH	11/29/2022 03:05PM
2211-03906-082	Kitchen- Sprayer #1	I	KF	11/17/2022 05:30AM	<1	ppb			JLR-NH	11/29/2022 03:08PM
2211-03906-083	Kitchen- Sprayer #2	I	KF	11/17/2022 05:30AM	<1	ppb			JLR-NH	11/29/2022 03:11PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/06/2022
CLIENT NAME: Mt View Middle School

CLIENT ADDRESS: 575 Mount View Rd
Thorndike, ME 04986

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/18/2022 08:00AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 14° CELSIUS
CLIENT JOB #: 569

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-03906-084	Kitchen- Prep sink #3	I	KF	11/17/2022 05:31AM	5.1	ppb			JLR-NH	11/29/2022 03:20PM
2211-03906-085	Kitchen- Sprayer #3	I	KF	11/17/2022 05:32AM	1.1	ppb			JLR-NH	11/29/2022 03:23PM
2211-03906-086	Kitchen- Market force cooker fill	I	KF	11/17/2022 05:33AM	<1	ppb			JLR-NH	11/29/2022 03:26PM
2211-03906-087	Kitchen- Dishwash 2 bay sink #1	I	KF	11/17/2022 05:36AM	<1	ppb			JLR-NH	11/29/2022 03:29PM
2211-03906-088	Kitchen- Dishwash 2 bay sink #2	I	KF	11/17/2022 05:37AM	<1	ppb			JLR-NH	11/29/2022 03:38PM
2211-03906-089	Kitchen- Dishwash sprayer #1	I	KF	11/17/2022 05:37AM	<1	ppb			JLR-NH	11/29/2022 03:41PM
2211-03906-090	Kitchen- Dishwash sprayer #2	I	KF	11/17/2022 05:38AM	<1	ppb			JLR-NH	11/29/2022 03:44PM
2211-03906-091	C107 Nurse station BR- Handwash	I	OT	11/17/2022 06:04AM	6.0	ppb			JLR-NH	11/29/2022 03:46PM
2211-03906-092	C107 Nurse station BR- Shower	I	OT	11/17/2022 06:04AM	192	ppb			JLR-NH	12/05/2022 10:37AM
2211-03906-093	C107 Nurse station- Handwash sink	I	OT	11/17/2022 06:05AM	<1	ppb			JLR-NH	11/29/2022 03:58PM
2211-03906-094	C107 Nurse station- Sprayer	I	OT	11/17/2022 06:06AM	1.1	ppb			JLR-NH	12/05/2022 10:46AM

Rebecca L. Labranche
Laboratory Director