

Public Notice: School Lead Water Sample Results

Information concerning the lead level results for drinking water samples taken at

name of school

Maine law requires schools to test all drinking water faucets that could be used for drinking or cooking purposes for the presence of lead. This law further requires that parents and staff are made aware of all of the sample results.

During the period of _____ to _____
begin date end date

Water samples were collected from _____ water fixtures.
locations

Any sites producing elevated levels of lead (exceeding 4 parts per billion, or ppb), and therefore the faucets of most concern, are listed in the table on the following page(s).

Results for all drinking water outlets tested can be viewed here:

Enter website address or physical location

Statewide test results for Maine schools can also be found the on Maine DWP website at: www.medwp.com/schools.html

How does lead get into the water? When lead is present in water, it typically leaches, or dissolves, into water flowing through plumbing and fixtures *inside* a building from sources such as solder, pipes, or the faucets themselves. The school's well water or water provided by your local water district are unlikely sources of lead.

What are the Health Effects of exposure to lead in drinking water? Infants and children who drink water containing high levels of lead can experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink water containing excess levels of lead over many years could develop kidney problems or high blood pressure.

What level of lead is safe? No level of lead is safe. Because of the potential serious health risks, both the Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control and Prevention (CDC) agree that there is no known safe level of lead in a child's blood.

Please be aware that this sampling is done under conditions that are optimal for identifying lead in water. By having the water sit unused for many hours, lead that might be leaching from pipes or fittings is more easily discovered. However, *these levels are likely not the level of lead present in the drinking water throughout the school day.*

What can I do? Here are a few steps you can take to reduce the risk of your child being exposed to lead through school drinking water:

- Provide your child with bottled water or water from your home to reduce their usage of school drinking water outlets. Be sure to sample your home water for lead, too.
- Remind your child to let the water run for 30 seconds before drinking or filling a water bottle at school, which will lower any possible lead concentration.
- Consult your doctor if you have any specific health concerns.

School Fixtures with Elevated Lead Results (exceeding 4 parts per billion)

**Additional tables may be attached if your school has more than 20 collection sites with elevated lead levels.*

	Collection Date	Collection Site	Concentration (ppb)
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			

What is Being Done:

To correct the problem(s), we have taken these actions:

Future plans for the reduction of high lead levels in our drinking water include:

These actions are expected to be completed on:

(Date)



Information about Lead in Drinking Water for Students, Staff, and Parents



Health Effects of Lead

If too much lead enters your body from drinking water or other sources, serious health problems can occur, including damage to the brain and kidneys and interference with the production of oxygen-carrying red blood cells.

The greatest risk of lead exposure is to infants, young children, and pregnant women: During pregnancy, the fetus receives lead from the mother, which may affect brain development. In children, the continuing effects of lead on the brain have been linked to lowered IQ. Furthermore, lead is stored in the bones and can be released later in life, so, adults who were exposed to high levels of lead earlier in life may still encounter kidney problems and high blood pressure.

Sources of Lead

Lead can be found in many places; knowing the sources of lead can help limit your contact with it. Although most of the reported cases of lead poisoning in Maine have been a result of lead paint dust, exposure can also occur through drinking and cooking with water that has lead, as it can dissolve into water from solder or brass faucets, fittings, and valves. Exposure to lead can also come from jobs and hobbies that utilize materials containing lead, as well as from things you buy such as toys and antiques.

How Lead Got into Your Water

The most likely source of lead in your water is leaching from lead solder on your pipes or out of brass plumbing materials found in faucets, fittings, and valves.

Steps You Can Take to Protect Yourself from Lead in Drinking Water

- Run the water for at least 30 seconds or until it becomes noticeably colder before using it for drinking or cooking. The longer water sits in piping, the greater the chance that lead might leach in.
- Use cold water for drinking and cooking as well as for preparing baby formula. Hot water dissolves lead more quickly than cold water.
- Clean your faucet aerator (screen) regularly.
- Consider using bottled water or a water filter for drinking and cooking.

* Remember: Boiling the water does *not* reduce lead levels.

Find Out More

For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at <http://www.epa.gov/lead>, or contact the Maine Childhood Lead Poisoning Prevention Program (866-292-3474) or your health care provider. Your doctor can answer questions about having your child tested for lead.



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Morse Memorial School
27 School St
Brooks, ME 04921

Date Printed: 12/13/2022
Work Order #: 2211-04475
Client Job #: 562
Date Received: 11/22/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/13/2022
CLIENT NAME: Morse Memorial School

CLIENT ADDRESS: 27 School St
Brooks, ME 04921

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/22/2022 10:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 562

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-04475-001	Faculty room- Handwash sink	I	OT	11/21/2022 04:00AM	7.0	ppb			JLR-NH	12/12/2022 11:52PM
2211-04475-002	Girls bathroom- Handwash sink (entrance)	I	OT	11/21/2022 04:01AM	6.7	ppb			JLR-NH	12/05/2022 05:57PM
2211-04475-003	Boys bathroom- Handwash sink (entrance)	I	OT	11/21/2022 04:02AM	4.1	ppb			JLR-NH	12/05/2022 06:00PM
2211-04475-004	Fountain- Entrance	I	DWF	11/21/2022 04:03AM	<1	ppb			JLR-NH	12/05/2022 06:03PM
2211-04475-005	Bottle fill station- Entrance	I	DWF	11/21/2022 04:03AM	<1	ppb			JLR-NH	12/05/2022 06:05PM
2211-04475-006	Classroom 7- Handwash sink	I	DWF	11/21/2022 04:05AM	15.3	ppb			JLR-NH	12/05/2022 06:08PM
2211-04475-007	Classroom 8- Handwash sink	I	OT	11/21/2022 04:06AM	14.6	ppb			JLR-NH	12/05/2022 06:11PM
2211-04475-008	Boys bathroom next to gym- Handwash sink	I	OT	11/21/2022 04:07AM	8.9	ppb			JLR-NH	12/05/2022 06:20PM
2211-04475-009	Girls bathroom next to gym-Handwash sink	I	OT	11/21/2022 04:08AM	3.9	ppb			JLR-NH	12/05/2022 06:23PM
2211-04475-010	Kitchen- Handwash sink	I	KF	11/21/2022 04:09AM	6.5	ppb			JLR-NH	12/05/2022 06:32PM
2211-04475-011	Kitchen- Three bay sink fixture #1	I	KF	11/21/2022 04:10AM	323	ppb			JLR-NH	12/05/2022 06:35PM
2211-04475-012	Kitchen- Three bay sink fixture #2	I	KF	11/21/2022 04:10AM	6.8	ppb			JLR-NH	12/05/2022 06:38PM
2211-04475-013	Kitchen- Dishwasher rinse station sprayer	I	KF	11/21/2022 04:11AM	2.9	ppb			JLR-NH	12/05/2022 06:41PM
2211-04475-014	Classroom 4- Handwash sink	I	OT	11/21/2022 04:13AM	15.1	ppb			JLR-NH	12/05/2022 06:44PM
2211-04475-015	Classroom 4- Bathroom handwash sink	I	OT	11/21/2022 04:14AM	2.9	ppb			JLR-NH	12/05/2022 06:47PM
2211-04475-016	Upstairs- Fountain	I	DWF	11/21/2022 04:15AM	<1	ppb			JLR-NH	12/05/2022 06:49PM
2211-04475-017	Upstairs- Bottle fill station	I	DWF	11/21/2022 04:15AM	<1	ppb			JLR-NH	12/05/2022 06:52PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/13/2022
CLIENT NAME: Morse Memorial School

CLIENT ADDRESS: 27 School St
Brooks, ME 04921

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/22/2022 10:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 562

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-04475-018	Upstairs girls bathroom-Handwash sink	I	OT	11/21/2022 04:16AM	6.3	ppb			JLR-NH	12/05/2022 07:10PM
2211-04475-019	Upstairs boys bathroom-Handwash sink	I	OT	11/21/2022 04:16AM	3.4	ppb			JLR-NH	12/05/2022 07:13PM

Rebecca L. Labranche
Laboratory Director