

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608C46**
NRC Sample ID: **1608C46-01A**
Collection Date: **8/18/2016 8:00:00 AM**
Received Date: **8/24/2016 10:00:00 AM**
Reported Date: **8/30/2016 1:48:06 PM**

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-01
Collectors Name: RE
Sample Location: Kindergarten
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00243		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00226		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-02A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-02
Collectors Name: RE
Sample Location: 1st Grade
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0112		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00243		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-03A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-03
Collectors Name: RE
Sample Location: 2nd Grade
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0114		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00349		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608C46**
NRC Sample ID: **1608C46-04A**
Collection Date: **8/18/2016 8:00:00 AM**
Received Date: **8/24/2016 10:00:00 AM**
Reported Date: **8/30/2016 1:48:06 PM**

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-04
Collectors Name: RE
Sample Location: 3rd Grade
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.533		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.000176		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608C46**
NRC Sample ID: **1608C46-05A**
Collection Date: **8/18/2016 8:00:00 AM**
Received Date: **8/24/2016 10:00:00 AM**
Reported Date: **8/30/2016 1:48:06 PM**

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-05
Collectors Name: RE
Sample Location: 4th Grade
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0155		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00318		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-06A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-06
Collectors Name: RE
Sample Location: Lower Hall #1
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0205		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00194		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1608C46**
NRC Sample ID: **1608C46-07A**
Collection Date: **8/18/2016 8:00:00 AM**
Received Date: **8/24/2016 10:00:00 AM**
Reported Date: **8/30/2016 1:48:06 PM**

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-07
Collectors Name: RE
Sample Location: Lower Hall #2
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0147		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.0101		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-08A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-08
Collectors Name: RE
Sample Location: Mrs Albee
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0495		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.00337		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-09A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-09
Collectors Name: RE
Sample Location: New Gym
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00860		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.000447		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-10A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-10
Collectors Name: RE
Sample Location: Upper Hall
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.502		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	0.000130		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-11A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-11
Collectors Name: RE
Sample Location: Girls Locker Room
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0983		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1608C46
NRC Sample ID: 1608C46-12A
Collection Date: 8/18/2016 8:00:00 AM
Received Date: 8/24/2016 10:00:00 AM
Reported Date: 8/30/2016 1:48:06 PM

Sample Information:

X023441 Joseph Charter School

Client Sample ID: X023441-12
Collectors Name: RE
Sample Location: Boys Locker Room
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0841		0.000515	mg/L	1.3 AL	8/25/2016	OML
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	8/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit