

# Lead in School Drinking Water Report

## Mattawa Elementary School



Date(s) collected: 2023-01-31

Date(s) analyzed: 2023-02-07, 2023-02-13, 2023-02-08

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
375361	Main Building	Pot Filler	Kitchen	2/3	Tap	12
375373	Main Building	Fountain	11	1/1	Water Fountain	5
375861	Main Building	Fountain	Staff	1/1	Water Fountain	5
375369	Main Building	Fountain	2	1/1	Water Fountain	2
375860	Main Building	Fountain	12	1/1	Water Fountain	2
375366	Main Building	Fountain	8	1/1	Water Fountain	1
375367	Main Building	Fountain	6	1/1	Water Fountain	1
375368	Main Building	Fountain	4	1/1	Water Fountain	1
375372	Main	Fountain	5	1/1	Water	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building				Fountain	
375374	Main Building	Fountain	13	1/1	Water Fountain	1
375377	Main Building	Fountain	18	1/1	Water Fountain	1
375379	Main Building	Fountain	14	1/1	Water Fountain	1
375360	Main Building	Pot Filler	Kitchen	1/3	Tap	<1
375362	Main Building	Sink	Kitchen	3/3	Tap	<1
375363	Main Building	Fountain	1/1	Gym	Water Fountain	<1
375364	Main Building	Fountain - Multi-Level with Bottle Filler	Main Entry	1/2	Water Fountain	<1
375365	Main Building	Fountain - Multi-Level with Bottle Filler	Main Entry	2/2	Water Bottle Filler	<1
375370	Main Building	Fountain	1	1/1	Water Fountain	<1
375371	Main Building	Fountain	3	1/1	Water Fountain	<1
375375	Main Building	Fountain	15	1/1	Water Fountain	<1
375376	Main Building	Fountain	17	1/1	Water Fountain	<1
375378	Main Building	Fountain	16	1/1	Water Fountain	<1

#### EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and

testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **[leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov)**