

Lead in School Drinking Water Report

Morris Schott Elementary School



Date(s) collected: 2023-03-04, 2023-02-21, 2023-02-24

Date(s) analyzed: 2023-03-14, 2023-03-03

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
376519	Main Building	Sink	Kitchen	3of4	Tap	12
376518	Main Building	Sink	Kitchen	2of4	Tap	2
377016	Main Building	Fountain	125	1of1	Water Fountain	1
375656	Main Building	Fountain	209	1of1	Water Fountain	<1
376517	Main Building	Sink	Kitchen	1of4	Tap	<1
377000	Main Building	Fountain - Multi-Level with Bottle Filler	Cafeteria Fountain	1of2	Water Fountain	<1
377001	Main Building	Fountain - Multi-Level with Bottle	Cafeteria Fountain	2of2	Water Bottle Filler	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
		Filler				
377002	Main Building	Fountain	Gym	1of1	Water Fountain	<1
377003	Main Building	Sink	Batcave	1of1	Tap	<1
377004	Main Building	Fountain	Ramp Fountain	1of1	Water Fountain	<1
377005	Main Building	Fountain	201	1of1	Water Fountain	<1
377006	Main Building	Fountain	202	1of1	Water Fountain	<1
377007	Main Building	Fountain	203	1of1	Water Fountain	<1
377008	Main Building	Fountain	Band	1of1	Water Fountain	<1
377009	Main Building	Fountain - Multi-Level	Conference Fountains	1of2	Water Fountain	<1
377010	Main Building	Fountain - Multi-Level	Conference Fountains	2of2	Water Fountain	<1
377011	Main Building	Fountain	205	1of1	Water Fountain	<1
377012	Main Building	Fountain	206	1of1	Water Fountain	<1
377013	Main Building	Fountain	207	1of1	Water Fountain	<1
377014	Main Building	Fountain	208	1of1	Water Fountain	<1
377015	Main Building	Fountain	124	1of1	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: leadfreekids@doh.wa.gov