

Lead in School Drinking Water Report

Wahluke Junior High School



Date(s) collected: 2023-01-31

Date(s) analyzed: 2023-02-07, 2023-02-13

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
375868	Main Building	Sink	Home Ec	2/4	Tap	3
375873	Main Building	Sink	Art	1/2	Tap	3
375866	Main Building	Fountain	Gym	1/1	Water Fountain	2
375867	Main Building	Sink	Home Ec	1/4	Tap	1
375869	Main Building	Sink	Home Ec	3/4	Tap	1
375874	Main Building	Sink	Art	2/2	Tap	1
375380	Main Building	Fountain	16	1/1	Water Fountain	<1
375381	Main Building	Fountain	17	1/1	Water Fountain	<1
375862	Main	Pot Filler	Kitchen	2/3	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	Building					
375863	Main Building	Ice Machine	Concession	1/1	Other	<1
375864	Main Building	Fountain - Multi-Level with Bottle Filler	Front	1/2	Water Fountain	<1
375865	Main Building	Fountain - Multi-Level with Bottle Filler	Front	2/2	Water Bottle Filler	<1
375870	Main Building	Sink	Home Ec	4/4	Tap	<1
375871	Main Building	Sink	Home Ec Hallway	1/1	Water Fountain	<1
375872	Main Building	Fountain	Room 8 Hallway	1/1	Water Fountain	<1
375875	Main Building	Fountain	12	1/1	Water Fountain	<1
375876	Main Building	Fountain	14	1/1	Water Fountain	<1
375877	Main Building	Sink	15	1/1	Tap	<1
375878	Main Building	Fountain - Multi-Level with Bottle Filler	15 Hallway	2/3	Water Fountain	<1
375879	Main Building	Fountain - Multi-Level with Bottle Filler	15 Hallway	3/3	Water Bottle Filler	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: leadfreekids@doh.wa.gov