



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1243

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS ROUTE 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 04/13/2022
Reported: 05/02/2022

Analytical Testing Parameters

Table with 4 columns: Client Sample ID (56A), Sample Matrix (Drinking Water), Lab Sample ID (J2D1243-01), Collected By (Client), Collection Date (04/12/2022 9:10)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, <0.0010, 0.015 AL, 0.0010, mg/L, 04/28/22 1208, 04/28/22 1334, MMC

Table with 4 columns: Client Sample ID (56B), Sample Matrix (Drinking Water), Lab Sample ID (J2D1243-02), Collected By (Client), Collection Date (04/12/2022 9:14)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, <0.0010, 0.015 AL, 0.0010, mg/L, 04/28/22 1208, 04/28/22 1339, MMC

Table with 4 columns: Client Sample ID (76B), Sample Matrix (Drinking Water), Lab Sample ID (J2D1243-03), Collected By (Client), Collection Date (04/12/2022 6:20)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, <0.0010, 0.015 AL, 0.0010, mg/L, 04/28/22 1208, 04/28/22 1340, MMC

Table with 4 columns: Client Sample ID (96B), Sample Matrix (Drinking Water), Lab Sample ID (J2D1243-04), Collected By (Client), Collection Date (04/12/2022 9:15)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Method: EPA 200.8, Rv. 5.4 (1994), Lead, 0.0012, 0.015 AL, 0.0010, mg/L, 04/28/22 1208, 04/28/22 1341, MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1243

<b>Client Sample ID:</b> 72A	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/12/2022 9:15
<b>Lab Sample ID:</b> J2D1243-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1343	MMC

<b>Client Sample ID:</b> 96A	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/12/2022 9:30
<b>Lab Sample ID:</b> J2D1243-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1344	MMC

<b>Client Sample ID:</b> 76A	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/12/2022 6:19
<b>Lab Sample ID:</b> J2D1243-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1345	MMC

<b>Client Sample ID:</b> 80B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/12/2022 9:35
<b>Lab Sample ID:</b> J2D1243-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1347	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1243

Client Sample ID: 81B	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 04/12/2022 9:26
Lab Sample ID: J2D1243-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1349	MMC

Client Sample ID: 80A	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 04/12/2022 9:35
Lab Sample ID: J2D1243-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1350	MMC

Client Sample ID: 99	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 04/12/2022 9:23
Lab Sample ID: J2D1243-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1355	MMC

Client Sample ID: 72B	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 04/12/2022 9:16
Lab Sample ID: J2D1243-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/28/22 1208	04/28/22 1356	MMC

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1243

**Project Requested Certification(s)**

Microbac Laboratories, Inc. - Dayville

11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

**Reviewed and Approved By:**

Shannon Weeks

Customer Relationship Coordinator

Reported: 05/02/2022 16:51

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | [www.microbac.com](http://www.microbac.com)

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned  iced  
 MNY Workorder # \_\_\_\_\_

LOWVILLE OF

<b>Client Information</b>		<b>Billing/Invoice:</b>	<b>Analysis Requested</b>					<b>Receiving Info (Lab Only)</b>	
Name:	Jeff/Lew Boces		Total Lead (EPA 200.8)					Ice:	YES
Address:	20104 NYS Route 3							Cooler:	YES
Contact:	Health/Safety Dept.							Sample Temp:	
Phone:	315-779-7000							Cooler Seal:	YES <input checked="" type="radio"/> NO
Project:								Pickup:	YES NO
Quote ID:	Lead Testing	PO#:						Dropoff:	C W
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:						Accepted?	YES NO
Carbon Copy:	Yes							Container Material	
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com		Plastic			Container Size (in MI)		
Fax Results:	Yes				250 ml			Preservative	

Sample Information			Matrix	Number of Containers for Analysis Requested					Comments/Field Data
Description/Location	Date	Time	Type						
1 56A	4/12/22	910	DW	1					
2 56B		914							
3 76B		620							
4 96B		931							
5 72A		915							
6 96A		930							
7 76A		619							
8 80B		935							
9 81B		926							
10 80A		935							
11 99		923							
12 72B		916							
13									
14									
15									
16									
17									
18									
19									
20									

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 P.M. Shannon Weeks



Print Name and Company	Date/Time	Comments
Sampled: <i>[Signature]</i>	4/12/22 1500	Fed Ex
Received: SPANER 4.13.22 13:10		
Received:		