

TABLE 1

**Drinking Water Sampling for Lead Content
Oak Grove Community Unit School District #68
Oak Grove East School
Sampled: October 23, 2018**

Sample ID	Location	Water Source	Results (ppb)
1	Kitchen - 3-Bay	Kitchen Sink	2.0
1A	Kitchen - 3-Bay	Kitchen Sink	1.9
1B	Kitchen - 3-Bay	Kitchen Sink	<1.0
2	Kitchen - Dishwashing Sink	Kitchen Sink	6.8
2A	Kitchen - Dishwashing Sink	Kitchen Sink	<1.0
3	Kitchen- Hand Sink	Kitchen Sink	2.0
3A	Kitchen- Hand Sink	Kitchen Sink	<1.0
4	2nd Fl. By Boys Restroom	Drinking Fountain	4.6
4A	2nd Fl. By Boys Restroom	Drinking Fountain	3.4
5	2nd Fl. By Girls Restroom	Drinking Fountain	4.0
5A	2nd Fl. By Girls Restroom	Drinking Fountain	3.4
6	Lower Level By Room 110	Drinking Fountain	4.4
6A	Lower Level By Room 110	Drinking Fountain	4.1
7	Room 109	Sink	24.9
7A	Room 109	Sink	1.1
8	Room 108	Sink	4.5
8A	Room 108	Sink	<1.0
9	1st Fl. Hallway By Main Office(L)	Drinking Fountain	<1.0
9A	1st Fl. Hallway By Main Office (L)	Drinking Fountain	<1.0
10	1st Fl. Hallway By Main Office (U)	Drinking Fountain	<1.0
10A	1st Fl. Hallway By Main Office (U)	Drinking Fountain	<1.0
11	2nd Fl. Hall By Women's RR(207)	Drinking Fountain	1.1
11A	2nd Fl. Hall By Women's RR(207)	Drinking Fountain	33.2
12	2nd Fl. Hall By Conference Rm 200	Drinking Fountain	<1.0
12A	2nd Fl. Hall By Conference Rm 200	Drinking Fountain	2.8

A/B Samples were precautionary samples collected at 30 seconds following the "first draw" samples (A) and 3 minutes following the A sample (B).

#####

Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.

#####

Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum