



**Adirondack Environmental Services, Inc**

Date: 12-Jun-23

CLIENT: Gilboa Conesville CSD  
 Project: Gilboa School

LabWork Order: 230607083  
 PO#: 23-00029

Lab SampleID: 230607083-005      Collection Date: 6/7/2023 6:20:00 AM  
 Client Sample ID: Room #7 Sink      Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4      Analyst: SM

( Prep: - 6/8/2023 )						
Copper	0.263	0.0050		mg/L	1	6/9/2023 9:11:08 PM
Lead	ND	0.0010		mg/L	1	6/9/2023 9:11:08 PM

Lab SampleID: 230607083-006      Collection Date: 6/7/2023 6:20:00 AM  
 Client Sample ID: Room #4 Watch Fountain      Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4      Analyst: SM

( Prep: - 6/8/2023 )						
Copper	0.0487	0.0050		mg/L	1	6/9/2023 9:14:43 PM
Lead	ND	0.0010		mg/L	1	6/9/2023 9:14:43 PM

Lab SampleID: 230607083-007      Collection Date: 6/7/2023 6:25:00 AM  
 Client Sample ID: Corridor Fountain      Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4      Analyst: SM

( Prep: - 6/8/2023 )						
Copper	0.0847	0.0050		mg/L	1	6/9/2023 9:18:19 PM
Lead	ND	0.0010		mg/L	1	6/9/2023 9:18:19 PM

Lab SampleID: 230607083-008      Collection Date: 6/7/2023 6:25:00 AM  
 Client Sample ID: Nurse Bath Sink      Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4      Analyst: SM

( Prep: - 6/8/2023 )						
Copper	0.0987	0.0050		mg/L	1	6/9/2023 9:21:55 PM
Lead	ND	0.0010		mg/L	1	6/9/2023 9:21:55 PM

