



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

**Veazie Community School**  
1040 School Street  
Veazie, ME 04401

**Date Printed:** 10/18/2021  
**Work Order #:** 2110-01505  
**Client Job #:** 476  
**Date Received:** 10/08/2021  
**Sample collected in:** Maine

**Attached please find results for the analysis of the samples received on the date referenced above.**

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 10/18/2021  
**CLIENT NAME:** Veazie Community School

**CLIENT ADDRESS:** 1040 School Street  
 Veazie, ME 04401

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 10/08/2021 02:00PM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 21° CELSIUS  
**CLIENT JOB #:** 476

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2110-01505-001	Kitchen Sm HW	I	KF	10/07/2021 07:00AM	5.1	ppb			JLR-NH	10/13/2021 06:47PM
2110-01505-002	Kitchen Big HW	I	KF	10/07/2021 07:00AM	4.8	ppb			JLR-NH	10/13/2021 06:50PM
2110-01505-003	Kitchen Big Sink	I	KF	10/07/2021 07:00AM	3.1	ppb			DR-NH	10/15/2021 12:59PM
2110-01505-004	Lobby Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 06:52PM
2110-01505-005	Lobby Bottle Station	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 06:55PM
2110-01505-006	Gym Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 06:58PM
2110-01505-007	Gym Bottle Station	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 07:01PM
2110-01505-008	Middle School Bottle Station	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 07:16PM
2110-01505-009	Primary Bottle Station	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 07:18PM
2110-01505-010	Teacher Lounge Sink	I	OT	10/07/2021 07:00AM	1.4	ppb			JLR-NH	10/13/2021 07:21PM
2110-01505-011	Library Sink	I	OT	10/07/2021 07:00AM	1.4	ppb			JLR-NH	10/13/2021 07:24PM
2110-01505-012	Science Lab Sink 1	I	OT	10/07/2021 07:00AM	2.5	ppb			JLR-NH	10/13/2021 07:33PM
2110-01505-013	Science Lab Sink 2	I	OT	10/07/2021 07:00AM	2.9	ppb			JLR-NH	10/13/2021 07:36PM
2110-01505-014	Science Lab Sink 3	I	OT	10/07/2021 07:00AM	5.3	ppb			JLR-NH	10/13/2021 07:39PM
2110-01505-015	Science Lab Sink 4	I	OT	10/07/2021 07:00AM	4.4	ppb			JLR-NH	10/13/2021 07:42PM
2110-01505-016	Science Lab Sink 5	I	OT	10/07/2021 07:00AM	3.0	ppb			JLR-NH	10/13/2021 07:50PM
2110-01505-017	Science Lab Fountain	I	DWF	10/07/2021 07:00AM	3.4	ppb			JLR-NH	10/13/2021 07:53PM
2110-01505-018	Nurse Clinic	I	DWF	10/07/2021 07:00AM	2.5	ppb			JLR-NH	10/13/2021 07:56PM
2110-01505-019	Art Room Sink 1	I	OT	10/07/2021 07:00AM	1.2	ppb			JLR-NH	10/13/2021 07:59PM
2110-01505-020	Art Room Sink 2	I	OT	10/07/2021 07:00AM	1.7	ppb			JLR-NH	10/13/2021 08:02PM
2110-01505-021	Resource Room Sink	I	OT	10/07/2021 07:00AM	2.2	ppb			JLR-NH	10/13/2021 08:05PM
2110-01505-022	Resource Room Fountain	I	OT	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 08:13PM
2110-01505-023	Cobb Sink	I	OT	10/07/2021 07:00AM	1.5	ppb			JLR-NH	10/13/2021 08:16PM
2110-01505-024	Cobb Fountain	I	DWF	10/07/2021 07:00AM	2.6	ppb			JLR-NH	10/13/2021 08:28PM
2110-01505-025	Gonyar Sink	I	OT	10/07/2021 07:00AM	1.7	ppb			JLR-NH	10/13/2021 08:31PM
2110-01505-026	Gonyar Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 08:34PM

Rebecca L. Labranche  
 Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 10/18/2021  
**CLIENT NAME:** Veazie Community School

**CLIENT ADDRESS:** 1040 School Street  
 Veazie, ME 04401

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 10/08/2021 02:00PM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 21° CELSIUS  
**CLIENT JOB #:** 476

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2110-01505-027	Frazier Sink	I	OT	10/07/2021 07:00AM	4.1	ppb			JLR-NH	10/13/2021 08:37PM
2110-01505-028	Frazier Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 08:40PM
2110-01505-029	Humphrey Sink	I	OT	10/07/2021 07:00AM	2.0	ppb			JLR-NH	10/13/2021 08:42PM
2110-01505-030	Humphrey Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 08:45PM
2110-01505-031	Daigneau Sink	I	OT	10/07/2021 07:00AM	2.2	ppb			JLR-NH	10/13/2021 08:48PM
2110-01505-032	Daigneau Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 09:03PM
2110-01505-033	Hileman Sink	I	OT	10/07/2021 07:00AM	2.4	ppb			JLR-NH	10/13/2021 09:06PM
2110-01505-034	Hileman Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 09:09PM
2110-01505-035	Int. Spare Sink	I	OT	10/07/2021 07:00AM	4.3	ppb			JLR-NH	10/13/2021 09:11PM
2110-01505-036	Int. Spare Fountain	I	DWF	10/07/2021 07:00AM	1.0	ppb			JLR-NH	10/13/2021 09:14PM
2110-01505-037	Kimball Sink	I	OT	10/07/2021 07:00AM	2.4	ppb			JLR-NH	10/13/2021 09:17PM
2110-01505-038	Kimball Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 09:20PM
2110-01505-039	Chandler Sink	I	OT	10/07/2021 07:00AM	1.9	ppb			JLR-NH	10/13/2021 09:23PM
2110-01505-040	Chandler Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/13/2021 09:26PM
2110-01505-041	P.Spare Sink	I	OT	10/07/2021 07:00AM	1.8	ppb			JLR-NH	10/14/2021 05:28PM
2110-01505-042	P.SPare Fountain	I	DWF	10/07/2021 07:00AM	2.2	ppb			JLR-NH	10/14/2021 05:45PM
2110-01505-043	PreK Sink	I	OT	10/07/2021 07:00AM	1.4	ppb			JLR-NH	10/14/2021 05:48PM
2110-01505-044	PreK Fountain	I	DWF	10/07/2021 07:00AM	<1	ppb			JLR-NH	10/14/2021 05:51PM

Rebecca L. Labranche  
 Laboratory Director