



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J1C0727

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lowville

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 02/16/2021
 Reported: 04/11/2021

Analytical Testing Parameters

Client Sample ID: 127								
Sample Matrix: Drinking Water					Collected By: RF - Client			
Lab Sample ID: J1C0727-01					Collection Date: 02/10/2021 6:16			

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1710	DLO

Client Sample ID: 62								
Sample Matrix: Drinking Water					Collected By: RF - Client			
Lab Sample ID: J1C0727-02					Collection Date: 02/10/2021 5:50			

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0060	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1715	DLO

Client Sample ID: 63								
Sample Matrix: Drinking Water					Collected By: RF - Client			
Lab Sample ID: J1C0727-03					Collection Date: 02/10/2021 5:50			

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 1351	04/06/21 1204	DLO

Client Sample ID: 64								
Sample Matrix: Drinking Water					Collected By: RF - Client			
Lab Sample ID: J1C0727-04					Collection Date: 02/10/2021 5:56			

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1717	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-05		Collection Date: 02/10/2021 5:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1719	DLO

Client Sample ID: 120	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-06		Collection Date: 02/10/2021 6:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1721	DLO

Client Sample ID: 127B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-07		Collection Date: 02/10/2021 6:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1722	DLO

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-08		Collection Date: 02/10/2021 5:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1728	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 106	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:10
Lab Sample ID: J1C0727-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1730	DLO

Client Sample ID: 102	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:06
Lab Sample ID: J1C0727-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1732	DLO

Client Sample ID: 65	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 5:52
Lab Sample ID: J1C0727-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1734	DLO

Client Sample ID: 126	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:15
Lab Sample ID: J1C0727-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1735	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1118A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:25
Lab Sample ID: J1C0727-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1739	DLO

Client Sample ID: 110	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:10
Lab Sample ID: J1C0727-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1741	DLO

Client Sample ID: 122	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:13
Lab Sample ID: J1C0727-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1743	DLO

Client Sample ID: 125	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:25
Lab Sample ID: J1C0727-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1745	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1118B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:25
Lab Sample ID: J1C0727-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1750	DLO

Client Sample ID: 1116A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:20
Lab Sample ID: J1C0727-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1752	DLO

Client Sample ID: 1116B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:20
Lab Sample ID: J1C0727-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1754	DLO

Client Sample ID: 1410D	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:35
Lab Sample ID: J1C0727-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1756	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 118	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:11
Lab Sample ID: J1C0727-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1447	04/01/21 1757	DLO

Client Sample ID: 103	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:03
Lab Sample ID: J1C0727-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1807	DLO

Client Sample ID: 1122B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:27
Lab Sample ID: J1C0727-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1812	DLO

Client Sample ID: 1120A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:26
Lab Sample ID: J1C0727-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1814	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1120B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:26
Lab Sample ID: J1C0727-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1816	DLO

Client Sample ID: 100	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:02
Lab Sample ID: J1C0727-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1818	DLO

Client Sample ID: 173	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:00
Lab Sample ID: J1C0727-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1820	DLO

Client Sample ID: 174	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:25
Lab Sample ID: J1C0727-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1825	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-29		Collection Date: 02/10/2021 6:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1827	DLO

Client Sample ID: 127	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-30		Collection Date: 02/10/2021 6:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1829	DLO

Client Sample ID: 109	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-31		Collection Date: 02/10/2021 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1831	DLO

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-32		Collection Date: 02/10/2021 6:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1833	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1210	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:36
Lab Sample ID: J1C0727-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1836	DLO

Client Sample ID: 1403	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:33
Lab Sample ID: J1C0727-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1838	DLO

Client Sample ID: 8	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:40
Lab Sample ID: J1C0727-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1840	DLO

Client Sample ID: 114	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:11
Lab Sample ID: J1C0727-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1842	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 112	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-37		Collection Date: 02/10/2021 6:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1848	DLO

Client Sample ID: 1115A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-38		Collection Date: 02/10/2021 6:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1849	DLO

Client Sample ID: 177	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-39		Collection Date: 02/10/2021 6:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1851	DLO

Client Sample ID: 1401D	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-40		Collection Date: 02/10/2021 6:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1853	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1122A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:27
Lab Sample ID: J1C0727-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1451	04/01/21 1855	DLO

Client Sample ID: 9	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:10
Lab Sample ID: J1C0727-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1904	DLO

Client Sample ID: 1214C	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:40
Lab Sample ID: J1C0727-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1910	DLO

Client Sample ID: 1117A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:20
Lab Sample ID: J1C0727-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1912	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 178	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-45		Collection Date: 02/10/2021 6:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1914	DLO

Client Sample ID: 176	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-46		Collection Date: 02/10/2021 6:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1916	DLO

Client Sample ID: 1410A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-47		Collection Date: 02/10/2021 6:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1917	DLO

Client Sample ID: 1410C	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-48		Collection Date: 02/10/2021 6:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1923	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1410B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-49		Collection Date: 02/10/2021 6:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1925	DLO

Client Sample ID: 1410C	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-50		Collection Date: 02/10/2021 6:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1927	DLO

Client Sample ID: 44	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-51		Collection Date: 02/10/2021 7:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0140	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1929	DLO

Client Sample ID: 1119B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-52		Collection Date: 02/10/2021 6:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1931	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1121A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:27
Lab Sample ID: J1C0727-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1934	DLO

Client Sample ID: 1115B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:30
Lab Sample ID: J1C0727-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1936	DLO

Client Sample ID: 116	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:15
Lab Sample ID: J1C0727-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1938	DLO

Client Sample ID: 1410B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:33
Lab Sample ID: J1C0727-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1940	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1401A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:35
Lab Sample ID: J1C0727-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1946	DLO

Client Sample ID: 1216	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:50
Lab Sample ID: J1C0727-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1948	DLO

Client Sample ID: 1121B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:23
Lab Sample ID: J1C0727-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1950	DLO

Client Sample ID: 1117B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:20
Lab Sample ID: J1C0727-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1952	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 1119A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:21
Lab Sample ID: J1C0727-61	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1452	04/01/21 1954	DLO

Client Sample ID: 38	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:00
Lab Sample ID: J1C0727-62	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2203	DLO

Client Sample ID: 41	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:10
Lab Sample ID: J1C0727-63	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2209	DLO

Client Sample ID: 2112	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:30
Lab Sample ID: J1C0727-64	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2211	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2404C	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:15
Lab Sample ID: J1C0727-65	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2213	DLO

Client Sample ID: 1217	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:53
Lab Sample ID: J1C0727-66	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2215	DLO

Client Sample ID: 33	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:06
Lab Sample ID: J1C0727-67	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2217	DLO

Client Sample ID: 46	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:08
Lab Sample ID: J1C0727-68	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2223	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2108	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:25
Lab Sample ID: J1C0727-69	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2225	DLO

Client Sample ID: DF2403	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:20
Lab Sample ID: J1C0727-70	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2227	DLO

Client Sample ID: 28	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:02
Lab Sample ID: J1C0727-71	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2229	DLO

Client Sample ID: 1305	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 6:55
Lab Sample ID: J1C0727-72	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2231	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 31	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-73		Collection Date: 02/10/2021 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2235	DLO

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-74		Collection Date: 02/10/2021 7:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2236	DLO

Client Sample ID: 1301	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-75		Collection Date: 02/10/2021 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2238	DLO

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-76		Collection Date: 02/10/2021 6:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2240	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 43	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-77		Collection Date: 02/10/2021 7:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0074	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2246	DLO

Client Sample ID: 2300A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-78		Collection Date: 02/10/2021 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2248	DLO

Client Sample ID: 186	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-79		Collection Date: 02/10/2021 7:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2250	DLO

Client Sample ID: 1212	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-80		Collection Date: 02/10/2021 6:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2252	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-81		Collection Date: 02/10/2021 7:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/01/21 1552	04/01/21 2254	DLO

Client Sample ID: 185	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-82		Collection Date: 02/10/2021 7:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2304	DLO

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-83		Collection Date: 02/10/2021 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2310	DLO

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-84		Collection Date: 02/10/2021 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2312	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 27	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-85		Collection Date: 02/10/2021 7:02

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2314	DLO

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-86		Collection Date: 02/10/2021 6:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2316	DLO

Client Sample ID: 25	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-87		Collection Date: 02/10/2021 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2318	DLO

Client Sample ID: 183	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-88		Collection Date: 02/10/2021 7:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2324	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: DF2101	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:15
Lab Sample ID: J1C0727-89	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2326	DLO

Client Sample ID: 68	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 8:00
Lab Sample ID: J1C0727-90	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2328	DLO

Client Sample ID: 97	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 8:30
Lab Sample ID: J1C0727-91	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2330	DLO

Client Sample ID: 90	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 8:05
Lab Sample ID: J1C0727-92	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2332	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 187	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:10
Lab Sample ID: J1C0727-93	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2336	DLO

Client Sample ID: 2203	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:33
Lab Sample ID: J1C0727-94	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2338	DLO

Client Sample ID: 182	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:35
Lab Sample ID: J1C0727-95	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2340	DLO

Client Sample ID: 2110	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:26
Lab Sample ID: J1C0727-96	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2342	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-97		Collection Date: 02/10/2021 8:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0058	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2348	DLO

Client Sample ID: 91	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-98		Collection Date: 02/10/2021 8:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2350	DLO

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-99		Collection Date: 02/10/2021 8:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2352	DLO

Client Sample ID: 193	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AA		Collection Date: 02/10/2021 8:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2354	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2115	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AB		Collection Date: 02/10/2021 7:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/01/21 1553	04/01/21 2356	DLO

Client Sample ID: 188	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AC		Collection Date: 02/10/2021 7:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1139	DLO

Client Sample ID: 2111	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AD		Collection Date: 02/10/2021 7:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1144	DLO

Client Sample ID: 2116	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AE		Collection Date: 02/10/2021 7:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1146	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2113	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AF		Collection Date: 02/10/2021 7:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1148	DLO

Client Sample ID: 2119	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AG		Collection Date: 02/10/2021 7:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1150	DLO

Client Sample ID: 190	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AH		Collection Date: 02/10/2021 7:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1152	DLO

Client Sample ID: 2117	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AI		Collection Date: 02/10/2021 7:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1157	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2105	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AJ		Collection Date: 02/10/2021 7:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1159	DLO

Client Sample ID: 99	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AK		Collection Date: 02/10/2021 8:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1201	DLO

Client Sample ID: 2106	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AL		Collection Date: 02/10/2021 7:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1203	DLO

Client Sample ID: 179	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AM		Collection Date: 02/10/2021 7:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1204	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2404A	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:20
Lab Sample ID: J1C0727-AN	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0606	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1208	DLO

Client Sample ID: 184	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:35
Lab Sample ID: J1C0727-AO	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1210	DLO

Client Sample ID: 192	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 8:03
Lab Sample ID: J1C0727-AP	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0133	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1212	DLO

Client Sample ID: 2202	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:36
Lab Sample ID: J1C0727-AQ	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0165	0.015 AL	0.0010	mg/L		04/02/21 1351	04/06/21 1210	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2114	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:30
Lab Sample ID: J1C0727-AR	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1214	DLO

Client Sample ID: 2118	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:30
Lab Sample ID: J1C0727-AS	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1219	DLO

Client Sample ID: 2109	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:28
Lab Sample ID: J1C0727-AT	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1221	DLO

Client Sample ID: 2406	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:21
Lab Sample ID: J1C0727-AU	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1223	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 34	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AV		Collection Date: 02/10/2021 7:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1225	DLO

Client Sample ID: 98	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AW		Collection Date: 02/10/2021 8:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/02/21 0950	04/02/21 1226	DLO

Client Sample ID: 1218	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AX		Collection Date: 02/10/2021 6:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0097	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1235	DLO

Client Sample ID: 2104B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AY		Collection Date: 02/10/2021 7:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1301	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 189	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-AZ		Collection Date: 02/10/2021 7:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1241	DLO

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BA		Collection Date: 02/10/2021 7:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1243	DLO

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BB		Collection Date: 02/10/2021 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1245	DLO

Client Sample ID: 180	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BC		Collection Date: 02/10/2021 7:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1246	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2404D	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:20
Lab Sample ID: J1C0727-BD	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1248	DLO

Client Sample ID: 35	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:08
Lab Sample ID: J1C0727-BE	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1254	DLO

Client Sample ID: 94	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 8:00
Lab Sample ID: J1C0727-BF	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1256	DLO

Client Sample ID: 2107	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:27
Lab Sample ID: J1C0727-BG	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1257	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 93	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BH		Collection Date: 02/10/2021 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1259	DLO

Client Sample ID: 2404B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BI		Collection Date: 02/10/2021 7:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0392	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1305	DLO

Client Sample ID: 2201	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BJ		Collection Date: 02/10/2021 7:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1307	DLO

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BK		Collection Date: 02/10/2021 7:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1308	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BL		Collection Date: 02/10/2021 6:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1310	DLO

Client Sample ID: 191	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BM		Collection Date: 02/10/2021 7:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1316	DLO

Client Sample ID: 84	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BN		Collection Date: 02/10/2021 8:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1318	DLO

Client Sample ID: 95	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BO		Collection Date: 02/10/2021 8:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1319	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 2120	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BP		Collection Date: 02/10/2021 7:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1321	DLO

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BQ		Collection Date: 02/10/2021 7:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		04/02/21 0951	04/02/21 1323	DLO

Client Sample ID: 1226	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BR		Collection Date: 02/10/2021 6:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1356	DLO

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BS		Collection Date: 02/10/2021 8:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1401	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 87	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BT		Collection Date: 02/10/2021 8:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1403	DLO

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BU		Collection Date: 02/10/2021 8:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1405	DLO

Client Sample ID: 181	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BV		Collection Date: 02/10/2021 7:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1407	DLO

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J1C0727-BW		Collection Date: 02/10/2021 7:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1332	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1C0727

Client Sample ID: 47	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 02/10/2021 7:09
Lab Sample ID: J1C0727-BX	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.015 AL	0.0010	mg/L		04/02/21 1232	04/02/21 1358	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Jennifer Walker
 Operations Manager
 Reported: 04/11/2021 20:40

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

1000112

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:			
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
Email: rfiller@boces.com , frhauck@boces.com , ishaw@boces.com			

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	
127	2/10	6:16		DW	
292		5:50			
603		5:50			
604		5:50			
607		5:53			
720		6:14			
727B		6:17			
646		5:53			
970		6:10			
201		6:00			
605		5:52			
120		6:15			
1118 A		6:25			
110		6:10			
122		6:13			
125		6:25			
1118B		6:25			
1116A		6:20			
1116B		6:20			
1410 D		6:35			

Ice:	YES NO
Cooler:	YES NO
Sample Temp:	
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material:	
Container Size (in MI):	
Preservative:	

J 1 C 0 7 2 7
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing if the samples are not properly preserved. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract the analysis of another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract the analysis of another accredited laboratory.

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY # 10795, EPA # NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

Client Information
 Name: Jeff/Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: Lead Testing
 Quote ID: PO#
 Rush TAT Bus. Days: 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes

Billing/Invoice:
 Billing/Invoice: Total Lead (EPA 200.8)
 Matrix Type: DW

Sample Information
 Description/Location: 118, 103, 1122B, 1120A, 1120B, 100, 173, 174, 6, 124, 109, 7, 1210, 1403, 8, 114, 112, 115A, 177, 1401D
 Date: 3/10
 Time: 6:11, 6:03, 6:27, 6:26, 6:26, 6:02, 6:00, 6:25, 6:46, 6:15, 6:03, 6:40, 6:30, 6:33, 6:40, 6:10, 6:25, 6:30, 6:35

Receiving Info (Lab Use Only)
 Ice: YES (NO)
 Cooler: YES (NO)
 Sample Temp: 3.8
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material
 Container Size (in MI)
 Preservative

Number	Description/Location	Date	Time	Matrix Type	Number of Containers for Analysis Requested				Comments/Field Data
					1	2	3	4	
1	118	3/10	6:11	DW					
2	103		6:03						
3	1122B		6:27						
4	1120A		6:26						
5	1120B		6:26						
6	100		6:02						
7	173		6:00						
8	174		6:25						
9	6		6:46						
10	124		6:15						
11	109		6:03						
12	7		6:40						
13	1210		6:30						
14	1403		6:33						
15	8		6:40						
16	114		6:10						
17	112		6:10						
18	115A		6:25						
19	177		6:30						
20	1401D		6:35						

Print Name and Company
 Sampled: [Signature]
 Date/Time: 2/12/2021
 Received: [Signature]
 Date/Time: 2/20/2021 11:45/1470

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are agreeing that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information
 Name: Jeff Lew Boces
 Address: 20104 NYS Route 3
 Contact: Health/Safety Dept.
 Phone: 315-779-7000
 Project: Lead Testing
 Quote ID: PO#
 Rush TAT Bus. Days: 2-5 5-7 7-10
 Carbon Copy: Yes
 Email Results: Yes
 Fax Results: Yes
 Billing/Invoice: rfilley@boces.com, fhauck@boces.com, lshaw@boces.com

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: 318
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material
 Container Size (in MI)
 Preservative

Sample Information			Analysis Requested			Comments/Field Data
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	
1122 A	2/10	6:27	DW	DW	1	
9		6:10				
1214C		6:40				
1117 A		6:20				
178		6:30				
176		6:28				
140A		6:33				
140C		6:33				
140B		6:33				
140C		6:35				
44		7:13				
1119 B		6:21				
1121 A		6:27				
1115 B		6:30				
1118		6:15				
1401 B		6:33				
1401 A		6:35				
1216		6:50				
1121 B		6:23				
1117 B		6:20				

Sampled: [Signature] Date/Time: 2/12/2021
Received:
Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing for which we will not be contract the analysis of another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the terms of its subcontract and are in agreement with this action.

3821 Buck Drive
Cortland NY 13045
Phone: (607) 753-3403 Fax: (607) 753-3415
NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

6000112

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jeff/Lew Boces					Ice:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>					
Address:	20104 NYS Route 3					Cooler:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>					
Contact:	Health/Safety Dept.					Sample Temp:	38					
Phone:	315-779-7000					Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>					
Project:	Lead Testing		PO#:			Pickup:	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>					
Quote ID:			Date Req.:			Dropoff:	C W					
Rush TAT Bus. Days:	2-5 5-7 7-10					Accepted?	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>					
Carbon Copy:	Yes					Container Material						
Email Results:	Yes					Container Size (in MI)						
Fax Results:	Yes					Preservative						
	Email: rfilley@boces.com, fhauck@boces.com, lshaw@boces.com											
Sample Information			Matrix			Number of Containers for Analysis Requested			Comments/Field Data			
Description/Location	Date	Time	Type									
1119 A	2/10	6:24	DW									
38		7:08										
41		7:10										
2112		7:30										
2404C		7:15										
1217		6:53										
33		7:00										
46		7:08										
2108		7:25										
DF 2403		7:20										
28		7:02										
1305		6:55										
31		7:00										
240		7:02										
1301		7:05										
5		6:45										
43		7:13										
2300A		7:05										
186		7:40										
1212		6:45										
Print Name and Company			Date/Time	Comments								
[Signature]			2/12/2021									
Received: [Signature]			2-16-2021									1145/1440
Received: [Signature]												

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been notified by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

6000112

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)		
Name:	Jeff/Lew Boces					Ice:	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				
Address:	20104 NYS Route 3					Cooler:	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				
Contact:	Health/Safety Dept.					Sample Temp:	3.8				
Phone:	315-779-7000					Cooler Seal:	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				
Project:	Lead Testing					Pitchup:	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				
Quote ID:	PO#					Dropoff:	C W				
Rush TAT Bus. Days:	2-5 5-7 7-10					Accepted?	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				
Carbon Copy:	Yes					Container Material	Plastic				
Email Results:	Yes		rfiller@boces.com, fhauck@boces.com, lshaw@boces.com			Container Size (in MI)	250 ml				
Fax Results:	Yes					Preservative	HNO3				
Sample Information						Number of Containers for Analysis Requested					
	Description/Location	Date	Time	Matrix	Type						
1	42	2/10	711	DW							
2	185		736								
3	30		700								
4	32		700								
5	27		702								
6	3		645								
7	25		700								
8	183		743								
9	DF 2101		715								
10	68		800								
11	97		830								
12	90		805								
13	187		710								
14	2203		233								
15	182		235								
16	2110		726								
17	83		808								
18	91		808								
19	82		806								
20	193		803								

Sampled: *[Signature]* Date/Time: 2/12/2021
 Received: *[Signature]* Date/Time: 2-16-2021
 Received: *[Signature]* Date/Time: 1/15/14/10

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are indicating that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
Cortland NY 13045
Phone:(607)753-3403 Fax:(607)753-3415
NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

2000118

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jeff/Lew Boces		Date:	7/10		Ice:	YES NO		Container Material:	YES NO		
Address:	20104 NYS Route 3		Date:	7/10		Cooler:	YES NO		Container Size (in MI):	YES NO		
Contact:	Health/Safety Dept.		Date:	7/10		Sample Temp:	38		Preservative:	YES NO		
Phone:	315-779-7000		Date:	7/10		Cooler Seal:	YES NO		Accepted?	YES NO		
Project:	Lead Testing		Date:	7/10								
Quote ID:	Lead Testing		Date:	7/10								
Rush TAT Bus. Days:	2-5 5-7 7-10		Date:	7/10								
Carbon Copy:	Yes		Date:	7/10								
Email Results:	Yes		Date:	7/10								
Fax Results:	Yes		Date:	7/10								
Sample Information			Matrix			Number of Containers for Analysis Requested			Comments/Field Data			
Description/Location	Date	Time	Type	Time	Time							
2115	2/10	7:31	DW	7:31	7:31	1						
188		7:40		7:40	7:40							
2111		7:30		7:30	7:30							
2116		7:30		7:30	7:30							
2113		7:30		7:30	7:30							
2119		7:34		7:34	7:34							
190		7:50		7:50	7:50							
2117		7:55		7:55	7:55							
2105		7:26		7:26	7:26							
99		8:08		8:08	8:08							
2100		7:25		7:25	7:25							
179		7:28		7:28	7:28							
2404A		7:20		7:20	7:20							
184		7:35		7:35	7:35							
192		8:03		8:03	8:03							
2202		7:30		7:30	7:30							
2114		7:30		7:30	7:30							
2118		7:30		7:30	7:30							
2109		7:28		7:28	7:28							
2400		7:21		7:21	7:21							
Sampled:						Date/Time			Comments			
<i>[Signature]</i>						2/12/2021						
Received:						Date/Time			Comments			
<i>[Signature]</i>						2-16-2021/1145/1440						
Received:						Date/Time			Comments			
<i>[Signature]</i>												

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing for which case we will subcontract the analysis to another accredited laboratory. By signing this document you are indicating that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Microbac Laboratories, Inc.


CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

6000118

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	Lead Testing	PO#:	
Quote ID:		Date Req.:	
Rush TAT Bus. Days:	2-5 5-7 7-10		
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data	
34	2/10	707		DW			Ice: <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO
98		812					Cooler: <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO
1218		650					Sample Temp: 3.8
2104 B		735					Cooler Seal: <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO
189		710					Pickup: <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO
48		708					Dropoff: <input checked="" type="checkbox"/> C <input checked="" type="checkbox"/> W
40		705					Accepted? <input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO
180		728					Container Material
2404 D		720					Container size (in ml)
35		708					Preservative
204		800					
2107		727					
93		800					
2404 B		715					
2201		740					
34		709					
17		645					
191		755					
84		807					
95		800					

Print Name and Company	Date/Time	Comments
	2/12/2021	
Received:	2-16-2021	145/1440

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are being received with this action.

