

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: October 7, 2021

Sample ID: 21087

Date Analyzed: 9/29/21

WO Number: 210922087

Customer: Gloversville Enlarged School District

Collection Date: 9/22 & 9/23/21

Address: 234 Lincoln Street, Gloversville, New York 12078

Collection Time: See Chart

Sample Location: Meco Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Well Water

Grab/Composite: Grab

Chlorinated: No

Receipt Temp: Ambient

<u>Sample #</u>	<u>Test</u>	<u>Sample Bottle #</u>	<u>Collection Date</u>	<u>Collection Time</u>	<u>Sample Point</u>	<u>Test Result</u>	<u>Units mg/l</u>	<u>MCL</u>	<u>Qualifiers</u>	<u>Method Used</u>
1	Copper	39	9/22/21	5:53 AM	Cold Water Cafeteria Kitchen Sink	0.0145	mg/l	1.3		EPA 200.8 REV 5.4
1	Lead	39	9/22/21	5:53 AM	Cold Water Cafeteria Kitchen Sink	ND	mg/l	0.015		EPA 200.8 REV 5.4
2	Copper	40	9/23/21	6:16 AM	Boiler Room Hallway Fountain Bottle Fill near Rm #110	0.296	mg/l	1.3		EPA 200.8 REV 5.4
2	Lead	40	9/23/21	6:16 AM	Boiler Room Hallway Fountain Bottle Fill near Rm #110	0.0034	mg/l	0.015		EPA 200.8 REV 5.4
3	Copper	36	9/23/21	6:18 AM	Room #110 Sink	0.165	mg/l	1.3		EPA 200.8 REV 5.4
3	Lead	36	9/23/21	6:18 AM	Room #110 Sink	0.0034	mg/l	0.015		EPA 200.8 REV 5.4
4	Copper	38	9/23/21	6:20 AM	Room #113 Sink	0.162	mg/l	1.3		EPA 200.8 REV 5.4
4	Lead	38	9/23/21	6:20 AM	Room #113 Sink	0.0045	mg/l	0.015		EPA 200.8 REV 5.4
5	Copper	37	9/23/21	6:23 AM	Room #201 Sink	0.255	mg/l	1.3		EPA 200.8 REV 5.4
5	Lead	37	9/23/21	6:23 AM	Room #201 Sink	0.0050	mg/l	0.015		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
219 Noonan Road
Ft. Johnson, New York 12070
Phone/Fax: (518) 842-5171

Date: October 7, 2021

Sample ID: 21087

Date Analyzed: 9/29/21

WO Number: 210922087

Customer: Gloversville Enlarged School District

Collection Date: 9/22 & 9/23/21

Address: 234 Lincoln Street, Gloversville, New York 12078

Collection Time: See Chart

Sample Location: Meco Elementary School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Well Water

Grab/Composite: Grab

Chlorinated: No

Receipt Temp: Ambient

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

All test results are within acceptable limits, please consult chart. If you have any questions, please call the laboratory.
All results are reported as wet weight unless noted.

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:

RL = Reporting Limit
DF = Dilution Factor
< = Less than
> = Greater than
≈ = Approximately
ND = Not Detected at reporting limit
NP = Not Provided
mg/l = milligrams per liter = ppm
ppm = parts per million
µg/l = micrograms per liter = ppb
ppb = parts per billion
gpg = grains per gallon
MCL = Maximum Contaminant Level
SM = Standard Methods For the
Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10709