



# Life Science Laboratories, Inc.

Date Printed: 6/17/21

## Laboratory Analysis Report Prepared For South Seneca Central School District

Client Project ID: Ovid Middle School/High School Lead Study

LSL Project ID: 2107766

Todd Reynolds  
South Seneca Central School District  
7263 Main St.  
Ovid, NY 14521

Phone: (607) 869-9636

A copy of this report was sent to:

Seneca County DOH

Sample ID: HS-050-IM	LSL Sample ID: 2107766-001
Location:	Receive Date/Time: 05/25/21 15:43
Sampled: 05/25/21 4:52	Project Rec'd by: dcr1
Sampled By: MM	Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study

Number of Samples

32

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 213-4090  
Fax (585) 213-4192  
NYS DOH ELAP #11667


LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032

LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by:

  
Kristin E. Carpenter, Quality Staff

Date:

  
06/17/21

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-050-1M

**Lab ID:** 2107766-001A  
**Collection Date:** 05/25/21 4:52  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	< 0.0010	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 06/10/21 18:02

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-038-BF

**Lab ID:** 2107766-002A  
**Collection Date:** 05/25/21 4:53  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	06/10/21 18:08

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-039-F  
**Lab ID:** 2107766-003A  
**Collection Date:** 05/25/21 4:55  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0023	mg/L	06/10/21 18:10

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-040-F

**Lab ID:** 2107766-004A  
**Collection Date:** 05/25/21 4:56  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0025	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 06/10/21 18:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-031-PF*  
**Lab ID:** 2107766-005A  
**Collection Date:** 05/25/21 4:57  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0031	mg/L	06/10/21 18:18

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-032-F

**Lab ID:** 2107766-006A  
**Collection Date:** 05/25/21 4:57  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0034	mg/L	06/10/21 18:20

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-017-F

**Lab ID:** 2107766-007A  
**Collection Date:** 05/25/21 5:00  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/10/21 18:22

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-018-F

**Lab ID:** 2107766-008A  
**Collection Date:** 05/25/21 5:00  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0031	mg/L	06/10/21 18:24

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-054-F*  
**Lab ID:** 2107766-009A  
**Collection Date:** 05/25/21 5:00  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0038	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 06/10/21 18:26

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-008-BF*  
**Lab ID:** 2107766-010A  
**Collection Date:** 05/25/21 5:04  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/10/21 18:28

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-015-F*  
**Lab ID:** 2107766-011A  
**Collection Date:** 05/25/21 5:08  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0097	mg/L	06/10/21 18:30

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-016-IM*  
**Lab ID:** 2107766-012A  
**Collection Date:** 05/25/21 5:08  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/10/21 18:32

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-118-F*  
**Lab ID:** 2107766-013A  
**Collection Date:** 05/25/21 5:08  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0039	mg/L	06/15/21 15:37

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-119-F*  
**Lab ID:** 2107766-014A  
**Collection Date:** 05/25/21 5:08  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0024	mg/L	06/10/21 18:40

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-025-F*  
**Lab ID:** 2107766-015A  
**Collection Date:** 05/25/21 5:15  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0091	mg/L	06/10/21 18:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-026-F

**Lab ID:** 2107766-016A  
**Collection Date:** 05/25/21 5:15  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0020	mg/L	06/10/21 18:44

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-106-BF*  
**Lab ID:** 2107766-017A  
**Collection Date:** 05/25/21 5:18  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/10/21 18:46

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-114-F

**Lab ID:** 2107766-018A  
**Collection Date:** 05/25/21 5:21  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0043	mg/L	06/10/21 18:48

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-115-F*  
**Lab ID:** 2107766-019A  
**Collection Date:** 05/25/21 5:21  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0027	mg/L	06/10/21 18:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-062-BF

**Lab ID:** 2107766-020A  
**Collection Date:** 05/25/21 5:22  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/10/21 18:52

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-058-F*  
**Lab ID:** 2107766-021A  
**Collection Date:** 05/25/21 5:24  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	06/10/21 17:30

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-059-F*  
**Lab ID:** 2107766-022A  
**Collection Date:** 05/25/21 5:24  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0015	mg/L	06/10/21 17:36

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HIS-060-F*

**Lab ID:** 2107766-023A  
**Collection Date:** 05/25/21 5:24  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/10/21 17:38

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-061-F

**Lab ID:** 2107766-024A  
**Collection Date:** 05/25/21 5:24  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	06/10/21 17:40

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-105-F

**Lab ID:** 2107766-025A  
**Collection Date:** 05/25/21 5:26  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0039	mg/L	06/10/21 17:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-116-F

**Lab ID:** 2107766-026A  
**Collection Date:** 05/25/21 5:27  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0013	mg/L	06/10/21 17:44

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-065-BF

**Lab ID:** 2107766-027A  
**Collection Date:** 05/25/21 5:28  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	06/10/21 17:46

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-103-F*  
**Lab ID:** 2107766-028A  
**Collection Date:** 05/25/21 5:31  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0018	mg/L	06/10/21 17:52

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-104-F

**Lab ID:** 2107766-029A  
**Collection Date:** 05/25/21 5:31  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0025	mg/L	06/10/21 17:54

**Qualifiers:** \* Value may exceed the Acceptable Level  
 E Value exceeds the instrument calibration range  
 J Analyte detected below the PQL  
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Practical Quantitation Limit (PQL)  
 S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-120-F*  
**Lab ID:** 2107766-030A  
**Collection Date:** 05/25/21 5:39  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0012	mg/L	06/15/21 15:40

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** HS-121-F

**Lab ID:** 2107766-031A  
**Collection Date:** 05/25/21 5:39  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0023	mg/L	06/15/21 15:44

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** South Seneca Central School District  
**Location:** Ovid Middle School/High School Lead Study  
**Matrix:** PWS

**Client Sample ID:** *HS-122-BF*

**Lab ID:** 2107766-032A  
**Collection Date:** 05/25/21 5:40  
**Date Received:** 05/25/21 15:43

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	06/10/21 18:00

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits

Telephone # (315) 445-1104

Phone # (315) 445-1900

Client: South Seneca Central School District Phone # (607) 869-9636

Address: 7263 Main Street Fax #

Ovid, NY 14521

Contact Person: LSL Project #:

Todd Reynolds Client's Site I.D.:

Ovid Middle School / High School

LSL Sample Number	Client's Sample Identifications	Authorization:		Type	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time							
001A	HS-050-IM	5.25.2021	04:52AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		✓
002	HS-038-BF	5.25.2021	04:53AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
003	HS-039-F	5.25.2021	04:55AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
004	HS-040-F	5.25.2021	04:56AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
005	HS-031-PF	5.25.2021	04:57AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
006	HS-032-F	5.25.2021	04:57AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
007	HS-017-F	5.25.2021	05:00AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
008	HS-018-F	5.25.2021	05:00AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
009	HS-054-F	5.25.2021	05:00AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
010	HS-008-BF	5.25.2021	05:04AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
011	HS-015-F	5.25.2021	05:08AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
012	HS-016-IM	5.25.2021	05:08AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
013	HS-118-F	5.25.2021	05:08AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		
014	HS-119-F	5.25.2021	05:08AM	X	PW	NONE	1 8 oz	LEAD BY EPA 200.8		✓

Notes and Hazard identifications: **PLEASE FILL OUT COMPLETELY**

SAMPLES MUST BE RECEIVED ON ICE

SAMPLES MUST BE RECEIVED ON ICE

Custody Transfers

Print Name: Mike Miroiu Signature: *Mike C. Miroiu*

Received By: *S. Segan*

Received By: *Bill Conahan*

Received for Lab By: *David Kincaid*

Received By: *S. Segan*

Received By: *Bill Conahan*

Received for Lab By: *David Kincaid*

Received By: *S. Segan*

Received By: *Bill Conahan*

Received for Lab By: *David Kincaid*

Date

5.25.2021

08:28AM

5/25/21

10:30 AM

5/25/21

1340

5/25/21

1543

1543

1543

1543

1543

Shipment Method:

Y N 22.7°C

Copy TO: SENECA COUNTY DOH

Results to: jdrew@tstbooces.org

1 Samples Preserved@tstbooces.org

Upon Receipt at Lab@tstbooces.org

mimiroiu@tstbooces.org

**Chain of Custody Record**

2107766

South SenecaCSD 7781

Client: South Seneca Central School District Phone # (607) 869-9636  
 Address: 7263 Main Street Fax #  
 Ovid, NY 14521  
 Contact Person: Todd Reynolds Client's Site I.D.: Ovid Middle School / High School  
 LSL Project #: South SenecaCSD 7781

LSL Sample Number	Client's Sample Identifications	Authorization:			Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time	Type			#	size/type			
015A	HS-025-F	5.25.2021	05:15AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		✓
016	HS-026-F	5.25.2021	05:15AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
017	HS-106-BF	5.25.2021	05:18AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
018	HS-114-F	5.25.2021	05:21AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
019	HS-115-F	5.25.2021	05:21AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
020	HS-062-BF	5.25.2021	05:22AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
021	HS-058-F	5.25.2021	05:24AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
022	HS-059-F	5.25.2021	05:24AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
023	HS-060-F	5.25.2021	05:24AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
024	HS-061-F	5.25.2021	05:24AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
025	HS-0105-F	5.25.2021	05:26AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
026	HS-116-F	5.25.2021	05:27AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
027	HS-065-BF	5.25.2021	06:28AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		
028	HS-103-F	5.25.2021	05:31AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8		✓

**SAMPLES MUST BE RECEIVED ON ICE** Please Fill Out Completely **SAMPLES MUST BE RECEIVED ON ICE**

Notes and Hazard Identifications: **COPY TO: SENECA COUNTY DOH**

Results to: jdraw@tstbooces.org  
 segan@tstbooces.org  
 mal@tstbooces.org  
 mmiroiu@tstbooces.org

Samples Preserved Upon Receipt at Lab

Print Name: Mike Miroiu Signature: *Mike Miroiu*  
 Received By: *D. Egan-Lynch*  
 Relinquished By: *D. Egan-Lynch*  
 Relinquished By: *Bill Donahue*  
 Received for Lab By: *Donald Finisco*

Date: 5.25.2021 08:21 AM  
 5/25/21 10:30 AM  
 5/25/21 1340  
 5/25/21 15:43

Shipment Method: Samples Received Intact: Y N 22.7°C

**Chain of Custody Record**

2107766

SouthSenecaCSD

7781

Client: South Seneca Central School District Phone # (607) 869-9636  
 Address: 7263 Main Street Ovid, NY 14521  
 Telephone # (315) 445-1900 Fax #  
 Contact Person: LSL Project #:  
 Todd Reynolds Client's Site I.D.:  
 Ovid Middle School / High School

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Type grab comp.	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time									
029A	HS-104-F	5.25.2021	05:31AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8			✓
030A	HS-120-F	5.25.2021	05:39AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8			
031A	HS-121-F	5.25.2021	05:39AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8			
032A	HS-122-BF	5.25.2021	05:40AM	X	PW	NONE	1	8 oz	LEAD BY EPA 200.8			✓
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				
				X	PW	NONE	1	8 oz				

**Please Fill Out Completely**

**SAMPLES MUST BE RECEIVED ON ICE**

**SAMPLES MUST BE RECEIVED ON ICE**

Notes and Hazard identifications:  
 COPY TO: SENECA COUNTY DOH

Results to: jdrew@tstbooces.org  
 segan@tstbooces.org  
 Samples Preserved  
 Upon Receipt at Lab malo@tstbooces.org  
 mmiroiu@tstbooces.org

Print Name: Mike Miroiu Signature: *Mike Miroiu*  
 Received By: *David Gonzalez*  
 Relinquished By: *David Gonzalez*  
 Relinquished By: *David Gonzalez*

Shipment Method: Y N 22.7°C  
 Samples Received Intact: Y N

Date: 5.25.2021 08:32 AM  
 5/25/21 10:30 AM  
 5/25/21 1340  
 5/25/21 15:43