



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057
Phone: 315-445-1105 Fax: 315-445-1301

TO: South Seneca CSD
Mihai Miroiu at TST BOCES

FROM: Life Science Laboratories, Inc.
Quality Assurance Department

RE: Revision of Report and/or Invoice
2002395

DATE: June 25, 2021

The attached report and/or invoice was revised. The reason for the change and instructions on how it was revised is as follows:

Mihai Miroiu at TST BOCES requests that the sample identifications in the report correspond to the sample identifications on the chains of custody.

If you have any questions regarding this change, please don't hesitate to contact us at 315-445-1105.



Life Science Laboratories, Inc.

Todd Reynolds
South Seneca Central School District
7263 Main St.
Ovid, NY 14521

Phone: (607) 869-9636

Revised Laboratory Analysis Report For South Seneca Central School District

Client Project ID:

Lead Study

LSL Project ID: **2002395**

Receive Date/Time: 02/14/20 14:00

Project Received by: gis1

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032


LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

This report was reviewed by:



Kristin E. Carpenter, Quality Staff

Date:



02/28/20

A copy of this report was sent to:

Originally Printed: 5/19/20

Page 1 of 2

Date Printed: 6/28/21

- - REVISED LABORATORY ANALYSIS REPORT - -

South Seneca Central School District Ovid, NY

Sample ID: South Seneca Central School District LSL Sample ID: 2002395-001
 Location: Interlaken Elementary School
 Sampled: 02/14/20 4:08 Sampled By: SE
 Sample Matrix: PW

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
<i>(1) Lead Study</i>				
Number of Samples	54		2/24/20	MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-001-F*

Lab ID: 2002395-001A
Collection Date: 02/14/20 4:08
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0040	mg/L	03/04/20 17:02

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-003-F

Lab ID: 2002395-002A
Collection Date: 02/14/20 4:11
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0040	mg/L	03/04/20 17:05

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-008-F

Lab ID: 2002395-003A
Collection Date: 02/14/20 4:15
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0052	mg/L	03/04/20 17:08

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-009-F
Lab ID: 2002395-004A
Collection Date: 02/14/20 4:16
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0037	mg/L	03/04/20 17:18

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-010-DF*
Lab ID: 2002395-005A
Collection Date: 02/14/20 4:15
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0070	mg/L	03/04/20 17:22

Qualifiers:

* Value may exceed the Acceptable Level	B Analyte detected in the associated Method Blank
E Value exceeds the instrument calibration range	H Holding times for preparation or analysis exceeded
J Analyte detected below the PQL	ND Not Detected at the Practical Quantitation Limit (PQL)
P Prim./Conf. column %D or RPD exceeds limit	S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-011-F
Lab ID: 2002395-006A
Collection Date: 02/14/20 4:20
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0065	mg/L	03/04/20 17:25

- Qualifiers:
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-012-F

Lab ID: 2002395-007A
Collection Date: 02/14/20 4:20
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0066	mg/L	03/04/20 17:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-013-F

Lab ID: 2002395-008A
Collection Date: 02/14/20 4:23
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0069	mg/L	02/21/20 19:35

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-015-F
Lab ID: 2002395-009A
Collection Date: 02/14/20 4:25
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0016	mg/L	02/21/20 19:37

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-016-F

Lab ID: 2002395-010A
Collection Date: 02/14/20 4:26
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.019 *	mg/L	02/21/20 19:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-018-F

Lab ID: 2002395-011A
Collection Date: 02/14/20 4:28
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0096	mg/L	02/21/20 19:40

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-021-F

Lab ID: 2002395-012A
Collection Date: 02/14/20 4:31
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	02/21/20 19:46

- | | |
|---|---|
| <p>Qualifiers:</p> <ul style="list-style-type: none"> * Value may exceed the Acceptable Level E Value exceeds the instrument calibration range J Analyte detected below the PQL P Prim./Conf. column %D or RPD exceeds limit | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Practical Quantitation Limit (PQL) S Spike Recovery outside accepted recovery limits |
|---|---|

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-024-F
Lab ID: 2002395-013A
Collection Date: 02/14/20 4:33
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.020 *	mg/L	02/21/20 19:48

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-025-B*
Lab ID: 2002395-014A
Collection Date: 02/14/20 4:33
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.011	mg/L	02/21/20 19:50

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-027-F*
Lab ID: 2002395-015A
Collection Date: 02/14/20 4:34
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0049	mg/L	02/21/20 19:52

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-028-B

Lab ID: 2002395-016A
Collection Date: 02/14/20 4:34
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0022	mg/L	02/21/20 19:54

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-030-F

Lab ID: 2002395-017A
Collection Date: 02/14/20 4:36
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.016 *	mg/L	02/21/20 19:56

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-031-B

Lab ID: 2002395-018A
Collection Date: 02/14/20 4:36
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0044	mg/L	02/24/20 21:11

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-032-F

Lab ID: 2002395-019A
Collection Date: 02/14/20 4:36
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.047 *	mg/L	02/24/20 21:21

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-034-F

Lab ID: 2002395-020A
Collection Date: 02/14/20 4:37
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0087	mg/L	02/24/20 21:24

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-035-B

Lab ID: 2002395-021A
Collection Date: 02/14/20 4:37
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0035	mg/L	02/24/20 21:27

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-037-DF

Lab ID: 2002395-022A
Collection Date: 02/14/20 4:39
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 21:37

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-040-DF*

Lab ID: 2002395-023A
Collection Date: 02/14/20 4:39
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 21:41

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-041-F*

Lab ID: 2002395-024A
Collection Date: 02/14/20 4:39
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.0086	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 02/24/20 21:44

- | | |
|---|---|
| <p>Qualifiers:</p> <ul style="list-style-type: none"> * Value may exceed the Acceptable Level E Value exceeds the instrument calibration range J Analyte detected below the PQL P Prim./Conf. column %D or RPD exceeds limit | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Practical Quantitation Limit (PQL) S Spike Recovery outside accepted recovery limits |
|---|---|

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-042-F

Lab ID: 2002395-025A
Collection Date: 02/14/20 4:42
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.039 *	mg/L	02/24/20 21:48

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-043-DF

Lab ID: 2002395-026A
Collection Date: 02/14/20 4:43
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	02/24/20 21:51

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-044-F*

Lab ID: 2002395-027A
Collection Date: 02/14/20 4:43
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0066	mg/L	02/24/20 21:54

Qualifiers: * Value may exceed the Acceptable Level
 E Value exceeds the instrument calibration range
 J Analyte detected below the PQL
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Practical Quantitation Limit (PQL)
 S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-045-DF

Lab ID: 2002395-028A
Collection Date: 02/14/20 4:44
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	02/24/20 16:57

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-046-F

Lab ID: 2002395-029A
Collection Date: 02/14/20 4:44
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0081	mg/L	02/24/20 22:01

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-051-DF

Lab ID: 2002395-030A
Collection Date: 02/14/20 4:48
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 22:04

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-060-DF*

Lab ID: 2002395-031A
Collection Date: 02/14/20 4:50
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 22:08

- Qualifiers:
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-061-DF

Lab ID: 2002395-032A
Collection Date: 02/14/20 4:50
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 22:18

- Qualifiers:
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-062F

Lab ID: 2002395-033A
Collection Date: 02/14/20 4:55
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0042	mg/L	02/24/20 22:21

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-063-F

Lab ID: 2002395-034A
Collection Date: 02/14/20 4:55
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0021	mg/L	02/24/20 22:25

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-065-F

Lab ID: 2002395-036A
Collection Date: 02/14/20 4:54
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0025	mg/L	02/24/20 22:31

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-066-F

Lab ID: 2002395-037A
Collection Date: 02/14/20 4:55
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.033 *	mg/L	02/24/20 22:35

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-072-DF*
Lab ID: 2002395-038A
Collection Date: 02/14/20 4:57
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0051	mg/L	02/24/20 22:38

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-073-DF
Lab ID: 2002395-039A
Collection Date: 02/14/20 4:57
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0038	mg/L	02/24/20 22:48

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-074-F

Lab ID: 2002395-040A
Collection Date: 02/14/20 4:58
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.010	mg/L	02/24/20 22:58

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-076-DF*

Lab ID: 2002395-041A
Collection Date: 02/14/20 5:01
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	< 0.0010	EPA 200.8,Rev.5.4 mg/L	(EPA 200.2) 02/24/20 23:02

- | | |
|---|---|
| <p>Qualifiers:</p> <ul style="list-style-type: none"> * Value may exceed the Acceptable Level E Value exceeds the instrument calibration range J Analyte detected below the PQL P Prim./Conf. column %D or RPD exceeds limit | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Practical Quantitation Limit (PQL) S Spike Recovery outside accepted recovery limits |
|---|---|

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-078-F*

Lab ID: 2002395-042A
Collection Date: 02/14/20 5:10
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0039	mg/L	02/24/20 23:05

- Qualifiers:
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-079-B
Lab ID: 2002395-043A
Collection Date: 02/14/20 5:10
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0014	mg/L	02/24/20 23:09

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-086-DF*
Lab ID: 2002395-044A
Collection Date: 02/14/20 5:03
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0020	mg/L	02/24/20 23:12

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-087-F

Lab ID: 2002395-045A
Collection Date: 02/14/20 5:04
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.012	mg/L	02/24/20 23:15

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-092

Lab ID: 2002395-046A
Collection Date: 02/14/20 5:12
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev.5.4	(EPA 200.2)
Lead	0.013	mg/L	02/24/20 23:19

Qualifiers: * Value may exceed the Acceptable Level
 E Value exceeds the instrument calibration range
 J Analyte detected below the PQL
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Practical Quantitation Limit (PQL)
 S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-093-DF

Lab ID: 2002395-047A
Collection Date: 02/14/20 5:12
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0023	mg/L	02/24/20 23:22

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-094-F

Lab ID: 2002395-048A
Collection Date: 02/14/20 5:13
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0029	mg/L	02/24/20 23:25

Qualifiers: * Value may exceed the Acceptable Level
E Value exceeds the instrument calibration range
J Analyte detected below the PQL
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Practical Quantitation Limit (PQL)
S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-098-F
Lab ID: 2002395-049A
Collection Date: 02/14/20 5:15
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0055	mg/L	02/24/20 23:29

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: ES-100-DF

Lab ID: 2002395-050A
Collection Date: 02/14/20 5:17
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0011	mg/L	02/24/20 23:39

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-104-DF*
Lab ID: 2002395-051A
Collection Date: 02/14/20 5:22
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0027	mg/L	02/24/20 23:42

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-108-F*

Lab ID: 2002395-052A
Collection Date: 02/14/20 5:24
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.039 *	mg/L	02/24/20 23:46

Qualifiers: * Value may exceed the Acceptable Level
 E Value exceeds the instrument calibration range
 J Analyte detected below the PQL
 P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Practical Quantitation Limit (PQL)
 S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-110-DF*

Lab ID: 2002395-053A
Collection Date: 02/14/20 5:25
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	02/24/20 23:49

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

REVISED



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: South Seneca Central School District
Location: Lead Study
Matrix: PW

Client Sample ID: *ES-114-F*
Lab ID: 2002395-054A
Collection Date: 02/14/20 5:26
Date Received: 02/14/20 14:00

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.018 *	mg/L	02/24/20 23:52

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

Client: South Seneca Central School District Phone # (607) 869-9636
 Address: 7263 Main Street Fax #
 Ovid, NY 14521

Contact Person: LSL Project #:
 Todd Reynolds Client's Site I.D.:
 Interlaken Elementary School

LSL Sample Number	Client's Sample Identifications	Authorization:		Type grab comp.	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time							
ES-001	ES-001-F	2/14/20	4:08 AM	✓		None	1 250 mL	Lead EPA 200.8		
002	ES-003-F	2/14/20	4:11 AM	✓		None	1 250 mL	Lead EPA 200.8		
003	ES-008-F	2/14/20	4:15 AM	✓		None	1 250 mL	Lead EPA 200.8		
004	ES-009-F	2/14/20	4:16 AM	✓		None	1 250 mL	Lead EPA 200.8		
005	ES-010-DF	2/14/20	4:15 AM	✓		None	1 250 mL	Lead EPA 200.8		
006	ES-011-F	2/14/20	4:20 AM	✓		None	1 250 mL	Lead EPA 200.8		
007	ES-012-F	2/14/20	4:20 AM	✓		None	1 250 mL	Lead EPA 200.8		
008	ES-013-F	2/14/20	4:23 AM	✓		None	1 250 mL	Lead EPA 200.8		
009	ES-015-F	2/14/20	4:25 AM	✓		None	1 250 mL	Lead EPA 200.8		
010	ES-016-F	2/14/20	4:26 AM	✓		None	1 250 mL	Lead EPA 200.8		
011	ES-018-F	2/14/20	4:28 AM	✓		None	1 250 mL	Lead EPA 200.8		
012	ES-021-F	2/14/20	4:31 AM	✓		None	1 250 mL	Lead EPA 200.8		
013	ES-024-F	2/14/20	4:33 AM	✓		None	1 250 mL	Lead EPA 200.8		
014	ES-025-B	2/14/20	4:33 AM	✓		None	1 250 mL	Lead EPA 200.8		

SAMPLES MUST BE RECEIVED ON ICE Please Fill Out Completely

Custody Transfers

Print Name: Stephanie Egan-Engels Signature: *[Signature]* Date: 2/14/20 11:51 AM

Received By: *[Signature]* Date: 2.14.20 13:55

Relinquished By: *[Signature]* Received By: *[Signature]*

Relinquished By: *[Signature]* Received for Lab By: *[Signature]* Date: 2/14/20 19:00

Shipment Method: Y N 19.0

Notes and Hazard identifications:

Send test results to:
ldrew@tstbooces.org
segan@tstbooces.org
malc@tstbooces.org
mimiroiu@tstbooces.org

Chain of Custody Record

2002395

SouthSenecaCSD

7781

Contact Person: LSL Project #:

Todd Reynolds

Client's Site I.D.:

Interlaken Elementary School

Client's Project I.D.: Lead in Drinking Water

Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
ES-015	ES-027-F	2/14/20	4:34 AM	V			None	1	250 mL	Lead EPA 200.8		
016	ES-028-B	2/14/20	4:34 AM	V			None	1	250 mL	Lead EPA 200.8		
017	ES-030-F	2/14/20	4:36 AM	V			None	1	250 mL	Lead EPA 200.8		
018	ES-031-B	2/14/20	4:36 AM	V			None	1	250 mL	Lead EPA 200.8		
019	ES-032-F	2/14/20	4:36 AM	V			None	1	250 mL	Lead EPA 200.8		
020	ES-034-F	2/14/20	4:37 AM	V			None	1	250 mL	Lead EPA 200.8		
021	ES-035-B	2/14/20	4:37 AM	V			None	1	250 mL	Lead EPA 200.8		
022	ES-037-DF	2/14/20	4:39 AM	V			None	1	250 mL	Lead EPA 200.8		
023	ES-040-DF	2/14/20	4:39 AM	V			None	1	250 mL	Lead EPA 200.8		
024	ES-041-F	2/14/20	4:39 AM	V			None	1	250 mL	Lead EPA 200.8		
025	ES-042-F	2/14/20	4:42 AM	V			None	1	250 mL	Lead EPA 200.8		
026	ES-043-DF	2/14/20	4:43 AM	V			None	1	250 mL	Lead EPA 200.8		
027	ES-044-F	2/14/20	4:43 AM	V			None	1	250 mL	Lead EPA 200.8		
028	ES-045-DF	2/14/20	4:44 AM	V			None	1	250 mL	Lead EPA 200.8		

SAMPLES MUST BE RECEIVED ON ICE

Please Fill Out Completely

SAMPLES MUST BE RECEIVED ON ICE

Notes and Hazard Identifications:

Send test results to:

ldrew@tstbooces.org

segan@tstbooces.org

malo@tstbooces.org

mmiroiu@tstbooces.org

Custody Transfers

Sampled and Reinquished By:

Print Name: Stephanie Egan-Engels

Signature: *[Signature]*

Date: 2/14/20

Time: 11:54 AM

Reinquished By: *[Signature]*

Received By: *[Signature]*

Date: 2/14/20

Time: 13:55

Reinquished By:

Received for Lab By: *[Signature]*

Date: 2/14/20

Time: 14:00

Shipment Method:

Samples Received Intact: Y N 19.0's



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057

Chain of Custody Record

Client: South Seneca Central School District
 Address: 7263 Main Street
 Ovid, NY 14521

Telefax # (315) 445-1900
 Phone # (607) 869-9636
 Fax #

Contact Person: Todd Reynolds
 Client's Site I.D.: Interlaken Elementary School
 LSL Project #:

LSL Sample Number	Client's Sample Identifications	Authorization:		Sample Date	Sample Time	Type grab comp.	Matrix	Preserv. Added	# Containers size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time									
ES-029	ES-046-F	2/14/20	4:44 AM	V		None	1	250 mL	Lead EPA 200.8			
030	ES-051-DF	2/14/20	4:48 AM	V		None	1	250 mL	Lead EPA 200.8			
031	ES-060-DF	2/14/20	4:50 AM	V		None	1	250 mL	Lead EPA 200.8			
032	ES-061-DF	2/14/20	4:50 AM	V		None	1	250 mL	Lead EPA 200.8			
033	ES-062-F	2/14/20	4:55 AM	V		None	1	250 mL	Lead EPA 200.8			
034	ES-063-F	2/14/20	4:55 AM	V		None	1	250 mL	Lead EPA 200.8			
035	ES-64-IM	2/14/20	4:54 AM	V		None	1	250 mL	Lead EPA 200.8			
036	ES-065-F	2/14/20	4:54 AM	V		None	1	250 mL	Lead EPA 200.8			
037	ES-066-F	2/14/20	4:55 AM	V		None	1	250 mL	Lead EPA 200.8			
038	ES-072-DF	2/14/20	4:57 AM	V		None	1	250 mL	Lead EPA 200.8			
039	ES-073-DF	2/14/20	4:57 AM	V		None	1	250 mL	Lead EPA 200.8			
040	ES-074-F	2/14/20	4:58 AM	V		None	1	250 mL	Lead EPA 200.8			
041	ES-076-DF	2/14/20	5:01 AM	V		None	1	250 mL	Lead EPA 200.8			
042	ES-078-F	2/14/20	5:10 AM	V		None	1	250 mL	Lead EPA 200.8			

SAMPLES MUST BE RECEIVED ON ICE

Please Fill Out Completely

Custody Transfers

Notes and Hazard identifications:

Send test results to: ldrew@tstbooces.org
segan@tstbooces.org
malo@tstbooces.org
mmiroliu@tstbooces.org

Print Name: Stephanie Egan-Engels
 Signature: *[Signature]*
 Date: 2/14/20
 Time: 11:54 AM

Received By: *[Signature]*
 Date: 2/14/20
 Time: 13:55

Received for Lab By: *[Signature]*
 Date: 2/14/20
 Time: 14:00

Shipment Method: Samples Received Intact: Y N 19.0"



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057

Chain of Custody Record

Client: South Seneca Central School District
 Address: 7263 Main Street
 Ovid, NY 14521
 Phone # (315) 445-1900
 Phone # (607) 869-9636
 Fax #

Contact Person: Todd Reynolds
 LSL Project #: Interlaken Elementary School
 Client's Site I.D.:

LSL Sample Number	Client's Sample Identifications	Authorization:		Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
		Sample Date	Sample Time						
ES-043	ES-079-B	2/14/20	5:10 AM		None	1 250 mL	Lead EPA 200.8		
044	ES-086-DF	2/14/20	5:03 AM		None	1 250 mL	Lead EPA 200.8		
045	ES-087-F	2/14/20	5:04 AM		None	1 250 mL	Lead EPA 200.8		
046	ES-092	2/14/20	5:12 AM		None	1 250 mL	Lead EPA 200.8		
047	ES-093-DF	2/14/20	5:12 AM		None	1 250 mL	Lead EPA 200.8		
048	ES-094-F	2/14/20	5:13 AM		None	1 250 mL	Lead EPA 200.8		
049	ES-098-F	2/14/20	5:15 AM		None	1 250 mL	Lead EPA 200.8		
050	ES-100-DF	2/14/20	5:17 AM		None	1 250 mL	Lead EPA 200.8		
051	ES-104-DF	2/14/20	5:22 AM		None	1 250 mL	Lead EPA 200.8		
052	ES-108-F	2/14/20	5:24 AM		None	1 250 mL	Lead EPA 200.8		
053	ES-110-DF	2/14/20	5:25 AM		None	1 250 mL	Lead EPA 200.8		
054	ES-114-F	2/14/20	5:26 AM		None	1 250 mL	Lead EPA 200.8		
055 KA					None	1 250 mL	Lead EPA 200.8		
056 KA					None	1 250 mL	Lead EPA 200.8		

SAMPLES MUST BE RECEIVED ON ICE

Please Fill Out Completely

SAMPLES MUST BE RECEIVED ON ICE

Custody Transfers

Print Name: Stephanie Egan-Engels
 Signature: *[Signature]*
 Date: 2/14/20
 Time: 11:54 AM

Relinquished By: *[Signature]*
 Received By: *[Signature]*
 Date: 2-14-20
 Time: 13:55

Relinquished By: *[Signature]*
 Received for Lab By: *[Signature]*
 Date: 2-14-20
 Time: 14:10

Shipment Method: *[Signature]*
 Samples Received Intact: Y N
 Date: 19:00

Send test results to:
ldrew@tstbooces.org
segan@tstbooces.org
malo@tstbooces.org
mmiroju@tstbooces.org