

Tremco Incorporated

3735 Green Road • Beachwood, Ohio 44122 • 216-292-5000



Robert Hamersky
Field Advisor

Cell: 609-947-00291
E-mail: Rhamersky@tremcoinc.com

Re: Pinelands High School
520 Nugentown Road
Little Egg Harbor, NJ 08087

Roof Assembly Letter

See the following project roof composition **build sheet** below.

Metal Deck - Trinity Report S34, S36 & S37:

- **Cap Sheet**
 - POWERply Premium FR
 - Set in Standard PP Cold Applied Adhesive (2 gallons per sq) Welded Laps
- **Base SBS Ply**
 - POWERply HT Plus Smooth
 - Set in type III hot asphalt
- **Coverboard**
 - 1/2" Coverboard- set in type III Hot asphalt
 - Fiberboard
 - On 2nd story levels, must use 1/2" Dens-deck Prime or Secure Rock in (zone 3) corner locations only!
- **Insulation**
 - 2- layers of 2.5": Iso. Insulation –
 - Mechanically fastened with #14 HD fastener and 3" insulation Plate
 - Fastening pattern
 - Zone 1 field- 1 per 2 square feet (8 per 4' x 4' board)
 - Zone 2 perimeter – 1 per 2 square feet
 - Zone 3 corners- 1 per 1.45 sf (11 per 4' x 4' board)
 - Perimeter dimensions are calculated by the following:
 - .10 x the lesser roof dimension, or .40 x the height. The less of the two numbers can be utilized rounding up to the nearest 4' wide insulation board.
- **Roof decking:**
 - Steel Decking

Respectfully,
Robert Hamersky
Field Advisor
Tremco Roofing & Building Maintenance