



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

**Veazie Community School**  
1040 School Street  
Veazie, ME 04401

**Date Printed:** 12/08/2021  
**Work Order #:** 2112-00785  
**Client Job #:** 476  
**Date Received:** 12/06/2021  
**Sample collected in:** Maine

**Attached please find results for the analysis of the samples received on the date referenced above.**

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com



## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 12/08/2021  
**CLIENT NAME:** Veazie Community School

**CLIENT ADDRESS:** 1040 School Street  
 Veazie, ME 04401

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 12/06/2021 09:25AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 18° CELSIUS  
**CLIENT JOB #:** 476

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2112-00785-001	Kitchen Sm HW	F	KF	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 07:46PM
2112-00785-002	Kitchen Big HW	F	KF	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 07:49PM
2112-00785-003	Science Lab Sink 3	F	OT	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 07:53PM
2112-00785-004	Science Lab Sink 4	F	OT	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 08:04PM
2112-00785-005	Frazier Sink	F	OT	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 08:08PM
2112-00785-006	Int. Spare Sink	F	OT	12/03/2021 07:00AM	<1	ppb			JLR-NH	12/07/2021 08:11PM



Rebecca L. Labranche  
 Laboratory Director