



Liberty OHM

September 16th, 2016

Mr. Marty Foutch
Facilities Director
Bixby Public Schools
109 N. Armstrong
Bixby, OK 74008

**RE: Bixby Central Intermediate - 25% IAQ
Liberty OHM File Number 16-162**

**CC: Richard Walters
Maintenance Department**

Dear Mr. Foutch:

On September 12th, 2016, Liberty OHM conducted quality assurance testing at Bixby Central Intermediate. A total of 25% of the rooms were selected and tested at random for indoor air quality (spore count).

Findings

On September 12th, 14 rooms, for a total of 25% of Bixby Central Intermediate, were selected at random and tested. The ratio of total indoor/outdoor airborne mold concentrations was not elevated on the day of testing.

The following observations were noted:

- No visible mold or water intrusion/damage was found on the day of testing.

Recommendations

- No recommendations are provided at this time.

Disclaimer

Liberty OHM makes no assertion as to the health risks associated with the levels reported in this report. We make no correlation that the levels reported are safe for occupancy or do not pose a risk from exposure. We advise you, our client to consult with an Occupational Health or other qualified physician for additional information and guidance.

IAQ Results – Quality Assurance Testing – Central Intermediate
Survey Date: September 12, 2016
Report Date: September 16, 2016
Page 2

If you have questions or need additional information, please let me know.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack Kerr". The signature is written in a cursive style with a large, looped initial "J".

Jack Kerr, B.S.
EHS Project Manager
Liberty OHM

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
Location	Total spores/m3	Species	Raw count	Calc. count	% of total
1: Outside Reference Pre	12,000	Cladosporium	106	5,900	48
		Basidiospores	45	2,500	20
		Ascospores	32	1,800	14
		Penicillium/Aspergillus types	20	1,100	9
		Cercospora	61	410	3
		Smuts, Periconia, Myxomycetes	41	270	2
		Alternaria	20	130	1
		Curvularia	9	60	< 1
		Bipolaris/Drechslera group	7	47	< 1
		Fusarium	5	33	< 1
		Nigrospora	4	27	< 1
		Ulocladium	3	20	< 1
		Pithomyces	3	20	< 1
		Epicoccum	2	13	< 1
		Rusts	1	7	< 1
		Oidium	1	7	< 1
2: 304	160	Basidiospores	2	53	33
		Penicillium/Aspergillus types	1	27	17
		Ascospores	1	27	17
		Bipolaris/Drechslera group	3	20	13
		Rusts	1	7	4
		Pithomyces	1	7	4
		Other brown	1	7	4
		Curvularia	1	7	4
		Alternaria	1	7	4

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
3: Teachers Lounge	700	Cladosporium	6	160	23
		Basidiospores	6	160	23
		Ascospores	5	130	19
		Curvularia	11	73	10
		Smuts, Periconia, Myxomycetes	8	53	8
		Bipolaris/Drechslera group	4	27	4
		Pithomyces	3	20	3
		Nigrospora	3	20	3
		Fusarium	3	20	3
		Alternaria	2	13	2
		Spegazzinia	1	7	1
		Other brown	1	7	1
		Epicoccum	1	7	1
4: 160	40	Curvularia	2	13	33
		Smuts, Periconia, Myxomycetes	1	7	17
		Other brown	1	7	17
		Nigrospora	1	7	17
		Bipolaris/Drechslera group	1	7	17
5: 158	250	Penicillium/Aspergillus types	2	53	21
		Cladosporium	2	53	21
		Basidiospores	2	53	21
		Ascospores	1	27	11
		Curvularia	3	20	8
		Smuts, Periconia, Myxomycetes	2	13	5
		Pithomyces	1	7	3
		Other brown	1	7	3
		Nigrospora	1	7	3
		Cercospora	1	7	3
		Bipolaris/Drechslera group	1	7	3

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
6: Cafeteria	490	Cladosporium	9	240	49
		Penicillium/Aspergillus types	4	110	22
		Basidiospores	2	53	11
		Ascospores	1	27	5
		Cercospora	3	20	4
		Pithomyces	2	13	3
		Smuts, Periconia, Myxomycetes	1	7	1
		Other brown	1	7	1
		Curvularia	1	7	1
		Bipolaris/Drechslera group	1	7	1
7: Psych Testing	93	Basidiospores	2	53	57
		Ascospores	1	27	29
		Smuts, Periconia, Myxomycetes	1	7	7
		Curvularia	1	7	7
8: 237	250	Basidiospores	3	80	32
		Penicillium/Aspergillus types	2	53	22
		Ascospores	2	53	22
		Cladosporium	1	27	11
		Smuts, Periconia, Myxomycetes	3	20	8
		Other brown	1	7	3
		Cercospora	1	7	3
9: Library/Media Center	750	Cladosporium	9	240	32
		Ascospores	9	240	32
		Basidiospores	6	160	21
		Penicillium/Aspergillus types	3	80	11
		Smuts, Periconia, Myxomycetes	3	20	3
		Alternaria	1	7	1

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
10: 401	930	Cladosporium	16	430	46
		Basidiospores	7	190	20
		Ascospores	6	160	17
		Penicillium/Aspergillus types	2	53	6
		Smuts, Periconia, Myxomycetes	6	40	4
		Cercospora	3	20	2
		Alternaria	2	13	1
		Pithomyces	1	7	1
		Other brown	1	7	1
		Curvularia	1	7	1
		Chaetomium	1	7	1
		Bipolaris/Drechslera group	1	7	1
11: 403	110	Penicillium/Aspergillus types	3	80	71
		Basidiospores	1	27	24
		Pithomyces	1	7	6
12: 233	260	Curvularia	8	53	21
		Cladosporium	2	53	21
		Pithomyces	6	40	15
		Bipolaris/Drechslera group	6	40	15
		Rusts	4	27	10
		Smuts, Periconia, Myxomycetes	3	20	8
		Other brown	2	13	5
		Spegazzinia	1	7	3
		Nigrospora	1	7	3
13: 204	240	Cladosporium	4	110	44
		Smuts, Periconia, Myxomycetes	4	27	11
		Penicillium/Aspergillus types	1	27	11
		Curvularia	4	27	11
		Bipolaris/Drechslera group	2	13	6
		Alternaria	2	13	6
		Rusts	1	7	3
		Polythrincium	1	7	3
		Pithomyces	1	7	3
		Nigrospora	1	7	3

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
14: 216	460	Curvularia	21	140	30
		Penicillium/Aspergillus types	3	80	17
		Bipolaris/Drechslera group	11	73	16
		Pithomyces	8	53	12
		Cladosporium	2	53	12
		Smuts, Periconia, Myxomycetes	3	20	4
		Other brown	3	20	4
		Rusts	2	13	3
		Nigrospora	1	7	1
15: 208	380	Cladosporium	4	110	28
		Basidiospores	3	80	21
		Ascospores	3	80	21
		Penicillium/Aspergillus types	1	27	7
		Alternaria	3	20	5
		Smuts, Periconia, Myxomycetes	2	13	4
		Curvularia	2	13	4
		Cercospora	2	13	4
		Bipolaris/Drechslera group	2	13	4
		Rusts	1	7	2
		Pithomyces	1	7	2

Table 1 Bixby Central Intermediate 25% Random Air Monitoring Survey Date: September 12th, 2016					
16: Outside Reference Post	15,000	Cladosporium	141	7,800	53
		Basidiospores	44	2,400	16
		Ascospores	38	2,100	14
		Penicillium/Aspergillus types	16	890	6
		Cercospora	109	730	5
		Smuts, Periconia, Myxomycetes	41	270	2
		Alternaria	40	270	2
		Curvularia	14	93	1
		Fusarium	12	80	1
		Nigrospora	11	73	< 1
		Ulocladium	4	27	< 1
		Pithomyces	3	20	< 1
		Rusts	2	13	< 1
		Chaetomium	2	13	< 1
		Bipolaris/Drechslera group	2	13	< 1
		Spegazzinia	1	7	< 1
		Other brown	1	7	< 1



Liberty OHM

APPENDIX A

LABORATORY RESULTS



Report for:

Jack Kerr
Liberty OHM
1211 E 39th St
Tulsa, OK 74105

Regarding: Project: 16-162; Bixby Central Intermediate 25%
EML ID: 1600832

Approved by:

Dates of Analysis:
Spore trap analysis: 09-15-2016

Technical Manager
Louise White

Service SOPs: Spore trap analysis (EM-MY-S-1038)
AIHA-LAP, LLC accredited service, Lab ID #179768

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the items tested.

EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: Liberty OHM
C/O: Jack Kerr
Re: 16-162; Bixby Central Intermediate 25%

Date of Sampling: 09-12-2016
Date of Receipt: 09-13-2016
Date of Report: 09-15-2016

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	1: Outside Reference Pre				2: 304				3: Teachers Lounge				4: 160			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	7431825-1				7431826-1				7431827-1				7431828-1			
Analysis Date:	09/15/2016				09/15/2016				09/15/2016				09/15/2016			
Sample volume (liters)	150				150				150				150			
Background debris (1-4+)††	1+				3+				4+				2+			
	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%
Hyphal fragments	9	60	7	n/a	5	33	7	n/a	15	100	7	n/a	1	7	7	n/a
Pollen	281	1,900	7	n/a					2	13	7	n/a	3	20	7	n/a
§ TOTAL FUNGAL SPORES	360	12,000	n/a	100	12	160	n/a	100	54	700	n/a	100	6	40	n/a	100
Alternaria	20	130	7	1	1	7	7	4	2	13	7	2				
Ascospores	32	1,800	56	14	1	27	27	17	5	130	27	19				
Basidiospores	45	2,500	56	20	2	53	27	33	6	160	27	23				
Bipolaris/Drechslera group	7	47	7	< 1	3	20	7	13	4	27	7	4	1	7	7	17
Cercospora	61	410	7	3												
Chaetomium																
Cladosporium	106	5,900	56	48					6	160	27	23				
Curvularia	9	60	7	< 1	1	7	7	4	11	73	7	10	2	13	7	33
Epicoccum	2	13	7	< 1					1	7	7	1				
Fusarium	5	33	7	< 1					3	20	7	3				
Nigrospora	4	27	7	< 1					3	20	7	3	1	7	7	17
Oidium	1	7	7	< 1												
Other brown					1	7	7	4	1	7	7	1	1	7	7	17
Penicillium/Aspergillus types	20	1,100	56	9	1	27	27	17								
Pithomyces	3	20	7	< 1	1	7	7	4	3	20	7	3				
Rusts	1	7	7	< 1	1	7	7	4								
Smuts, Periconia, Myxomycetes	41	270	7	2					8	53	7	8	1	7	7	17
Spegazzinia									1	7	7	1				
Stachybotrys																
Ulocladium	3	20	7	< 1												

Comments: A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

*The DL/m3 has been rounded to a whole number.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: Liberty OHM
C/O: Jack Kerr
Re: 16-162; Bixby Central Intermediate 25%

Date of Sampling: 09-12-2016
Date of Receipt: 09-13-2016
Date of Report: 09-15-2016

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	5: 158				6: Cafeteria				7: Psych Testing				8: 237			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	7431829-1				7431830-1				7431831-1				7431832-1			
Analysis Date:	09/15/2016				09/15/2016				09/15/2016				09/15/2016			
Sample volume (liters)	150				150				150				150			
Background debris (1-4+)††	2+				3+				2+				1+			
	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%
Hyphal fragments	2	13	7	n/a	2	13	7	n/a	1	7	7	n/a	1	7	7	n/a
Pollen													3	20	7	n/a
§ TOTAL FUNGAL SPORES	17	250	n/a	100	25	490	n/a	100	5	93	n/a	100	13	250	n/a	100
Ascospores	1	27	27	11	1	27	27	5	1	27	27	29	2	53	27	22
Basidiospores	2	53	27	21	2	53	27	11	2	53	27	57	3	80	27	32
Bipolaris/Drechslera group	1	7	7	3	1	7	7	1								
Cercospora	1	7	7	3	3	20	7	4					1	7	7	3
Chaetomium																
Cladosporium	2	53	27	21	9	240	27	49					1	27	27	11
Curvularia	3	20	7	8	1	7	7	1	1	7	7	7				
Nigrospora	1	7	7	3												
Other brown	1	7	7	3	1	7	7	1					1	7	7	3
Penicillium/Aspergillus types	2	53	27	21	4	110	27	22					2	53	27	22
Pithomyces	1	7	7	3	2	13	7	3								
Smuts, Periconia, Myxomycetes	2	13	7	5	1	7	7	1	1	7	7	7	3	20	7	8
Stachybotrys																

Comments: A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

*The DL/m3 has been rounded to a whole number.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: Liberty OHM
C/O: Jack Kerr
Re: 16-162; Bixby Central Intermediate 25%

Date of Sampling: 09-12-2016
Date of Receipt: 09-13-2016
Date of Report: 09-15-2016

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	9: Library/Media Center				10: 401				11: 403				12: 233			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	7431833-1				7431834-1				7431835-1				7431836-1			
Analysis Date:	09/15/2016				09/15/2016				09/15/2016				09/15/2016			
Sample volume (liters)	150				150				150				150			
Background debris (1-4+)††	2+				3+				3+				4+			
	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%
Hyphal fragments	2	13	7	n/a	5	33	7	n/a	1	7	7	n/a	7	47	7	n/a
Pollen	1	7	7	n/a	5	33	7	n/a					5	33	7	n/a
§ TOTAL FUNGAL SPORES	31	750	n/a	100	47	930	n/a	100	5	110	n/a	100	33	260	n/a	100
Alternaria	1	7	7	1	2	13	7	1								
Ascospores	9	240	27	32	6	160	27	17								
Basidiospores	6	160	27	21	7	190	27	20	1	27	27	24				
Bipolaris/Drechslera group					1	7	7	1					6	40	7	15
Cercospora					3	20	7	2								
Chaetomium					1	7	7	1								
Cladosporium	9	240	27	32	16	430	27	46					2	53	27	21
Curvularia					1	7	7	1					8	53	7	21
Nigrospora													1	7	7	3
Other brown					1	7	7	1					2	13	7	5
Penicillium/Aspergillus types	3	80	27	11	2	53	27	6	3	80	27	71				
Pithomyces					1	7	7	1	1	7	7	6	6	40	7	15
Rusts													4	27	7	10
Smuts, Periconia, Myxomycetes	3	20	7	3	6	40	7	4					3	20	7	8
Spegazzinia													1	7	7	3
Stachybotrys																

Comments: A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

*The DL/m3 has been rounded to a whole number.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

Client: Liberty OHM
C/O: Jack Kerr
Re: 16-162; Bixby Central Intermediate 25%

Date of Sampling: 09-12-2016
Date of Receipt: 09-13-2016
Date of Report: 09-15-2016

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	13: 204				14: 216				15: 208				16: Outside Reference Post			
Comments (see below)	A				A				A				A			
Lab ID-Version‡:	7431837-1				7431838-1				7431839-1				7431840-1			
Analysis Date:	09/15/2016				09/15/2016				09/15/2016				09/15/2016			
Sample volume (liters)	150				150				150				150			
Background debris (1-4+)††	4+				4+				3+				1+			
	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%	Count	Count/m3	DL/m3*	%
Hyphal fragments	3	20	7	n/a	8	53	7	n/a	7	47	7	n/a	15	100	7	n/a
Pollen	4	27	7	n/a	2	13	7	n/a	3	20	7	n/a	34	910	27	n/a
§ TOTAL FUNGAL SPORES	21	240	n/a	100	54	460	n/a	100	24	380	n/a	100	481	15,000	n/a	100
Alternaria	2	13	7	6					3	20	7	5	40	270	7	2
Ascospores									3	80	27	21	38	2,100	56	14
Basidiospores									3	80	27	21	44	2,400	56	16
Bipolaris/Drechslera group	2	13	7	6	11	73	7	16	2	13	7	4	2	13	7	<1
Cercospora									2	13	7	4	109	730	7	5
Chaetomium													2	13	7	<1
Cladosporium	4	110	27	44	2	53	27	12	4	110	27	28	141	7,800	56	53
Curvularia	4	27	7	11	21	140	7	30	2	13	7	4	14	93	7	1
Fusarium													12	80	7	1
Nigrospora	1	7	7	3	1	7	7	1					11	73	7	<1
Other brown					3	20	7	4					1	7	7	<1
Penicillium/Aspergillus types	1	27	27	11	3	80	27	17	1	27	27	7	16	890	56	6
Pithomyces	1	7	7	3	8	53	7	12	1	7	7	2	3	20	7	<1
Polythrincium	1	7	7	3												
Rusts	1	7	7	3	2	13	7	3	1	7	7	2	2	13	7	<1
Smuts, Periconia, Myxomycetes	4	27	7	11	3	20	7	4	2	13	7	4	41	270	7	2
Spegazzinia													1	7	7	<1
Stachybotrys																
Ulocladium													4	27	7	<1

Comments: A) Analysis of replicate sample is delayed.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

*The DL/m3 has been rounded to a whole number.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Fungal Spores has been rounded to two significant figures to reflect analytical precision.

CHAIN OF CUSTODY



www.EMLabPK.com

A TestAmerica Company

New Jersey: 3800 Lincoln Drive East, Suite A, Marlton, NJ 08053 • (609) 871-1984
 Phoenix, AZ: 1501 West Kendall Drive, Phoenix, AZ 85027 • (602) 651-4602
 San Bruno, CA: 1150 Bayhill Drive, #100, San Bruno, CA 94068 • (650) 608-6653

Weather	Fog	Rain	Snow	Wind	Clear
None	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Light	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Medium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heavy	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CONTACT INFORMATION

Company:	Liberty OIL & GAS	Address:	1211 E. 39th St Tulsa, OK 74105 USA
Contact:	Jack Kern	Special Instructions:	
Phone:	918-742-1567		

PROJECT INFORMATION

Project ID:	16-162	TURN AROUND TIME CODES (TAT)	STD - Standard (1)
Project Description:	Bibby Central Intermediate OSHA	ND - New Business Day	
Project Zip Code:		SD - Same Business Day Rush	
PO Number:		WH - Weekend / Holiday	
Sample ID		Sample Type (Abbrev)	TAT (Hours)

Sampling Date & Time: 9-12-16
 Sampled By: Jack

Rushes received after 2 pm on weekdays, will be considered received the next business day. Please alert us in advance of weekend analysis needs.

Sample ID	Description	Sample Type (Abbrev)	TAT (Hours)	Total Volume / Area (as specified)	Notes (Date of day, Temp, Etc., etc.)
1	Outside Residence Pore	ST	STD	150L	
2	30" Teacher's Lounge				
3	15B				
4	Colberts				
5	Psych Testers				
6	237				
7	Library / Media Center				
8	401				
9	403				

SAMPLE TYPE CODES

BC - BioCassette™	ST - Spore Trap, Zelon, Allergenco, Rufford	T - Tape	D - Dust
AIS - Air-Sampler	P - Portable Water	SW - Swab	SD - Soil
SAS - Surface Air Sampler	NP - Non-Portable Water	G - Bulk	
CP - Contact Plate		O - Other	

REQUISITIONED BY

DATE & TIME

RECEIVED BY

DATE & TIME

By submitting this Chain of Custody, you agree to be bound by the terms and conditions set forth at <http://www.emlabpk.com/chainofcustodyterms.html>

Copyright © 2002-2013 EMLab P&K


Doc #155/Rev 2-2012/02/2013/02/2013/02/2013

REQUESTED SERVICES

001600832

Non-Culturable	Culturable	Other Requests
Spore Trap	BioCassette™, Andersen, SAS, Swab, Water, Bulk, Dust, Soil, Contact Plates	
Type		
Swab		
Risk		
Fungal - Spore Trap Analysis		
Spore Trap Analysis - Other particles		
Direct Microscopic Exam (Qualitative)		
Quantitative Spore Count Direct Exam		
1-Media Surface Fungi (Genus ID + Asp. spp.)		
2-Media Surface Fungi (Genus ID + Asp. spp.)		
3-Media Surface Fungi (Genus ID + Asp. spp.)		
Culturable Air Fungi (Genus ID + Asp. spp.)		
Gram Stain & Counts (Culturable Air & Surface Bacteria)		
Legionella culture		
Total Coliform, E. coli (Presence/Absence)		
Membrane Filtration (specify organism):		
MPN Bacteria (specify organism):		
Quantitray - Sewage Screen		
Asbestos Analysis - PCM Airborne Fiber Count (NIOSH 7480)		
Asbestos Analysis - PLM (EPA method 8000R-93-116)		
PCR (specify test):		

CHAIN OF CUSTODY



Weather	Fog	Rain	Snow	Wind	Cloud
None	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Light	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Medium	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heavy	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REQUESTED
(Use checkboxes below)

001600832

New Jersey: 3900 Lincoln Drive East, Suite A, Marlton, NJ 08053 • (609) 871-1984
Phoenix, AZ: 1551 West Knolls Drive, Phoenix, AZ 85027 • (602) 631-4602
San Bruno, CA: 1150 Bayhill Drive, #100, San Bruno, CA 94066 • (650) 888-6553

CONTACT INFORMATION

Company:	Labcity OTEMA (13549)	Address:	1211 E 39th St, Tulsa, OK 74105 USA
Contact:	Jack Kott	Special Instructions:	
Phone:	918-742-1367		

PROJECT INFORMATION

Project ID:	16-162	STD:	Standard
Project Description:	Billy Gail / Anderson 257	NO - Next Business Day	
Project Zip Code:		SD - Same Business Day Rush	
Project Number:		WH - Weekend / Holiday	
Sample ID:		Sample Type (Please)	TAT (approx)
		Sampled By:	Total Volume / Area (ie. approximately)
			Notes (Time of day, Temp, etc.)

TURN AROUND TIME CODES (TAT)

Rushes received after 2 pm or on weekends, will be completed received the next business day. Please alert us in advance of weekend analysis needs.

Sample ID	Description	Sample Type (Please)	TAT (approx)	Total Volume / Area (ie. approximately)	Notes (Time of day, Temp, etc.)
12	233	ST	STD	150L	
13	204				
14	216				
15	208				
16	Outside Reference Post				

SAMPLE TYPE CODES

BC - BioCassette™	ST - Spore Trap, Zefon	T - Tap	D - Dust
AIS - Anderson	Adaptor, Rusk	SW - Swab	SD - Soil
SAS - Surface Air Sampler	P - Portable Water	B - Bulk	
CP - Coriolis Phase	NP - Non-Portable Water	O - Other	

REINQUIRED BY

DATE & TIME

RECEIVED BY

DATE & TIME

By submitting this Chain of Custody, you agree to be bound by the terms and conditions set forth at <http://www.emlab.com/maintenance/terms.html>

Copyright © 2002-2013 EMLab P&K



001600832

LOC #1157 Nov 25, 2013 emlab.com Page 1 of 1 Q6