



# Liberty OHM

---

April 26, 2011

Mr. Marty Foutch  
Facilities Director  
Bixby Public Schools  
109 N. Armstrong  
Bixby, OK 74008

**Re: Bixby North Elementary IAQ – Kindergarten Hallway**

Dear Mr. Foutch,

On April 15 & 21, 2011, Liberty OHM visited Bixby North Elementary, located at 7701 E. 121<sup>st</sup> Street. The purpose of this visit was to perform a survey and sampling of the north Kindergarten Hallway, outside of classrooms 116-123, after being notified of a potential mold type odor in the area.

**FINDINGS**

Our initial inspection on April 15<sup>th</sup> showed elevated Penicillium/Aspergillus levels in the hallway, with visible mold behind the baseboard in Rm. 123 on the south wall. Surface sampling showed concentrations of Penicillium/Aspergillus and Stachybotrys.

Liberty OHM returned on April 21<sup>st</sup> to perform a more extensive inspection and sampling. Lab results show elevated levels of Penicillium/Aspergillus and Stachybotrys, with the highest levels in Rm. 116 and surface concentrations of Penicillium/Aspergillus on blue bookshelf in Rm. 118.

The following visual observations were noted:

**Rm. 116**

- Visible Mold (VM) and visible water damage under cabinet on the east wall
- VM on loose drywall in HVAC closet

**Rm. 123**

- VM behind baseboards on south wall

**Rm. 118**

- VM on baseboards around blue bookshelf

See Recommendations below.

## **RECOMMENDATIONS**

Based on our visual inspection and sampling data, we recommend the following:

**Occupancy of classrooms 116, 118, 121, and 123 is not recommended until remediation has been completed.**

Under negative pressure containment as described below, perform the following work in the following areas:

1. Isolate and contain hallway from classrooms 116 – 123 north to exit door.
2. Rm. 116 – Remove cabinet on east wall. RR east wall 2' beyond all VM and WD. Remove mold impacted loose drywall in HVAC closet.
3. Rm. 123 – RR south wall 2' in all directions beyond VM. (Approx. center of wall)
4. Rm. 118 – Clean and treat baseboards with antimicrobial around blue bookshelf.
5. RR Carpet in classrooms 116, 118, 121, and 123.
6. HEPA vacuum and moist wipe with antimicrobial all blue bookshelves in classrooms 116, 118, 121, and 123.
7. Following removal and before build back, HEPA vacuum, wipe, and clean with antimicrobial by appropriate method all walls, floors and other non-porous items in the remediated isolation zone. Remove/replace any wall fiberglass insulation associated with the abatement areas.
8. Following removal and before build back, scrub air in classrooms 116, 118, 121, and 123 and associated hallway with HEPA equipped air scrubbers for at least 72 hours, ensuring a minimum of 5 air exchanges per hour, then contact Liberty OHM to perform a final PRV or Post Remediation Verification survey and sampling prior to build-back.
9. Abatement of materials should continue an additional two (2) feet beyond any previously undetected mold or water damage discovered during remediation.

Recommendations are based in part on professional publication guidelines including the IICRC S500 Standard and Reference Guide for Professional Water Damage Restoration and IICRC S520 Standard and Reference Guide for Professional Mold Remediation. These publications are incorporated into the requirements of the abatement contractor selector to perform the work.

### Additional Protocols

All mold remediation work should be performed by a qualified mold remediation contractor utilizing appropriate personal protective equipment and under strict environmental controls. All work areas should be placed under negative pressure containment (i.e. 6 mil. Plastic sheeting and HEPA filtration) and exhausted to the outside, where applicable. All HVAC return air ducts, floor, and/or ceiling ducts should be sealed prior to any remediation work. All structural materials (i.e. wall studs, headers, window frames, etc) should be cleaned and treated with an antimicrobial such as Microban® or equivalent and properly dried. Once dry, all affected structural materials should be encapsulated with a primer/sealer, we recommend using Fosters 40/20® or equivalent.

See Tables 1 & 2 below for results from April 15, 2011.

See Tables 3 & 4 below for results from April 21, 2011

<b>Table 1</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway – IAQ</b> <b>April 15, 2011</b> <b>Spore Trap Analysis</b>					
<b>Location</b>	<b>Total spores/m 3</b>	<b>Species</b>	<b>Raw count</b>	<b>Calc. count</b>	<b>% of total</b>
1: Outside	1,500	Cladosporium Basidiospores <b>Penicillium/Aspergillus types</b> Ascospores Smuts, Periconia, Myxomycetes Alternaria Oidium	66 21 <b>9</b> 8 3 1 1	880 280 <b>120</b> 110 40 13 13	61 19 <b>8</b> 7 3 1 1
2: N. Kindergarten Hallway @ Rm. 123	2,200	Cladosporium <b>Penicillium/Aspergillus types</b> Basidiospores Smuts, Periconia, Myxomycetes Pithomyces Curvularia Alternaria Epicoccum Other brown Ascospores Bipolaris/Drechslera group	59 <b>58</b> 26 7 3 2 2 2 2 2 1	790 <b>770</b> 350 93 40 27 27 27 27 27 13	36 <b>35</b> 16 4 2 1 1 1 1 1 1 1

<b>Table 1</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway – IAQ</b> <b>April 15, 2011</b> <b>Spore Trap Analysis</b>					
Location	Total spores/m <sup>3</sup>	Species	Raw count	Calc. count	% of total
3: S. Kindergarten Hallway	2,600	Penicillium/Aspergillus types	75	1,000	38
		Cladosporium	73	970	37
		Basidiospores	24	320	12
		Smuts, Periconia, Myxomycetes	13	170	7
		Chaetomium	3	40	2
		Other brown	3	40	2
		Ascospores	3	40	2
		Alternaria	2	27	1
		Epicoccum	1	13	1

<b>Table 2</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway – Rm. 123</b> <b>April 15, 2011</b> <b>Quantitative Spore Count</b>		
Location:	4: S. Wall Rm. 123	
Comments (see below)	None	
Sample type	Tape sample	
Lab ID-Version:	3426729-1	
	raw ct.	spores/unit
Penicillium/Aspergillus types	50	50,000
Stachybotrys	350	350,000
Ulocladium	100	100,000
Background debris (1-4+)	4+	
Sample size	1	
Unit	1 cm <sup>2</sup>	
§ TOTAL SPORES/UNIT		500,000

<b>Table 3</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway Retest – IAQ</b> <b>April 21, 2011</b> <b>Spore Trap Analysis</b>					
<b>Location</b>	<b>Total spores/m 3</b>	<b>Species</b>	<b>Raw count</b>	<b>Calc. count</b>	<b>% of total</b>
1: Outside - Pre IAQ	2,600	Ascospores	79	1,100	40
		Cladosporium	54	720	27
		Basidiospores	34	450	17
		Smuts, Periconia, Myxomycetes	12	160	6
		<b>Penicillium/Aspergillus types</b>	<b>7</b>	<b>93</b>	<b>4</b>
		Alternaria	4	53	2
		Other brown	4	53	2
		Bipolaris/Drechslera group	2	27	1
		Oidium	2	27	1
2: Hallway @ Rm. 123	4,200	<b>Penicillium/Aspergillus types</b>	<b>272</b>	<b>3,600</b>	<b>86</b>
		Cladosporium	26	350	8
		Alternaria	8	110	3
		Basidiospores	4	53	1
		Ascospores	4	53	1
		Curvularia	2	27	1
		Epicoccum	1	13	< 1
		Bipolaris/Drechslera group	1	13	< 1
3: Hallway @ Rm. 119	3,600	<b>Penicillium/Aspergillus types</b>	<b>211</b>	<b>2,800</b>	<b>79</b>
		Cladosporium	33	440	12
		Ascospores	9	120	3
		Basidiospores	8	110	3
		Smuts, Periconia, Myxomycetes	3	40	1
		Alternaria	2	27	1
		Epicoccum	1	13	< 1
4: Rm. 119	320	<b>Penicillium/Aspergillus types</b>	<b>11</b>	<b>150</b>	<b>46</b>
		Cladosporium	7	93	29
		Alternaria	2	27	8
		Basidiospores	2	27	8
		Smuts, Periconia, Myxomycetes	1	13	4
		Bipolaris/Drechslera group	1	13	4

<b>Table 3</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway Retest – IAQ</b> <b>April 21, 2011</b> <b>Spore Trap Analysis</b>					
Location	Total spores/m <sup>3</sup>	Species	Raw count	Calc. count	% of total
5: Rm. 116	37,000	Penicillium/Aspergillus types	67	36,000	96
		Cladosporium	63	840	2
		Basidiospores	13	170	< 1
		Smuts, Periconia, Myxomycetes	12	160	< 1
		Alternaria	10	130	< 1
		Other brown	10	130	< 1
		Ascospores	5	67	< 1
		Curvularia	4	53	< 1
		Bipolaris/Drechslera group	3	40	< 1
		Epicoccum	2	27	< 1
		Stachybotrys	2	27	< 1
		Pithomyces	1	13	< 1
6: Rm. 123	4,100	Penicillium/Aspergillus types	250	3,300	80
		Cladosporium	26	350	8
		Basidiospores	10	130	3
		Ascospores	7	93	2
		Smuts, Periconia, Myxomycetes	5	67	2
		Alternaria	4	53	1
		Other brown	4	53	1
		Bipolaris/Drechslera group	3	40	1
		Stachybotrys	2	27	1
7: Outside - Post IAQ	2,300	Ascospores	90	1,200	53
		Basidiospores	33	440	20
		Cladosporium	26	350	15
		Penicillium/Aspergillus types	12	160	7
		Smuts, Periconia, Myxomycetes	4	53	2
		Epicoccum	2	27	1
		Other brown	2	27	1

<b>Table 4</b> <b>Bixby North Elementary</b> <b>Kindergarten Hallway Retest – Rm. 118</b> <b>April 21, 2011</b> <b>Quantitative Spore Count</b>		
Location:	8: Rm. 118-Book Shelf	
Comments (see below)	A	
Sample type	Swab sample	
Lab ID-Version:	3435779-1	
	raw ct.	spores/unit
Alternaria		
Arthrinium		
Basidiospores		
Bipolaris/Drechslera group		
Botrytis		
Chaetomium		
Cladosporium		
Curvularia		
Epicoccum		
Myrothecium		
Nigrospora		
Penicillium/Aspergillus types	82	2,600,000
Pithomyces		
Rusts		
Stachybotrys		
Stemphylium		
Torula		
Ulocladium		
Zygomycetes		
Background debris (1-4+)	1+	
Sample size	1	
Unit	1 cm2	
§ TOTAL SPORES/UNIT		2,600,000

\*\*\*\*\*

### **Disclaimer**

This report reflects conditions discovered at the time of the survey. In many instances, mold amplification may continue following our inspection and prior to any abatement work. Therefore, additional areas of water/mold damage not mentioned above may be found during the remediation efforts (discovery). There may also be areas impacted that could not be directly inspected during Liberty OHM's survey without performing exploratory destructive testing. If any other areas of water/mold damage are found during the remediation please contact our office so that we can perform additional inspections and scope of work. In general, abatement of materials should continue an additional two (2) feet beyond any previously undetected mold or water damage discovered during remediation.

Liberty OHM makes no assertion as to the health risks associated with the levels reported in this report. We make no correlation that the levels reported are safe for occupancy or do not pose a risk from exposure. We advise you, our client to consult with an Occupational Health or other qualified physician for additional information and guidance.

If you have questions or need additional information, please let me know.

Sincerely,



Rob Thompson, CIH, CSP  
President - Liberty OHM

