

## Water Testing Results - Sherman County School

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
High Drinking Fountain Grade School	X041414 #1	5/14/2020	0.201
Library Program Room Kitchen	X041414 #2	5/14/2020	0.726
Library Drinking Fountain	X041414 #3	5/14/2020	0.976
Bottle Filler by Office	X041414 #4	5/14/2020	ND
Rm 17 Drinking Fountain	X041414 #5	5/14/2020	0.117
Room 17 Faucet	X041414 #6	5/14/2020	ND
Grade School Room 20 Drinking Fountain	X041414 #7	5/14/2020	0.116
Preschool Upper Faucet	X041414 #8	5/14/2020	0.134
Middle Sink Home Ec Room	X041414 #9	5/14/2020	0.495
Grade School Room 20 Faucet	X041414 #10	5/14/2020	ND
Grade School Gym Low Drinkin Fountain	X041414 #11	5/14/2020	0.206
Bottle Filler Grade School	X041414 #12	5/14/2020	ND
Triple Sink Left Faucet	X041414 #13	5/14/2020	0.358
Grade School Room 18 Faucet	X041414 #14	5/14/2020	0.256
Drinking Fountain Room 16	X041414 #15	5/14/2020	0.104
Grade School Room 19 Faucet	X041414 #16	5/14/2020	ND
Triple Sink Right N Home Room	X041414 #17	5/14/2020	0.272
Faucet Room 16	X041414 #18	5/14/2020	ND
Cafeteria Bottle Filler	X041414 #19	5/14/2020	0.146
High School Locker Hall DF	X041414 #20	5/14/2020	ND
Grade School Room 18 Drinking Fountain	X041414 #21	5/14/2020	0.319
Grade School Gym Bottle Filler	X041414 #22	5/14/2020	0.165
Teacher Work Room Grade School	X041414 #23	5/14/2020	0.134
Gym Lobby Drinking Fountain	X041414 #24	5/14/2020	ND
Senior High Hall Bottle Filler	X041414 #25	5/14/2020	ND
Senior High Hall Drinking Fountain	X041414 #26	5/14/2020	ND
Low Drinking Fountain Grade School	X041414 #27	5/14/2020	ND
Faucet Room 13	X041414 #28	5/14/2020	ND
Grade School Drinking Fountain Room 19	X041414 #29	5/14/2020	0.114
Cafeteria Tall Drinking Fountain	X041414 #30	5/14/2020	ND
Grade School #15 Faucet	X041414 #31	5/14/2020	0.11
Preschool Drinking Fountain	X041414 #32	5/14/2020	0.165
Grade School Room 15 Drinking Fountain	X041414 #33	5/14/2020	ND
Grade School Gym High Drinking Fountain	X041414 #34	5/14/2020	0.174
Cafeteria Low Drinking Fountain	X041414 #35	5/14/2020	0.103
Grade School Room 21 Faucet	X041414 #36	5/14/2020	0.118
Grade School Drinking Fountain Room 21	X041414 #37	5/14/2020	0.141
Kitchen L Sink by Dishwasher	X041414 #38	5/14/2020	0.717
Preschool Lower Faucet	X041414 #39	5/14/2020	ND
Drinking Fountain Room 13	X041414 #40	5/14/2020	0.733
Jr. High Bottle Filler	X041414 #41	5/14/2020	0.256
Kitchen Dump Kettle	X041414 #42	5/14/2020	0.144
Jr. High Fountain	X041414 #43	5/14/2020	ND
Prep Sink South	X041414 #44	5/14/2020	0.418
Prep Sink North	X041414 #45	5/14/2020	0.358

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			
N/A			

ND = Non Detect - Lead level is below the set detection limits of .103 ppb



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-3678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

### Sample Information:

Lab ID: 20050540-01 Client Sample ID: X041414 #1  
Collection Date: 5/6/2020 8:00:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: High Drinking Fountain Grade School

#### Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.201		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-02 Client Sample ID: X041414 #2  
Collection Date: 5/6/2020 7:54:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Library Program Room Kitchen

#### Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.726		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-03 Client Sample ID: X041414 #3  
Collection Date: 5/6/2020 7:53:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Library Drinking Fountain

#### Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.976		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcode  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

### Sample Information:

Lab ID: 20050540-04 Client Sample ID: X041414 #4  
Collection Date: 5/6/2020 7:50:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Bottle Filler by Office

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-05 Client Sample ID: X041414 #5  
Collection Date: 5/6/2020 8:11:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Rm 17 Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.117		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-06 Client Sample ID: X041414 #6  
Collection Date: 5/6/2020 8:12:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Rm 17 Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at test code  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-07 Client Sample ID: X041414 #7  
Collection Date: 5/6/2020 8:46:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Grade School Rm 20 DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.116		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-08 Client Sample ID: X041414 #8  
Collection Date: 5/6/2020 8:16:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Preschool Upper Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.134		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-09 Client Sample ID: X041414 #9  
Collection Date: 5/6/2020 9:07:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Middle Sink Home Ec Room

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.495		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
F Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

CI Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-3678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-10 Client Sample ID: X041414 #10  
Collection Date: 5/6/2020 8:47:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Grade School Rm 20 Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-11 Client Sample ID: X041414 #11  
Collection Date: 5/6/2020 8:04:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Grade School Gym Low DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.206		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-12 Client Sample ID: X041414 #12  
Collection Date: 5/6/2020 8:01:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Bottle Filler Grade School

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

QUALIFIERS

\* Value exceeds Maximum Contaminant Level.  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

CI Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

### Sample Information:

Lab ID: 20050540-13 Client Sample ID: X041414 #13  
Collection Date: 5/6/2020 9:08:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Triple Sink Left Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.358		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-14 Client Sample ID: X041414 #14  
Collection Date: 5/6/2020 8:36:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Grade School Rm 18 Faucet

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.256		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-15 Client Sample ID: X041414 #15  
Collection Date: 5/6/2020 8:19:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Drinking Fountain Rm 16

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.104		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level.  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

# **Analytical Report**

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

**Lab Order:** 20050540  
**Received Date:** 5/14/2020 10:15:00 AM  
**Reported Date:** 5/22/2020 2:06:40 PM

Sample Information:

**Lab ID:** 20050540-16 **Client Sample ID:** X041414 #16  
**Collection Date:** 5/6/2020 8:41:00 AM **Collected By:** Dean Dark  
**Matrix:** Drinking Water **Sample Location:** Grade School Rm 19 Faucet

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-17 **Client Sample ID:** X041414 #17  
**Collection Date:** 5/6/2020 9:11:00 AM **Collected By:** Dean Dark  
**Matrix:** Drinking Water **Sample Location:** Triple Sink Right N Home Room

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.272		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-18 **Client Sample ID:** X041414 #18  
**Collection Date:** 5/6/2020 8:20:00 AM **Collected By:** Dean Dark  
**Matrix:** Drinking Water **Sample Location:** Faucet Room 16

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

**QUALIFIERS**

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Netlson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-19 Client Sample ID: X041414 #19  
Collection Date: 5/6/2020 9:18:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Cafeteria Bottle Filler

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.146		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-20 Client Sample ID: X041414 #20  
Collection Date: 5/6/2020 8:52:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: High School Locker Hall DF

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-21 Client Sample ID: X041414 #21  
Collection Date: 5/6/2020 8:35:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Grade School Rm 18 DF

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.319		0.103	µg/L	1	5/15/2020	15.0	A

QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-3678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-22 Client Sample ID: X041414 #22  
Collection Date: 5/6/2020 8:06:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School Gym Bottle Filler

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.165		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-23 Client Sample ID: X041414 #23  
Collection Date: 5/6/2020 7:55:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Teacher Work Rm Grade School

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.134		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-24 Client Sample ID: X041414 #24  
Collection Date: 5/6/2020 8:55:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Gym Lobby Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

CI Sample container temperature is out of limit as specified at testood  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PI Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrelabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-25 Client Sample ID: X041414 #25  
Collection Date: 5/6/2020 9:03:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Sr High Hall Bottle Filler

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-26 Client Sample ID: X041414 #26  
Collection Date: 5/6/2020 9:02:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Sr High Hall Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-27 Client Sample ID: X041414 #27  
Collection Date: 5/6/2020 8:00:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Low Drinking Fountain Grade School

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

### Sample Information:

Lab ID: 20050540-28 Client Sample ID: X041414 #28  
Collection Date: 5/6/2020 8:33:00 AM Collected By: Dean Dark  
Matrix: Drinking Water Sample Location: Faucet Rm 13

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-29 Client Sample ID: X041414 #29  
Collection Date: 5/6/2020 8:40:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School Drinking Fountain Rm 19

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.114		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-30 Client Sample ID: X041414 #30  
Collection Date: 5/6/2020 9:17:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Cafeteria Tall Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

CI Sample container temperature is out of limit as specified at test code  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-31 Client Sample ID: X041414 #31  
Collection Date: 5/6/2020 8:29:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School #15 Faucet

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.110		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-32 Client Sample ID: X041414 #32  
Collection Date: 5/6/2020 8:15:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Preschool Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.165		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-33 Client Sample ID: X041414 #33  
Collection Date: 5/6/2020 8:28:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School Rm 15 Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level.  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540  
Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 20050540  
Received Date: 5/14/2020 10:15:00 AM  
Reported Date: 5/22/2020 2:06:40 PM

Sample Information:

Lab ID: 20050540-34 Client Sample ID: X041414 #34  
Collection Date: 5/6/2020 8:05:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School Gym High DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.174		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-35 Client Sample ID: X041414 #35  
Collection Date: 5/6/2020 9:15:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Cafeteria Low Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.103		0.103	µg/L	1	5/15/2020	15.0	A

Lab ID: 20050540-36 Client Sample ID: X041414 #36  
Collection Date: 5/6/2020 8:45:00 AM Collected By: Craig Wood  
Matrix: Drinking Water Sample Location: Grade School Rm 21 Faucet

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.118		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcode  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: **20050540**

Date Reported: **5/22/2020**

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

**Lab Order:** 20050540  
**Received Date:** 5/14/2020 10:15:00 AM  
**Reported Date:** 5/22/2020 2:06:40 PM

Sample Information:

**Lab ID:** 20050540-37 **Client Sample ID:** X041414 #37  
**Collection Date:** 5/6/2020 8:44:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Grade School Drinking Fountain Rm 21

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.141		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-38 **Client Sample ID:** X041414 #38  
**Collection Date:** 5/7/2020 8:05:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Kitchen L Sink by Dishwasher

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.717		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-39 **Client Sample ID:** X041414 #39  
**Collection Date:** 5/6/2020 8:15:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Preschool Lower Faucet

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

CI Sample container temperature is out of limit as specified at testord  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20050540

Date Reported: 5/22/2020

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

**Lab Order:** 20050540  
**Received Date:** 5/14/2020 10:15:00 AM  
**Reported Date:** 5/22/2020 2:06:40 PM

Sample Information:

**Lab ID:** 20050540-40 **Client Sample ID:** X041414 #40  
**Collection Date:** 5/6/2020 8:32:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Drinking Fountain Rm 13

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.733		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-41 **Client Sample ID:** X041414 #41  
**Collection Date:** 5/7/2020 9:45:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Jr High Bottle Filler

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.256		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-42 **Client Sample ID:** X041414 #42  
**Collection Date:** 5/7/2020 9:45:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Kitchen Dump Kettle

Trace Metals by EPA 200.8 ICP-MS

Analyst: SJS

Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.144		0.103	µg/L	1	5/15/2020	15.0	A

### QUALIFIERS

\* Value exceeds Maximum Contaminant Level.  
E Value above quantitation range  
J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit  
R RPD outside accepted recovery limits

C1 Sample container temperature is out of limit as specified at testcod  
H Holding times for preparation or analysis exceeded  
MI Recovery outside control limits due to Matrix Interference  
PL Permit Limit

Original



**NEILSON  
RESEARCH  
CORPORATION**

Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: **20050540**

Date Reported: **5/22/2020**

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

**Lab Order:** 20050540  
**Received Date:** 5/14/2020 10:15:00 AM  
**Reported Date:** 5/22/2020 2:06:40 PM

Sample Information:

**Lab ID:** 20050540-43 **Client Sample ID:** X041414 #43  
**Collection Date:** 5/7/2020 9:45:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Jr High Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-44 **Client Sample ID:** X041414 #44  
**Collection Date:** 5/7/2020 9:45:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Prep Sink South

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.418		0.103	µg/L	1	5/15/2020	15.0	A

**Lab ID:** 20050540-45 **Client Sample ID:** X041414 #45  
**Collection Date:** 5/7/2020 9:45:00 AM **Collected By:** Craig Wood  
**Matrix:** Drinking Water **Sample Location:** Prep Sink North

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.358		0.103	µg/L	1	5/15/2020	15.0	A

**QUALIFIERS**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- ND Not Detected at the Reporting Limit
- R RPD outside accepted recovery limits

- CI Sample container temperature is out of limit as specified at testcod
- H Holding times for preparation or analysis exceeded
- MI Recovery outside control limits due to Matrix Interference
- PL Permit Limit

Original