



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Higginbotham**  
**Collingswood Board of Education**  
**424 Collings Ave.**  
**Collingswood, NJ 08108**

1/10/2022

Phone: (856) 962-5730  
Fax: (856) 962-9355

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/23/2021. The results are tabulated on the attached data pages for the following client designated project:

**Garfield School**

The reference number for these samples is EMSL Order #012200069. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012200069

CustomerID: COLL50A

CustomerPO:

ProjectID:

Attn: **Keith Higginbotham**  
**Collingswood Board of Education**  
**424 Collings Ave.**  
**Collingswood, NJ 08108**

Phone: (856) 962-5730  
 Fax: (856) 962-9355  
 Received: 12/23/2021 01:55 PM

Project: **Garfield School****Analytical Results**

**Client Sample Description** Garfield 1 **Collected:** 12/23/2021 6:18:00 AM **Lab ID:** 012200069-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.33	1.00 µg/L	1/6/2022 KB	1/7/2022 04:36 KB

**Client Sample Description** Garfield 2 **Collected:** 12/23/2021 6:21:00 AM **Lab ID:** 012200069-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.37	1.00 µg/L	1/6/2022 KB	1/7/2022 11:51 KB

**Client Sample Description** Garfield 3 **Collected:** 12/23/2021 6:25:00 AM **Lab ID:** 012200069-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.23	1.00 µg/L	1/6/2022 KB	1/7/2022 15:21 JW

**Client Sample Description** Garfield 4A Bottle Filler **Collected:** 12/23/2021 6:26:00 AM **Lab ID:** 012200069-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	1/6/2022 KB	1/7/2022 11:53 KB

**Client Sample Description** Garfield 4B Drinking Outlet **Collected:** 12/23/2021 6:26:00 AM **Lab ID:** 012200069-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	1/6/2022 KB	1/7/2022 11:54 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012200069

CustomerID: COLL50A

CustomerPO:

ProjectID:

Attn: **Keith Higginbotham**  
**Collingswood Board of Education**  
**424 Collings Ave.**  
**Collingswood, NJ 08108**

Phone: (856) 962-5730  
Fax: (856) 962-9355  
Received: 12/23/2021 01:55 PM

Project: **Garfield School****Analytical Results**

**Client Sample Description** Garfield 5A  
Bottle Filler  
**Collected:** 12/23/2021 6:28:00 AM  
**Lab ID:** 012200069-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	1/6/2022 KB	1/7/2022 11:56 KB

**Client Sample Description** Garfield 5B  
Drinking Outlet  
**Collected:** 12/23/2021 6:28:00 AM  
**Lab ID:** 012200069-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	1/6/2022 KB	1/7/2022 11:57 KB

**Client Sample Description** Garfield 6  
**Collected:** 12/23/2021 6:29:00 AM  
**Lab ID:** 012200069-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	59.4	1.00 µg/L	1/6/2022 KB	1/7/2022 12:03 KB

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

