



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

August 25, 2017

Mark Wertz
Central School District 51
1301 Eagle Ave.
Washington, IL 61571

Dear Mark Wertz:

Please find enclosed the analytical results for the sample(s) the laboratory received on **8/7/17 10:20 am** and logged in under work order **7081354**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7081354-01
Name: Kitchen Sink-Serving-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.65	ug/L		08/23/17 11:34	08/24/17 13:50	WJM	EPA 200.8

Sample: 7081354-02
Name: Kitchen Sink-Serving-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 13:51	WJM	EPA 200.8

Sample: 7081354-03
Name: Kitchen Sink-Triple-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.58	ug/L		08/23/17 11:34	08/24/17 13:52	WJM	EPA 200.8

Sample: 7081354-04
Name: Kitchen Sink-Triple-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.08	ug/L		08/23/17 11:34	08/24/17 13:53	WJM	EPA 200.8

Sample: 7081354-05
Name: Kitchen Kettle-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	37.1	ug/L		08/23/17 11:34	08/24/17 13:57	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-06
Name: Kitchen Kettle-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	23.9	ug/L		08/23/17 11:34	08/24/17 13:58	WJM	EPA 200.8

Sample: 7081354-07
Name: Kitchen Sink-Freezers-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.16	ug/L		08/23/17 11:34	08/24/17 14:03	WJM	EPA 200.8

Sample: 7081354-08
Name: Kitchen Sink-Freezers-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 05:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:05	WJM	EPA 200.8

Sample: 7081354-09
Name: Water Fountain-Cafe-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:06	WJM	EPA 200.8

Sample: 7081354-10
Name: Water Fountain-Cafe-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:07	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-11
Name: Water Fountain-Cafe HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:08	WJM	EPA 200.8

Sample: 7081354-12
Name: Water Fountain-Cafe HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:09	WJM	EPA 200.8

Sample: 7081354-13
Name: Water Fountain-Cafe Hall-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:13	WJM	EPA 200.8

Sample: 7081354-14
Name: Water Fountain-Cafe Hall-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:14	WJM	EPA 200.8

Sample: 7081354-15
Name: Water Fountain-Cafe Hall HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:10
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:20	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-16
Name: Water Fountain-Cafe Hall HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:10
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:21	WJM	EPA 200.8

Sample: 7081354-17
Name: Teachers Lounge Sink RM13-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.92	ug/L		08/23/17 11:34	08/24/17 14:22	WJM	EPA 200.8

Sample: 7081354-18
Name: Teachers Lounge Sink RM13-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:23	WJM	EPA 200.8

Sample: 7081354-19
Name: Water Fountain 5th Grade Hall-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.60	ug/L		08/23/17 11:34	08/24/17 14:24	WJM	EPA 200.8

Sample: 7081354-20
Name: Water Fountain 5th Grade Hall-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:25	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-21
Name: Water Fountain 5th Grade Hall HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.72	ug/L		08/23/17 11:34	08/24/17 14:29	WJM	EPA 200.8

Sample: 7081354-22
Name: Water Fountain 5th Grade Hall HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.01	ug/L		08/23/17 11:34	08/24/17 14:30	WJM	EPA 200.8

Sample: 7081354-23
Name: Water Fountain 501-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:35	WJM	EPA 200.8

Sample: 7081354-24
Name: Water Fountain 501-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.85	ug/L		08/23/17 11:34	08/24/17 14:36	WJM	EPA 200.8

Sample: 7081354-25
Name: Water Fountain 501HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:37	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-26
Name: Water Fountain 501HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:39	WJM	EPA 200.8

Sample: 7081354-27
Name: Water Fountain 8th Grade Hall Boys RR-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:40	WJM	EPA 200.8

Sample: 7081354-28
Name: Water Fountain 8th Grade Hall Boys RR-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:41	WJM	EPA 200.8

Sample: 7081354-29
Name: Water Fountain 8th Grade Hall Boys RR HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:45	WJM	EPA 200.8

Sample: 7081354-30
Name: Water Fountain 8th Grade Hall Boys RR HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:46	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-31
Name: Water Fountain 8th Grade Hall Girls RR-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 00:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:51	WJM	EPA 200.8

Sample: 7081354-32
Name: Water Fountain 8th Grade Hall Girls RR-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 00:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:52	WJM	EPA 200.8

Sample: 7081354-33
Name: Water Fountain 8th Grade Hall Girls RR HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 00:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:53	WJM	EPA 200.8

Sample: 7081354-34
Name: Water Fountain 8th Grade Hall Girls RR HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 00:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:54	WJM	EPA 200.8

Sample: 7081354-35
Name: Teachers Lounge 415 Sink-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:55	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-36
Name: Teachers Lounge 415 Sink-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:30
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 14:57	WJM	EPA 200.8

Sample: 7081354-37
Name: Water Fountain Computer Lab-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:00	WJM	EPA 200.8

Sample: 7081354-38
Name: Water Fountain Computer Lab-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:16	WJM	EPA 200.8

Sample: 7081354-39
Name: Water Fountain Computer Lab HC-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:18	WJM	EPA 200.8

Sample: 7081354-40
Name: Water Fountain Computer Lab HC-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:19	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-41
Name: Water Fountain Holford Foyer-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:20	WJM	EPA 200.8

Sample: 7081354-42
Name: Water Fountain Holford Foyer-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:21	WJM	EPA 200.8

Sample: 7081354-43
Name: Filling Station Holford-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:22	WJM	EPA 200.8

Sample: 7081354-44
Name: Filling Station Holford-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 06:45
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 15:23	WJM	EPA 200.8

Sample: 7081354-45
Name: Water Fountain Gym Girls LR-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 10:19	WJM	EPA 200.8



ANALYTICAL RESULTS

Sample: 7081354-46
Name: Water Fountain Gym Girls LR-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.24	ug/L		08/23/17 11:34	08/24/17 10:20	WJM	EPA 200.8

Sample: 7081354-47
Name: Water Fountain Gym Boys LR-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 10:21	WJM	EPA 200.8

Sample: 7081354-48
Name: Water Fountain Gym Boys LR-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:00
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		08/23/17 11:34	08/24/17 10:22	WJM	EPA 200.8

Sample: 7081354-49
Name: Drinking Station 5th Hall-1
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	30.4	ug/L		08/23/17 11:34	08/24/17 10:23	WJM	EPA 200.8

Sample: 7081354-50
Name: Drinking Station 5th Hall-2
Matrix: Drinking Water - Regular Sample

Sampled: 07/31/17 07:15
Received: 08/07/17 10:20

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	10.7	ug/L		08/23/17 11:34	08/24/17 10:25	WJM	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager




PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6551 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Central School Dist S1		P.O. NUMBER	SCHOOL NAME	MEANS SHIPPED	3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)			
ADDRESS 1301 Eagle Ave		PHONE NUMBER 444-3943	EMAIL	DATE SHIPPED	LEAD 200.8				LOGIN #			
CITY STATE ZIP Washington, IL 61571		SAMPLER (PLEASE PRINT) Mark Wertz		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE					LAB PROJ. #		TEMPLATE:	
CONTACT PERSON Mark Wertz		SAMPLER'S SIGNATURE <i>Mark Wertz</i>		OTHER: MATRIX TYPE					BOTTLE COUNT		PROJ. MGR: KURT STEPPING	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE/TIME LAST USED					
wf 5th grade Hall		7-31	6:15	ml	DW	1	X	Friday 7-28				
" " " "		7-31	6:15	ml	DW	1	X					
wf 5th grade Hall HC		7-31	6:15	ml	DW	1	X					
" " " "		7-31	6:15	ml	DW	1	X					
wf 501		7-31	6:15	ml	DW	1	X					
" " "		7-31	6:15	ml	DW	1	X					
wf 501 HC		7-31	6:15	ml	DW	1	X					
" " "		7-31	6:15	ml	DW	1	X					
				ml	DW	1	X					
				ml	DW	1	X					
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		5 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.								
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:								
7 RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE	8 COMMENTS: (FOR LAB USE ONLY)							
		TIME		TIME	SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE								
		TIME		TIME								
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE								
		TIME		TIME								

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Central School Dist 51		P.O. NUMBER SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)	
ADDRESS 1301 Eagle Ave		PHONE NUMBER 444-3943		EMAIL		DATE SHIPPED		LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR: KURT STEPPING			
CITY STATE ZIP Washington, IL 6157		SAMPLER (PLEASE PRINT) Mark Wertz		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER DW- DRINKING WATER WWSL- SLUDGE NAS- SOLID LCH- LEACHATE		LEAD 200.8		DATE/TIME LAST USED Friday 7-28			
CONTACT PERSON Mark Wertz		SAMPLER'S SIGNATURE 		OTHER:							
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT					
Wf 8th grade Hall Boys RR		7-31	6:30	ml	DW	1	X				
" " " " " "		7-31	6:30	ml	DW	1	X				
Wf 8th grade hall Boys RR Hc		7-31	6:30	ml	DW	1	X				
" " " " " "		7-31	6:30	ml	DW	1	X				
Wf 8th grade Hall Girls RR				ml	DW	1	X				
" " " " " "				ml	DW	1	X				
Wf 8th grade hall Girls RR Hc				ml	DW	1	X				
" " " " " "				ml	DW	1	X				
Teachers lounge 415 Sink		7-31	6:30	ml	DW	1	X				
" " " "		7:31	6:30	ml	DW	1	X				
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH <small>(RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)</small>		RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-8.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.					
7 RELINQUISHED BY: (SIGNATURE)		DATE TIME	RECEIVED BY: (SIGNATURE)			DATE TIME	8 COMMENTS: (FOR LAB USE ONLY)				
RELINQUISHED BY: (SIGNATURE)		DATE TIME	RECEIVED BY: (SIGNATURE)			DATE TIME	SAMPLE TEMPERATURE UPON RECEIPT 18°C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) <small>(EXCLUDES TYPICAL FIELD PARAMETERS)</small> DATE AND TIME TAKEN FROM SAMPLE BOTTLE				
RELINQUISHED BY: (SIGNATURE)		DATE TIME	RECEIVED BY: (SIGNATURE)			DATE TIME	Y OR N Y OR N Y OR N Y OR N				

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-8551 FAX: (309) 692-8558

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Central School Dist 51		P.O. NUMBER	SCHOOL NAME	MEANS SHIPPED	3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY)																																																																																																							
ADDRESS 1301 Eagle Ave		PHONE NUMBER 444-3943	EMAIL	DATE SHIPPED	LEAD 200.8				LOGIN #																																																																																																							
CITY STATE ZIP Washington, IL 61571		SAMPLER (PLEASE PRINT) Mark Wertz		MATRIX TYPES: WW-WASTEWATER DW-DISBURG WATER GW-GROUND WATER WWSL-SLUDGE RAS-SOLID LCHT-LEACHATE					LOGGED BY:		LAB PROJ.#																																																																																																					
CONTACT PERSON Mark Wertz		SAMPLER'S SIGNATURE <i>[Signature]</i>		OTHER:	<table border="1"> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>																																																																																																								TEMPLATE:		PROJ. MGR: KURT STEPPING	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE/TIME LAST USED																																																																																																									
wf Computer Lab		7/31	6:45	ml	DW	1	Friday 7-28																																																																																																									
" " "		7/31	6:45	ml	DW	1																																																																																																										
wf Computer Lab itc		7/31	6:45	ml	DW	1																																																																																																										
" " " "		7/31	6:45	ml	DW	1																																																																																																										
wf Holford foyer		7/31	6:45	ml	DW	1																																																																																																										
" " " "		7/31	6:45	ml	DW	1																																																																																																										
Filling Station Holford		7/31	6:45	ml	DW	1																																																																																																										
" " " "		7/31	6:45	ml	DW	1																																																																																																										
wf gym girls LR		7/31	7:00	ml	DW	1																																																																																																										
" " " "		7/31	7:00	ml	DW	1																																																																																																										
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.																																																																																																												
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:																																																																																																												
7 RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE	8 COMMENTS: (FOR LAB USE ONLY)																																																																																																											
		TIME		TIME	SAMPLE TEMPERATURE UPON RECEIPT 15°C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE																																																																																																											
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE																																																																																																												
		TIME		TIME																																																																																																												
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE																																																																																																												
		TIME		TIME																																																																																																												
		DATE		DATE																																																																																																												
		TIME		TIME																																																																																																												

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Central School Dist 51		P.O. NUMBER	SCHOOL NAME	MEANS SHIPPED	3 ANALYSIS REQUESTED			4 (FOR LAB USE ONLY)			
ADDRESS 1301 Eagle Ave		PHONE NUMBER 444-3943	EMAIL	DATE SHIPPED	LEAD 200.8			LOGIN # _____			
CITY STATE ZIP Washington IL 61571		SAMPLER (PLEASE PRINT) Mark Wertz		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE RAS- SOLID LCL- LEACHATE				LOGGED BY: _____		LAB PROJ. # _____	
CONTACT PERSON Mark Wertz		SAMPLER'S SIGNATURE <i>Mark Wertz</i>		OTHER: MATRIX TYPE				TEMPLATE: _____		PROJ. MGR: KURT STEPPING	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	DATE/TIME LAST USED				
wf gym Boys LR		7/31	7:00	ml	DW	1	Friday 7-28				
ll " " " "		7/31	7:00	ml	DW	1					
Drinking Station Sth Hall		7/31	7:15	ml	DW	1					
D-Drinking Station Sth Hall		7/31	7:15	ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
				ml	DW	1					
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-4.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.							
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		FAX # IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:							
7 RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE	8 COMMENTS: (FOR LAB USE ONLY)						
		TIME		TIME							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE	SAMPLE TEMPERATURE UPON RECEIPT 18 °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N PROPER BOTTLES RECEIVED IN GOOD CONDITION Y OR N BOTTLES FILLED WITH ADEQUATE VOLUME Y OR N SAMPLES RECEIVED WITHIN HOLD TIME(S) Y OR N (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE						
		TIME		TIME							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)	DATE							
		TIME		TIME							