



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 12/03/2021  
**CLIENT NAME:** Bath Middle School  
**CLIENT ADDRESS:** 6 Old Brunswick Road  
 Bath, ME 04530  
**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

Legend	
Lead Above 4 ppb	⚠
Lead Above 15 ppb	⊗

**DATE AND TIME RECEIVED:** 11/29/2021 09:35AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 21° CELSIUS  
**CLIENT JOB #:** 59

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2111-03724-001	DWF 300 wing	I	DWF	11/24/2021 07:34AM	31.2	ppb	⊗		JLR-NH	11/30/2021 03:17PM
2111-03724-002	Water Fountain/bottle fill station	I	DWF	11/24/2021 07:37AM	<1	ppb			JLR-NH	11/30/2021 03:21PM
2111-03724-003	DWF 100 wing by Rm 111	I	DWF	11/24/2021 07:40AM	20.4	ppb	⊗		JLR-NH	11/30/2021 03:32PM
2111-03724-004	Sink 100 wing staff rm	I	OT	11/24/2021 07:45AM	33.5	ppb	⊗		JLR-NH	11/30/2021 03:35PM
2111-03724-005	DWF 100 wing by Rm 106	I	DWF	11/24/2021 08:00AM	17.2	ppb	⊗		JLR-NH	11/30/2021 03:39PM
2111-03724-006	Sink Rm 101	I	OT	11/24/2021 08:10AM	2.1	ppb			JLR-NH	11/30/2021 03:43PM
2111-03724-007	Sink Clinic 603A	I	DWF	11/24/2021 08:13AM	2.5	ppb			JLR-NH	11/30/2021 03:53PM
2111-03724-008	Sink Clinic 603B	I	DWF	11/24/2021 08:14AM	3.2	ppb			JLR-NH	11/30/2021 03:57PM
2111-03724-009	Prep sink Kitchen	I	KF	11/24/2021 08:17AM	7.1	ppb	⚠		JLR-NH	11/30/2021 04:01PM
2111-03724-010	DWF outside of cafe	I	DWF	11/24/2021 08:19AM	3.4	ppb			JLR-NH	11/30/2021 04:04PM
2111-03724-011	Sink concession stand	I	OT	11/24/2021 08:20AM	5.7	ppb	⚠		JLR-NH	11/30/2021 04:19PM
2111-03724-012	DWF gym lobby	I	DWF	11/24/2021 08:22AM	3.2	ppb			JLR-NH	11/30/2021 04:22PM
2111-03724-013	DWF 6/7 grade Boy LR	I	DWF	11/24/2021 08:33AM	1.3	ppb			DR-NH	12/02/2021 01:17PM
2111-03724-014	DWF 8th grade Boys LR	I	DWF	11/24/2021 08:35AM	1.4	ppb			JLR-NH	11/30/2021 04:26PM
2111-03724-015	DWF 6/7 grade Girls LR	I	DWF	11/24/2021 08:30AM	2.1	ppb			DR-NH	12/02/2021 01:25PM
2111-03724-016	DWF 8th grade girls LR	I	DWF	11/24/2021 08:33AM	1.2	ppb			JLR-NH	11/30/2021 04:29PM

Rebecca L. Labranche  
 Laboratory Director