



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 12/03/2021  
**CLIENT NAME:** Phippsburg Elementary School  
**CLIENT ADDRESS:** 1047 Main Road  
 Phippsburg, ME 04562  
**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

**DATE AND TIME RECEIVED:** 11/29/2021 09:35AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 21° CELSIUS  
**CLIENT JOB #:** 358

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2111-03720-001	Drinking Fountain by music Rm	I	DWF	11/24/2021 10:32AM	<1	ppb			JLR-NH	11/30/2021 02:17PM
2111-03720-002	Drinking Fountain by Rm 11	I	DWF	11/24/2021 10:33AM	1.0	ppb			JLR-NH	11/30/2021 02:20PM
2111-03720-003	Drinking Fountain by Staff Rm	I	DWF	11/24/2021 10:35AM	<1	ppb			JLR-NH	11/30/2021 02:24PM
2111-03720-004	Sink in Staff Rm	I	OT	11/25/2021 10:36AM	1.1	ppb			DR-NH	12/02/2021 12:32PM
2111-03720-005	Kitchen Sink	I	KF	11/24/2021 10:38AM	2.7	ppb			DR-NH	12/02/2021 12:45PM

Rebecca L. Labranche  
 Laboratory Director