



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/01/2021
CLIENT NAME: Dike-Newell School
CLIENT ADDRESS: 3 Wright Drive
 Bath, ME 04530
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	⚠
Lead Above 15 ppb	⊗

DATE AND TIME RECEIVED: 11/29/2021 09:35AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 21° CELSIUS
CLIENT JOB #: 58

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2111-03731-001	Sink kitchen	I	KF	11/24/2021 08:57AM	<1	ppb			JLR-NH	11/30/2021 04:33PM
2111-03731-002	Drinking Fountain Rm 3	I	DWF	11/24/2021 09:01AM	6.6	ppb	⚠		JLR-NH	11/30/2021 04:36PM
2111-03731-003	Drinking Fountain Rm 5	I	DWF	11/24/2021 09:06AM	7.0	ppb	⚠		JLR-NH	11/30/2021 04:47PM
2111-03731-004	Drinking Fountain Rm 4	I	DWF	11/24/2021 09:05AM	4.2	ppb	⚠		JLR-NH	11/30/2021 04:51PM
2111-03731-005	Drinking Fountain Rm 2	I	DWF	11/24/2021 09:04AM	17.2	ppb	⊗		JLR-NH	11/30/2021 05:02PM
2111-03731-006	Drinking Fountain Rm 1	I	DWF	11/24/2021 09:02AM	22.5	ppb	⊗		JLR-NH	11/30/2021 05:05PM
2111-03731-007	DWF outside of cafe	I	DWF	11/24/2021 09:07AM	2.1	ppb			JLR-NH	11/30/2021 05:09PM
2111-03731-008	Sink main office	I	OT	11/24/2021 09:09AM	16.4	ppb	⊗		JLR-NH	11/30/2021 05:12PM
2111-03731-009	Sink nurses office	I	DWF	11/24/2021 09:11AM	5.7	ppb	⚠		JLR-NH	11/30/2021 05:16PM
2111-03731-010	Drinking Fountain Rm 27	I	DWF	11/24/2021 09:12AM	1.3	ppb			JLR-NH	11/30/2021 05:20PM
2111-03731-011	Drinking Fountain Rm 27A	I	DWF	11/24/2021 09:13AM	7.4	ppb	⚠		JLR-NH	11/30/2021 05:23PM
2111-03731-012	Drinking Fountain/Sink Rm 29	I	OT	11/24/2021 09:17AM	22.1	ppb	⊗		JLR-NH	11/30/2021 05:27PM
2111-03731-013	Drinking Fountain by Rm 32	I	DWF	11/24/2021 09:26AM	27.7	ppb	⊗		JLR-NH	11/30/2021 05:48PM
2111-03731-014	Drinking Fountain Rm 28	I	DWF	11/24/2021 09:28AM	2.9	ppb			JLR-NH	11/30/2021 05:52PM
2111-03731-015	Drinking Fountain Rm 35	I	DWF	11/24/2021 09:29AM	8.4	ppb	⚠		JLR-NH	11/30/2021 05:56PM
2111-03731-016	Drinking Fountain By Gym	I	DWF	11/24/2021 09:31AM	123	ppb	⊗		JLR-NH	11/30/2021 05:59PM
2111-03731-017	Sink Staff Rm 2nd Floor	I	OT	11/24/2021 09:34AM	18.9	ppb	⊗		JLR-NH	11/30/2021 06:03PM
2111-03731-018	Drinking Fountain by Bathroom	I	DWF	11/24/2021 09:36AM	7.8	ppb	⚠		JLR-NH	11/30/2021 06:06PM

Rebecca L. Labranche
 Laboratory Director