

May 19, 2021

Alex Rodriguez
Rome City School District
409 Bell Road
Rome, NY 13440

RE: Project: STALEY ELEM 04/27
Pace Project No.: 70172437

Dear Alex Rodriguez:

Enclosed are the analytical results for sample(s) received by the laboratory on May 10, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Julie Litvin
julie.litvin@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Shelby Schreiner, Rome City School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Pace Analytical Services Long Island

Virginia Certification # 460302

Delaware Certification # NY10478

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 2		Lab ID: 70172437001	Collected: 04/27/21 05:27	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		05/18/21 13:09	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 3		Lab ID: 70172437002	Collected: 04/27/21 05:28	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		05/18/21 13:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 4		Lab ID: 70172437003	Collected: 04/27/21 05:31	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		05/18/21 13:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 5		Lab ID: 70172437004	Collected: 04/27/21 05:32	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		05/18/21 13:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 6	Lab ID: 70172437005	Collected: 04/27/21 05:36	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		05/18/21 13:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 7		Lab ID: 70172437006	Collected: 04/27/21 05:37	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		05/18/21 13:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 8	Lab ID: 70172437007	Collected: 04/27/21 05:38	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		05/18/21 13:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 9		Lab ID: 70172437008	Collected: 04/27/21 05:39	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		05/18/21 13:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 13		Lab ID: 70172437009	Collected: 04/27/21 05:42	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	14.2	ug/L	1.0	1		05/18/21 13:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 14		Lab ID: 70172437010	Collected: 04/27/21 05:43	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.8	ug/L	1.0	1		05/18/21 13:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 15		Lab ID: 70172437011	Collected: 04/27/21 05:44	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.3	ug/L	1.0	1		05/18/21 13:22	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 17		Lab ID: 70172437012	Collected: 04/27/21 05:49	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.3	ug/L	1.0	1		05/18/21 13:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 18		Lab ID: 70172437013	Collected: 04/27/21 06:05	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		05/18/21 13:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 19		Lab ID: 70172437014	Collected: 04/27/21 06:06	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.8	ug/L	1.0	1		05/18/21 13:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

Sample: STALELEM 20		Lab ID: 70172437015	Collected: 04/27/21 06:07	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		05/18/21 13:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 21	Lab ID: 70172437016	Collected: 04/27/21 06:08	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 13:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 22								
Lab ID: 70172437017								
Collected: 04/27/21 06:09								
Received: 05/10/21 11:40								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.9	ug/L	1.0	1		05/18/21 13:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 23								
Lab ID: 70172437018								
Collected: 04/27/21 06:06								
Received: 05/10/21 11:40								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	14.8	ug/L	1.0	1		05/18/21 13:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 24	Lab ID: 70172437019	Collected: 04/27/21 06:01	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		05/18/21 13:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 25		Lab ID: 70172437020	Collected: 04/27/21 05:55	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		05/18/21 13:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 26		Lab ID: 70172437021	Collected: 04/27/21 05:54	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		05/18/21 13:36	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 28		Lab ID: 70172437022	Collected: 04/27/21 06:20	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.5	ug/L	1.0	1		05/18/21 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 29		Lab ID: 70172437023	Collected: 04/27/21 06:21	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.0	ug/L	1.0	1		05/18/21 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 30		Lab ID: 70172437024	Collected: 04/27/21 06:18	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	45.0	ug/L	1.0	1		05/18/21 13:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 31		Lab ID: 70172437025	Collected: 04/27/21 06:17	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.1	ug/L	1.0	1		05/18/21 13:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 32								
Lab ID: 70172437026								
Collected: 04/27/21 06:28 Received: 05/10/21 11:40 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	52.8	ug/L	1.0	1		05/18/21 13:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 33	Lab ID: 70172437027	Collected: 04/27/21 06:20	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	103	ug/L	1.0	1		05/18/21 13:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 34	Lab ID: 70172437028	Collected: 04/27/21 06:30	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		05/18/21 13:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 35		Lab ID: 70172437029	Collected: 04/27/21 06:31	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	79.7	ug/L	1.0	1		05/18/21 13:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 36		Lab ID: 70172437030	Collected: 04/27/21 06:23	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		05/18/21 13:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 37		Lab ID: 70172437031	Collected: 04/27/21 06:24	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.1	ug/L	1.0	1		05/18/21 13:50	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 39		Lab ID: 70172437032	Collected: 04/27/21 06:35	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		05/18/21 13:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 40		Lab ID: 70172437033	Collected: 04/27/21 06:36	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 13:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 41	Lab ID: 70172437034	Collected: 04/27/21 06:37	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		05/18/21 13:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 42		Lab ID: 70172437035	Collected: 04/27/21 06:38	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		05/18/21 13:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 45		Lab ID: 70172437036	Collected: 04/27/21 06:46	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.7	ug/L	1.0	1		05/18/21 13:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 46								
Lab ID: 70172437037								
Collected: 04/27/21 06:47								
Received: 05/10/21 11:40								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	10	ug/L	1.0	1		05/18/21 13:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 48		Lab ID: 70172437038	Collected: 04/27/21 06:52	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.7	ug/L	1.0	1		05/18/21 14:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 50		Lab ID: 70172437039	Collected: 04/27/21 06:56	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		05/18/21 14:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 51								
Lab ID: 70172437040								
Collected: 04/27/21 06:57								
Received: 05/10/21 11:40								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		05/18/21 14:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 52		Lab ID: 70172437041	Collected: 04/27/21 06:58	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:05	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 53		Lab ID: 70172437042	Collected: 04/27/21 06:59	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 54	Lab ID: 70172437043	Collected: 04/27/21 07:00	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 56		Lab ID: 70172437044	Collected: 04/27/21 07:05	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		05/18/21 14:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 57		Lab ID: 70172437045	Collected: 04/27/21 07:06	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		05/18/21 14:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 58		Lab ID: 70172437046	Collected: 04/27/21 07:07	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		05/18/21 14:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 60		Lab ID: 70172437047	Collected: 04/27/21 07:08	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/18/21 14:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 61		Lab ID: 70172437048	Collected: 04/27/21 07:12	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 62		Lab ID: 70172437049	Collected: 04/27/21 07:13	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		05/18/21 14:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 63		Lab ID: 70172437050	Collected: 04/27/21 07:14	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 65		Lab ID: 70172437051	Collected: 04/27/21 07:16	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:17	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 66		Lab ID: 70172437052	Collected: 04/27/21 07:18	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		05/18/21 14:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 67	Lab ID: 70172437053	Collected: 04/27/21 07:19	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		05/18/21 14:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: STALELEM 70								
Lab ID: 70172437054								
Collected: 04/27/21 05:35 Received: 05/10/21 11:40 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.4	ug/L	1.0	1		05/18/21 14:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 71		Lab ID: 70172437055	Collected: 04/27/21 05:55	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2490	ug/L	5.0	5		05/18/21 22:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 72		Lab ID: 70172437056	Collected: 04/27/21 06:12	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		05/18/21 14:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 73		Lab ID: 70172437057	Collected: 04/27/21 06:13	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.0	ug/L	1.0	1		05/18/21 14:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 74		Lab ID: 70172437058	Collected: 04/27/21 06:25	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	80.8	ug/L	1.0	1		05/18/21 14:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 75	Lab ID: 70172437059	Collected: 04/27/21 06:32	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	44.8	ug/L	1.0	1		05/18/21 14:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 76		Lab ID: 70172437060	Collected: 04/27/21 06:40	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		05/18/21 14:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 77		Lab ID: 70172437061	Collected: 04/27/21 06:44	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		05/18/21 14:34	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 78	Lab ID: 70172437062	Collected: 04/27/21 06:50	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.5	ug/L	1.0	1		05/18/21 14:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 79		Lab ID: 70172437063	Collected: 04/27/21 06:51	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.9	ug/L	1.0	1		05/18/21 14:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 80		Lab ID: 70172437064	Collected: 04/27/21 07:01	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 81		Lab ID: 70172437065	Collected: 04/27/21 07:08	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		05/18/21 14:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 82		Lab ID: 70172437066	Collected: 04/27/21 07:15	Received: 05/10/21 11:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

Sample: STALELEM 83	Lab ID: 70172437067	Collected: 04/27/21 07:20	Received: 05/10/21 11:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/18/21 14:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

QC Batch:	209205	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70172437001, 70172437002, 70172437003, 70172437004, 70172437005, 70172437006, 70172437007, 70172437008, 70172437009, 70172437010, 70172437011, 70172437012, 70172437013, 70172437014, 70172437015, 70172437016, 70172437017, 70172437018, 70172437019, 70172437020		

METHOD BLANK:	1043392	Matrix:	Water
Associated Lab Samples:	70172437001, 70172437002, 70172437003, 70172437004, 70172437005, 70172437006, 70172437007, 70172437008, 70172437009, 70172437010, 70172437011, 70172437012, 70172437013, 70172437014, 70172437015, 70172437016, 70172437017, 70172437018, 70172437019, 70172437020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/18/21 13:07	

LABORATORY CONTROL SAMPLE:	1043393					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE:	1043395						
Parameter	Units	70172437001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.0	50	35.7	64	70-130	M1

MATRIX SPIKE SAMPLE:	1043397						
Parameter	Units	70172437011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.3	50	33.5	57	70-130	M1

SAMPLE DUPLICATE:	1043394					
Parameter	Units	70172437001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	4.0	3.9	3		

SAMPLE DUPLICATE:	1043396					
Parameter	Units	70172437011 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.3	5.3	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

QC Batch:	209206	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70172437021, 70172437022, 70172437023, 70172437024, 70172437025, 70172437026, 70172437027, 70172437028, 70172437029, 70172437030, 70172437031, 70172437032, 70172437033, 70172437034, 70172437035, 70172437036, 70172437037, 70172437038, 70172437039, 70172437040		

METHOD BLANK:	1043398	Matrix:	Water
Associated Lab Samples:	70172437021, 70172437022, 70172437023, 70172437024, 70172437025, 70172437026, 70172437027, 70172437028, 70172437029, 70172437030, 70172437031, 70172437032, 70172437033, 70172437034, 70172437035, 70172437036, 70172437037, 70172437038, 70172437039, 70172437040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/18/21 13:34	

LABORATORY CONTROL SAMPLE:	1043399					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.9	98	85-115	

MATRIX SPIKE SAMPLE:	1043401						
Parameter	Units	70172437021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.9	50	31.7	55	70-130	M1

MATRIX SPIKE SAMPLE:	1043403						
Parameter	Units	70172437031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.1	50	27.7	47	70-130	M1

SAMPLE DUPLICATE:	1043400					
Parameter	Units	70172437021 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.9	3.9	2		

SAMPLE DUPLICATE:	1043402					
Parameter	Units	70172437031 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	4.1	4.1	0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

QC Batch:	209207	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70172437041, 70172437042, 70172437043, 70172437044, 70172437045, 70172437046, 70172437047, 70172437048, 70172437049, 70172437050, 70172437051, 70172437052, 70172437053, 70172437054, 70172437055, 70172437056, 70172437057, 70172437058, 70172437059, 70172437060		

METHOD BLANK: 1043404 Matrix: Water
Associated Lab Samples: 70172437041, 70172437042, 70172437043, 70172437044, 70172437045, 70172437046, 70172437047, 70172437048, 70172437049, 70172437050, 70172437051, 70172437052, 70172437053, 70172437054, 70172437055, 70172437056, 70172437057, 70172437058, 70172437059, 70172437060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/18/21 14:03	

LABORATORY CONTROL SAMPLE: 1043405

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.8	98	85-115	

MATRIX SPIKE SAMPLE: 1043407

Parameter	Units	70172437041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	27.2	53	70-130	M1

MATRIX SPIKE SAMPLE: 1043409

Parameter	Units	70172437051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	26.9	52	70-130	M1

SAMPLE DUPLICATE: 1043406

Parameter	Units	70172437041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1043408

Parameter	Units	70172437051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

QC Batch: 209212 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70172437061, 70172437062, 70172437063, 70172437064, 70172437065, 70172437066, 70172437067

METHOD BLANK: 1043413 Matrix: Water
Associated Lab Samples: 70172437061, 70172437062, 70172437063, 70172437064, 70172437065, 70172437066, 70172437067

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/18/21 14:30	

LABORATORY CONTROL SAMPLE: 1043414

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.1	98	85-115	

MATRIX SPIKE SAMPLE: 1043416

Parameter	Units	70172437061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.7	50	27.1	49	70-130	M1

MATRIX SPIKE SAMPLE: 1043418

Parameter	Units	70171101018 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.7	50	30.6	52	70-130	M1

SAMPLE DUPLICATE: 1043415

Parameter	Units	70172437061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.7	2.7	2	

SAMPLE DUPLICATE: 1043417

Parameter	Units	70171101018 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.7	4.8	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: STALEY ELEM 04/27

Pace Project No.: 70172437

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70172437001	STALELEM 2	EPA 200.8	209205		
70172437002	STALELEM 3	EPA 200.8	209205		
70172437003	STALELEM 4	EPA 200.8	209205		
70172437004	STALELEM 5	EPA 200.8	209205		
70172437005	STALELEM 6	EPA 200.8	209205		
70172437006	STALELEM 7	EPA 200.8	209205		
70172437007	STALELEM 8	EPA 200.8	209205		
70172437008	STALELEM 9	EPA 200.8	209205		
70172437009	STALELEM 13	EPA 200.8	209205		
70172437010	STALELEM 14	EPA 200.8	209205		
70172437011	STALELEM 15	EPA 200.8	209205		
70172437012	STALELEM 17	EPA 200.8	209205		
70172437013	STALELEM 18	EPA 200.8	209205		
70172437014	STALELEM 19	EPA 200.8	209205		
70172437015	STALELEM 20	EPA 200.8	209205		
70172437016	STALELEM 21	EPA 200.8	209205		
70172437017	STALELEM 22	EPA 200.8	209205		
70172437018	STALELEM 23	EPA 200.8	209205		
70172437019	STALELEM 24	EPA 200.8	209205		
70172437020	STALELEM 25	EPA 200.8	209205		
70172437021	STALELEM 26	EPA 200.8	209206		
70172437022	STALELEM 28	EPA 200.8	209206		
70172437023	STALELEM 29	EPA 200.8	209206		
70172437024	STALELEM 30	EPA 200.8	209206		
70172437025	STALELEM 31	EPA 200.8	209206		
70172437026	STALELEM 32	EPA 200.8	209206		
70172437027	STALELEM 33	EPA 200.8	209206		
70172437028	STALELEM 34	EPA 200.8	209206		
70172437029	STALELEM 35	EPA 200.8	209206		
70172437030	STALELEM 36	EPA 200.8	209206		
70172437031	STALELEM 37	EPA 200.8	209206		
70172437032	STALELEM 39	EPA 200.8	209206		
70172437033	STALELEM 40	EPA 200.8	209206		
70172437034	STALELEM 41	EPA 200.8	209206		
70172437035	STALELEM 42	EPA 200.8	209206		
70172437036	STALELEM 45	EPA 200.8	209206		
70172437037	STALELEM 46	EPA 200.8	209206		
70172437038	STALELEM 48	EPA 200.8	209206		
70172437039	STALELEM 50	EPA 200.8	209206		
70172437040	STALELEM 51	EPA 200.8	209206		
70172437041	STALELEM 52	EPA 200.8	209207		
70172437042	STALELEM 53	EPA 200.8	209207		
70172437043	STALELEM 54	EPA 200.8	209207		
70172437044	STALELEM 56	EPA 200.8	209207		
70172437045	STALELEM 57	EPA 200.8	209207		
70172437046	STALELEM 58	EPA 200.8	209207		
70172437047	STALELEM 60	EPA 200.8	209207		
70172437048	STALELEM 61	EPA 200.8	209207		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: STALEY ELEM 04/27
Pace Project No.: 70172437

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70172437049	STALELEM 62	EPA 200.8	209207		
70172437050	STALELEM 63	EPA 200.8	209207		
70172437051	STALELEM 65	EPA 200.8	209207		
70172437052	STALELEM 66	EPA 200.8	209207		
70172437053	STALELEM 67	EPA 200.8	209207		
70172437054	STALELEM 70	EPA 200.8	209207		
70172437055	STALELEM 71	EPA 200.8	209207		
70172437056	STALELEM 72	EPA 200.8	209207		
70172437057	STALELEM 73	EPA 200.8	209207		
70172437058	STALELEM 74	EPA 200.8	209207		
70172437059	STALELEM 75	EPA 200.8	209207		
70172437060	STALELEM 76	EPA 200.8	209207		
70172437061	STALELEM 77	EPA 200.8	209212		
70172437062	STALELEM 78	EPA 200.8	209212		
70172437063	STALELEM 79	EPA 200.8	209212		
70172437064	STALELEM 80	EPA 200.8	209212		
70172437065	STALELEM 81	EPA 200.8	209212		
70172437066	STALELEM 82	EPA 200.8	209212		
70172437067	STALELEM 83	EPA 200.8	209212		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 70172437



70172437

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section C Invoice Information:
Company: Rome City School District
Address: 409 Bell Road
Rome, NY 13440
Email: arodriguez@romescd.org
Phone: 315-334-7270
Fax:
Requested Due Date:

Company Name: Alex Rodriguez
Address:
Purchase Order #:
Project Name: Rome City School - Staley Elem
Project #:
Company Name:
Address:
Pace Quote: x
Pace Project Manager: julie.litvin@pacelabs.com
Pace Profile #: x

Page: 1 Of 6

Regulatory Agency
State / Location NY

Table with columns: ITEM #, MATRIX, CODE, MATRIX TYPE, COLLECTED (START DATE/TIME, END DATE/TIME), SAMPLE TEMP AT COLLECTION, # OF CONTAINERS, Unpreserved, H2SO4, HNO3, HCl, NaOH, Na2S2O3, Methanol, Other, Analyzes Test (Y/N), 200 & Lead, Requested Analysis Filtered (Y/N), Residual Chlorine (Y/N).

Table with columns: ADDITIONAL COMMENTS, RELINQUISHED BY / AFFILIATION, DATE, TIME, ACCEPTED BY / AFFILIATION, DATE, TIME, SAMPLE CONDITIONS (Received on, Sealed, Cooler, Custody, Ice, Temp in C).

SAMPLER NAME AND SIGNATURE
PRINT Name of SAMPLER: CHRIS PETER
SIGNATURE OF SAMPLER: [Signature]
DATE Signed: 4/27



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company: Rome City School District	Report To: Alex Rodriguez	Matrix Code: DW	Sample Type: (G-GRAB C-COMP)	Company Name:	Attention:
Address: 409 Bell Road	Copy To:	MATRIX CODE (see valid codes to left)		Address:	
Rome, NY 13440	Purchase Order #:	COLLECTED	START DATE TIME	Pace Quote:	
Email: erodriguez@omecsd.org	Project Name: Rome City School - Staley Elem	END DATE TIME		Address: x	
Phone: 315-334-7270	Project #: Rome City School - Staley Elem	DATE		Pace Project Manager: julie.litvin@pacelabs.com	
Requested Due Date:	Project #:	DATE		Pace Profile #: x	NY
		DATE		State / Location	
		DATE		NY	
		DATE		Regulatory Agency	

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE TIME	END DATE TIME			H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other			
1	STALELEM	17	4/27 0539										X			
2	STALELEM	18	0605										X			
3	STALELEM	19	0606										X			
4	STALELEM	20	0607										X			
5	STALELEM	21	0608										X			
6	STALELEM	22	0609										X			
7	STALELEM	23	0610										X			
8	STALELEM	27	0535-0601										X			
9	STALELEM	25	0535										X			
10	STALELEM	26	0539										X			
11	STALELEM	28	0820										X			
12	STALELEM	29	0621										X			

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	Received on	TEMP in C
	Signature	5-10-21	11:10	Signature	5-7-21	10:00		
	Signature			Signature	12/15/21	11:40		
SAMPLER NAME AND SIGNATURE				DATE Signed:				
PRINT Name of SAMPLER:								
SIGNATURE of SAMPLER:								



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Rome City School District	Report To:	Alex Rodriguez	Attention:	
Address:	409 Bell Road	Copy To:		Company Name:	
Rome, NY 13440		Purchase Order #:		Address:	
Email:	arodriguez@romecsd.org	Project Name:	Rome City School- Staley Elem	Pace Quote:	X
Phone:	315-334-7270	Requested Due Date:		Pace Project Manager:	julie litvin@pacelabs.com
				Pace Profile #:	X
				State / Location	NY
				Regulatory Agency	

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
			START	END									
1	STALELEM	DW	4/27	0618									
2	STALELEM	DW	1	0619									
3	STALELEM	DW	0627										
4	STALELEM	DW	30										
5	STALELEM	DW	30										
6	STALELEM	DW	31										
7	STALELEM	DW	23										
8	STALELEM	DW	24										
9	STALELEM	DW	35										
10	STALELEM	DW	36										
11	STALELEM	DW	37										
12	STALELEM	DW	38										

MATRIX CODE	DW	2008 Lead	X
Preservatives			
Unpreserved			
H2SO4			
HNO3			
HCl			
NaOH			
Na2S2O3			
Methanol			
Other			
Analyses Test	Y/N		
Requested Analysis Filtered (Y/N)			
# OF CONTAINERS			
SAMPLE TEMP AT COLLECTION			
TEMP in C			
Received on			
Sealed			
Cooler			
Samples			



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: **4** Of **6**

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Rome City School District	Report To:	Alex Rodriguez	Attention:	
Address:	409 Bell Road	Copy To:		Company Name:	
Rome, NY 13440		Purchase Order #:		Address:	
Email:	arodriguez@romecsd.org	Project Name:	Rome City School- Staley Elem	Pace Quote:	X
Phone:	315-334-7270	Requested Due Date:		Pace Project Manager:	julie.livvin@pace labs.com
				Pace Profile #:	X
				Regulatory Agency:	
				State / Location:	NY

ITEM #	MATRIX	CODE	COLLECTED		DATE	TIME	SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Requested Analysis Filtered (Y/N)										Residual Chlorine (Y/N)																
			START	END						Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	Analyses Test	Y/N																	
1	STALELEM	DW	4/27		0646		DW																													
2	STALELEM	DW			0647		DW																													
3	STALELEM	DW			0652		DW																													
4	STALELEM	DW			0656		DW																													
5	STALELEM	DW			0657		DW																													
6	STALELEM	DW			0658		DW																													
7	STALELEM	DW			0659		DW																													
8	STALELEM	DW			0700		DW																													
9	STALELEM	DW			0705		DW																													
10	STALELEM	DW			0706		DW																													
11	STALELEM	DW			0707		DW																													
12	STALELEM	DW			0708		DW																													
		ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME		SAMPLE CONDITIONS		Received on		TEMP in C		Ice (Y/N)		Custody (Y/N)		Sealed Cooler (Y/N)		Samples Intact (Y/N)								
		Am 216 sample in Does not Exist		<i>[Signature]</i>		5-10-21		0711		<i>[Signature]</i>		5-7-21		1000																						

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	DATE Signed:
SIGNATURE of SAMPLER:	



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 6 Of 6

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Rome City School District	Report To:	Alex Rodriguez	Attention:	
Address:	409 Bell Road	Copy To:		Company Name:	
Rome, NY 13440				Address:	
Email:	arodriguez@romecsd.org	Purchase Order #:		Pace Quote:	X
Phone:	315-334-7270	Project Name:	Rome City School- Staley Elem	Pace Project Manager:	julie.livini@pacelabs.com
Requested Due Date:		Project #:		Pace Profile #:	X
					NY
					Regulatory Agency
					State / Location

ITEM #	MATRIX CODE (A-Z, 0-9 /, -,) Sample ids must be unique	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED			# OF CONTAINERS	Requested Analysis Filtered (Y/N)										TEMP in C	Received on Ice (Y/N)	Custody Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)																	
				START DATE	START TIME	END TIME		PRESERVATIVES	ANALYSES TEST	ANALYSES TEST																													
										UNPRESERVED	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other						2008 Lead	Residual Chrome (Y/N)															
1	76 - Girl's Office Bath (near 57B in 312)	DW	DW	4/27	0640																																		
2	77 - GN Bath in cafe	DW	DW	1	0644																																		
3	78 - GN Bath next to 304	DW	DW	1	0656																																		
4	79 - ↓ 307	DW	DW	1	0651																																		
5	80 - in Girls across from 211	DW	DW	1	0701																																		
6	81 - in Boys ↓ 204	DW	DW	1	0708																																		
7	82 - in Girls (204) 573	DW	DW	1	0715																																		
8	83 - ↓ in Boys ↓ 511	DW	DW	1	0720																																		
9	STALELEM	DW	DW																																				
10	STALELEM	DW	DW																																				
11	STALELEM	DW	DW																																				
12	STALELEM	DW	DW																																				

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>Alex Rodriguez</i>	5-10-22	11-10	<i>Alex Pace</i>	5-21-22	1000	
			<i>Julie Livini</i>	5/10/22	1140	

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	DATE Signed:
SIGNATURE of SAMPLER:	



Sample Condition Upon Receipt

WO#: 70172437

Client Name: Rome City School District Project

PM: JL1

Due Date: 05/18/21

CLIENT: RCSD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes NoPacking Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091

Correction Factor: +0.0Cooler Temperature(°C): 19.1Cooler Temperature Corrected(°C): 19.1

Temp should be above freezing to 6.0°C

USDA Regulated Soil { N/A, water sample }Date and Initials of person examining contents: MN 5/11/21Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes NoDid samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: SL <input checked="" type="checkbox"/> W <input type="checkbox"/> OIL		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HCI48594</u>		
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample # <u>5 stale lem16</u> was not submitted. - JL1
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot # _____		
Residual chlorine strips Lot # _____		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot # _____		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution: _____

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____