

May 05, 2021

Alex Rodriguez
Rome City School District
409 Bell Road
Rome, NY 13440

RE: Project: BELLAMY ELEMENTERY 4/20
Pace Project No.: 70170849

Dear Alex Rodriguez:

Enclosed are the analytical results for sample(s) received by the laboratory on April 27, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Julie Litvin
julie.litvin@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Shelby Schreiner, Rome City School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Pace Analytical Services Long Island

Delaware Certification # NY10478

Virginia Certification # 460302

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 1		Lab ID: 70170849001	Collected: 04/20/21 05:16	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 4		Lab ID: 70170849002	Collected: 04/20/21 05:17	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 5		Lab ID: 70170849003	Collected: 04/20/21 05:18	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 6		Lab ID: 70170849004	Collected: 04/20/21 05:22	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 8		Lab ID: 70170849005	Collected: 04/20/21 05:24	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 10	Lab ID: 70170849006	Collected: 04/20/21 05:25	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 11		Lab ID: 70170849007	Collected: 04/20/21 05:26	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 13		Lab ID: 70170849008	Collected: 04/20/21 05:27	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 14	Lab ID: 70170849009	Collected: 04/20/21 05:28	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 16		Lab ID: 70170849010	Collected: 04/20/21 05:29	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 17		Lab ID: 70170849011	Collected: 04/20/21 05:30	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 19		Lab ID: 70170849012	Collected: 04/20/21 05:31	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 20		Lab ID: 70170849013	Collected: 04/20/21 05:32	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 22		Lab ID: 70170849014	Collected: 04/20/21 05:34	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 23		Lab ID: 70170849015	Collected: 04/20/21 05:35	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 25		Lab ID: 70170849016	Collected: 04/20/21 05:36	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 27		Lab ID: 70170849017	Collected: 04/20/21 05:38	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 29		Lab ID: 70170849018	Collected: 04/20/21 05:39	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 11:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 31		Lab ID: 70170849019	Collected: 04/20/21 05:41	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 33		Lab ID: 70170849020	Collected: 04/20/21 05:42	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 34		Lab ID: 70170849021	Collected: 04/20/21 05:44	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 36		Lab ID: 70170849022	Collected: 04/20/21 05:47	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 38	Lab ID: 70170849023	Collected: 04/20/21 05:50	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 39		Lab ID: 70170849024	Collected: 04/20/21 05:51	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 40		Lab ID: 70170849025	Collected: 04/20/21 05:52	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.8	ug/L	1.0	1		05/02/21 12:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 41		Lab ID: 70170849026	Collected: 04/20/21 05:55	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.0	ug/L	1.0	1		05/02/21 12:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 43		Lab ID: 70170849027	Collected: 04/20/21 05:58	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 45		Lab ID: 70170849028	Collected: 04/20/21 05:59	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 47		Lab ID: 70170849029	Collected: 04/20/21 06:00	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 49		Lab ID: 70170849030	Collected: 04/20/21 06:01	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 51		Lab ID: 70170849031	Collected: 04/20/21 06:03	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 53		Lab ID: 70170849032	Collected: 04/20/21 06:05	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 55		Lab ID: 70170849033	Collected: 04/20/21 06:07	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 57		Lab ID: 70170849034	Collected: 04/20/21 06:08	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 59		Lab ID: 70170849035	Collected: 04/20/21 06:09	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 61		Lab ID: 70170849036	Collected: 04/20/21 06:10	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 63		Lab ID: 70170849037	Collected: 04/20/21 06:14	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 65		Lab ID: 70170849038	Collected: 04/20/21 06:16	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 67		Lab ID: 70170849039	Collected: 04/20/21 06:18	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20
Pace Project No.: 70170849

Sample: BELL 69		Lab ID: 70170849040	Collected: 04/20/21 06:22	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 71		Lab ID: 70170849041	Collected: 04/20/21 06:21	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 74		Lab ID: 70170849042	Collected: 04/20/21 06:13	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 75		Lab ID: 70170849043	Collected: 04/20/21 06:30	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 78	Lab ID: 70170849044	Collected: 04/20/21 06:36	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		05/02/21 12:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 79	Lab ID: 70170849045	Collected: 04/20/21 06:37	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.3	ug/L	1.0	1		05/02/21 12:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 80		Lab ID: 70170849046	Collected: 04/20/21 06:39	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		05/02/21 12:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 81		Lab ID: 70170849047	Collected: 04/20/21 06:40	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		05/02/21 12:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 82	Lab ID: 70170849048	Collected: 04/20/21 06:41	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		05/02/21 12:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 83	Lab ID: 70170849049	Collected: 04/20/21 06:42	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 84		Lab ID: 70170849050	Collected: 04/20/21 06:45	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 85		Lab ID: 70170849051	Collected: 04/20/21 06:46	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 90		Lab ID: 70170849052	Collected: 04/20/21 06:47	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 91		Lab ID: 70170849053	Collected: 04/20/21 05:49	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 94		Lab ID: 70170849054	Collected: 04/20/21 06:25	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 95		Lab ID: 70170849055	Collected: 04/20/21 06:28	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 96		Lab ID: 70170849056	Collected: 04/20/21 06:23	Received: 04/27/21 10:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Sample: BELL 97	Lab ID: 70170849057	Collected: 04/20/21 06:31	Received: 04/27/21 10:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		05/02/21 12:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

QC Batch:	206566	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170849001, 70170849002, 70170849003, 70170849004, 70170849005, 70170849006, 70170849007, 70170849008, 70170849009, 70170849010, 70170849011, 70170849012, 70170849013, 70170849014, 70170849015, 70170849016, 70170849017, 70170849018		

METHOD BLANK:	1024965	Matrix:	Water
Associated Lab Samples:	70170849001, 70170849002, 70170849003, 70170849004, 70170849005, 70170849006, 70170849007, 70170849008, 70170849009, 70170849010, 70170849011, 70170849012, 70170849013, 70170849014, 70170849015, 70170849016, 70170849017, 70170849018		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/02/21 11:31	

LABORATORY CONTROL SAMPLE:	1024966					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.8	96	85-115	

MATRIX SPIKE SAMPLE:	1024968						
Parameter	Units	70170565014 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.5	113	70-130	

MATRIX SPIKE SAMPLE:	1024970						
Parameter	Units	70170849009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.2	109	70-130	

SAMPLE DUPLICATE:	1024967					
Parameter	Units	70170565014 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1024969					
Parameter	Units	70170849009 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BELLAMY ELEMENTERY 4/20
Pace Project No.: 70170849

QC Batch:	206567	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70170849019, 70170849020, 70170849021, 70170849022, 70170849023, 70170849024, 70170849025, 70170849026, 70170849027, 70170849028, 70170849029, 70170849030, 70170849031, 70170849032, 70170849033, 70170849034, 70170849035, 70170849036, 70170849037, 70170849038

METHOD BLANK: 1024971 Matrix: Water
Associated Lab Samples: 70170849019, 70170849020, 70170849021, 70170849022, 70170849023, 70170849024, 70170849025, 70170849026, 70170849027, 70170849028, 70170849029, 70170849030, 70170849031, 70170849032, 70170849033, 70170849034, 70170849035, 70170849036, 70170849037, 70170849038

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/02/21 12:00	

LABORATORY CONTROL SAMPLE: 1024972

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.2	94	85-115	

MATRIX SPIKE SAMPLE: 1024974

Parameter	Units	70170849019 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.3	116	70-130	

MATRIX SPIKE SAMPLE: 1024976

Parameter	Units	70170849029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.4	110	70-130	

SAMPLE DUPLICATE: 1024973

Parameter	Units	70170849019 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1024975

Parameter	Units	70170849029 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

QC Batch:	206568	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170849039, 70170849040, 70170849041, 70170849042, 70170849043, 70170849044, 70170849045, 70170849046, 70170849047, 70170849048, 70170849049, 70170849050, 70170849051, 70170849052, 70170849053, 70170849054, 70170849055, 70170849056, 70170849057		

METHOD BLANK:	1024977	Matrix:	Water
Associated Lab Samples:	70170849039, 70170849040, 70170849041, 70170849042, 70170849043, 70170849044, 70170849045, 70170849046, 70170849047, 70170849048, 70170849049, 70170849050, 70170849051, 70170849052, 70170849053, 70170849054, 70170849055, 70170849056, 70170849057		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/02/21 12:30	

LABORATORY CONTROL SAMPLE: 1024978

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.2	94	85-115	

MATRIX SPIKE SAMPLE: 1024980

Parameter	Units	70170849039 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.3	111	70-130	

MATRIX SPIKE SAMPLE: 1024982

Parameter	Units	70170849049 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.6	111	70-130	

SAMPLE DUPLICATE: 1024979

Parameter	Units	70170849039 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1024981

Parameter	Units	70170849049 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

WORKORDER QUALIFIERS

WO: 70170849

[1] Client gave sample BELL 97 @ 6:31 but was not on COC, logged off the bottle.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170849001	BELL 1	EPA 200.8	206566		
70170849002	BELL 4	EPA 200.8	206566		
70170849003	BELL 5	EPA 200.8	206566		
70170849004	BELL 6	EPA 200.8	206566		
70170849005	BELL 8	EPA 200.8	206566		
70170849006	BELL 10	EPA 200.8	206566		
70170849007	BELL 11	EPA 200.8	206566		
70170849008	BELL 13	EPA 200.8	206566		
70170849009	BELL 14	EPA 200.8	206566		
70170849010	BELL 16	EPA 200.8	206566		
70170849011	BELL 17	EPA 200.8	206566		
70170849012	BELL 19	EPA 200.8	206566		
70170849013	BELL 20	EPA 200.8	206566		
70170849014	BELL 22	EPA 200.8	206566		
70170849015	BELL 23	EPA 200.8	206566		
70170849016	BELL 25	EPA 200.8	206566		
70170849017	BELL 27	EPA 200.8	206566		
70170849018	BELL 29	EPA 200.8	206566		
70170849019	BELL 31	EPA 200.8	206567		
70170849020	BELL 33	EPA 200.8	206567		
70170849021	BELL 34	EPA 200.8	206567		
70170849022	BELL 36	EPA 200.8	206567		
70170849023	BELL 38	EPA 200.8	206567		
70170849024	BELL 39	EPA 200.8	206567		
70170849025	BELL 40	EPA 200.8	206567		
70170849026	BELL 41	EPA 200.8	206567		
70170849027	BELL 43	EPA 200.8	206567		
70170849028	BELL 45	EPA 200.8	206567		
70170849029	BELL 47	EPA 200.8	206567		
70170849030	BELL 49	EPA 200.8	206567		
70170849031	BELL 51	EPA 200.8	206567		
70170849032	BELL 53	EPA 200.8	206567		
70170849033	BELL 55	EPA 200.8	206567		
70170849034	BELL 57	EPA 200.8	206567		
70170849035	BELL 59	EPA 200.8	206567		
70170849036	BELL 61	EPA 200.8	206567		
70170849037	BELL 63	EPA 200.8	206567		
70170849038	BELL 65	EPA 200.8	206567		
70170849039	BELL 67	EPA 200.8	206568		
70170849040	BELL 69	EPA 200.8	206568		
70170849041	BELL 71	EPA 200.8	206568		
70170849042	BELL 74	EPA 200.8	206568		
70170849043	BELL 75	EPA 200.8	206568		
70170849044	BELL 78	EPA 200.8	206568		
70170849045	BELL 79	EPA 200.8	206568		
70170849046	BELL 80	EPA 200.8	206568		
70170849047	BELL 81	EPA 200.8	206568		
70170849048	BELL 82	EPA 200.8	206568		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: BELLAMY ELEMENTERY 4/20

Pace Project No.: 70170849

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170849049	BELL 83	EPA 200.8	206568		
70170849050	BELL 84	EPA 200.8	206568		
70170849051	BELL 85	EPA 200.8	206568		
70170849052	BELL 90	EPA 200.8	206568		
70170849053	BELL 91	EPA 200.8	206568		
70170849054	BELL 94	EPA 200.8	206568		
70170849055	BELL 95	EPA 200.8	206568		
70170849056	BELL 96	EPA 200.8	206568		
70170849057	BELL 97	EPA 200.8	206568		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

4318

Page: 4 Of 5

Section A
Required Client Information:
 Company: Internek-PSI
 Address: 104 Erie Boulevard
 Suite 1, Schenectady, NY 12305
 Email: william.kotas@internek.com
 Phone: 518-377-9841
 Requested Due Date:

Section B
Required Project Information:
 Report To: William Kotas
 Copy To: William Kotas
 Purchase Order #:
 Project Name:
 Project #:

Section C
Invoice Information:
 Attention: William Kotas
 Company Name: Internek-PSI
 Address: 104 Erie Boulevard
 Pace Quote:
 Pace Project Manager:
 Pace Profile #:


Regulatory Agency
State / Location
 NY

ITEM #	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives										Analyses Test	Y/N	Requested Analysis Filtered (Y/N)
			START DATE	END DATE			H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	Pb by EPA 200.8					
BEL63	DW G	DW G	04/20	0614		1											X		
65	DW G	DW G		0616		1											X		
67	DW G	DW G		0618		1											X		
69	DW G	DW G		0622		1											X		
71	DW G	DW G		0621		1											X		
74 (Bottle filler)	DW G	DW G		0613		1											X		
75	DW G	DW G		0630		1											X		
78	DW G	DW G		0636		1											X		
79	DW G	DW G		0637		1											X		
80	DW G	DW G		0639		1											X		
81	DW G	DW G		0640		1											X		
82	DW G	DW G		0641		1											X		

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
				<i>William Kotas</i>	4/27/24	1040	

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: Chris Putzer
 SIGNATURE of SAMPLER: *Chris Putzer*
 DATE Signed:

TEMP in C	Received on	Sealed	Custody	Cooler	Intact



Sample Condition Upon Receipt

Client Name: ROME

Proj#

WO#: 70170849

PM: JL1

Due Date: 05/06/21

CLIENT: RCSD

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 7735 5672 9505

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: T1091 Correction Factor: +0.0

Cooler Temperature(°C): 19.1 Cooler Temperature Corrected(°C): 19.1

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

temperature Blank Present: Yes No

Type of Ice: Wet Blue None

Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer

Date and Initials of person examining contents: 4/27/21 JP

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: SL <u>WT</u> OIL				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13.
pH paper Lot # <u>H1025486</u>				
All containers needing preservation are found to be in compliance with method recommendation?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	Sample #
(HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)				
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).				Initial when completed: Lot # of added preservative: Date/Time preservative added:
Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #				
Residual chlorine strips Lot #				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):				

Client Notification/ Resolution: _____ Field Data Required? Y / N

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: client gave sample BELL 97 @ 6:31 but was not on COC. logged at the end