



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

St George School
PO Box 153
Tenants Harbor, ME 04860

Date Printed: 02/03/2022
Work Order #: 2201-03069
Client Job #: 835
Date Received: 01/25/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/03/2022
CLIENT NAME: St George School
CLIENT ADDRESS: PO Box 153
 Tenants Harbor, ME 04860
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 01/25/2022 11:55AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 7° CELSIUS
CLIENT JOB #: 835

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-03069-001	room 28 bubbler	I	DWF	01/23/2022 08:00AM	96.2	ppb			JLR-NH	02/01/2022 03:38PM
2201-03069-002	room 28 faucet	I	OT	01/23/2022 08:00AM	1.6	ppb			JLR-NH	02/01/2022 07:30PM
2201-03069-003	room 27 bubbler	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/01/2022 07:33PM
2201-03069-004	room 27 faucet	I	OT	01/23/2022 08:00AM	4.9	ppb			JLR-NH	02/01/2022 07:36PM
2201-03069-005	room 26 bubbler	I	DWF	01/23/2022 08:00AM	7.1	ppb			JLR-NH	02/01/2022 07:39PM
2201-03069-006	room 26 faucet	I	OT	01/23/2022 08:00AM	3.0	ppb			JLR-NH	02/01/2022 07:42PM
2201-03069-007	room 25 bubbler	I	DWF	01/23/2022 08:00AM	175	ppb			JLR-NH	02/01/2022 03:41PM
2201-03069-008	room 25 faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/01/2022 07:53PM
2201-03069-009	junior high girls faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/01/2022 07:56PM
2201-03069-010	junior high boys faucet	I	OT	01/23/2022 08:00AM	1.5	ppb			JLR-NH	02/01/2022 07:59PM
2201-03069-011	room 7 bubbler	I	DWF	01/23/2022 08:00AM	86.4	ppb			JLR-NH	02/01/2022 08:02PM
2201-03069-012	room 7 bathroom faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/01/2022 08:05PM
2201-03069-013	room 7 faucet	I	OT	01/23/2022 08:00AM	2.4	ppb			JLR-NH	02/01/2022 08:13PM
2201-03069-014	room 1 bubbler	I	DWF	01/23/2022 08:00AM	441	ppb			JLR-NH	02/01/2022 03:43PM
2201-03069-015	room 1 faucet	I	OT	01/23/2022 08:00AM	2.8	ppb			JLR-NH	02/01/2022 08:16PM
2201-03069-016	room 2 bubbler	I	DWF	01/23/2022 08:00AM	16.0	ppb			JLR-NH	02/01/2022 03:46PM
2201-03069-017	room 2 faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/01/2022 08:19PM
2201-03069-018	room 3 bubbler	I	DWF	01/23/2022 08:00AM	96.5	ppb			JLR-NH	02/01/2022 03:49PM
2201-03069-019	room 3 faucet	I	OT	01/23/2022 08:00AM	1.9	ppb			JLR-NH	02/02/2022 12:59PM
2201-03069-020	room 4 bubbler	I	DWF	01/23/2022 08:00AM	79.7	ppb			JLR-NH	02/01/2022 03:52PM
2201-03069-021	room 4 faucet	I	OT	01/23/2022 08:00AM	3.2	ppb			JLR-NH	02/02/2022 01:02PM
2201-03069-022	water dispenser 2nd floor	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:05PM
2201-03069-023	water dispenser 1st floor	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:09PM
2201-03069-024	nurses faucet	I	OT	01/23/2022 08:00AM	1.9	ppb			JLR-NH	02/02/2022 01:12PM
2201-03069-025	nurses bathroom faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:15PM
2201-03069-026	teachers room faucet	I	OT	01/23/2022 08:00AM	1.8	ppb			JLR-NH	02/02/2022 01:18PM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/03/2022
CLIENT NAME: St George School
CLIENT ADDRESS: PO Box 153
Tenants Harbor, ME 04860
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 01/25/2022 11:55AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 7° CELSIUS
CLIENT JOB #: 835

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-03069-027	boys bathroom left faucet main hall	I	OT	01/23/2022 08:00AM	1.4	ppb			JLR-NH	02/02/2022 01:27PM
2201-03069-028	boys right faucet main hall	I	OT	01/23/2022 08:00AM	1.4	ppb			JLR-NH	02/02/2022 01:36PM
2201-03069-029	bottle fill station middle level	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:38PM
2201-03069-030	drinking fountain middle level	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:41PM
2201-03069-031	girls bathroom left faucet main hall	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:44PM
2201-03069-032	girls bathroom right faucet main hall	I	OT	01/23/2022 08:00AM	1.2	ppb			JLR-NH	02/02/2022 01:47PM
2201-03069-033	health faucet under window	I	OT	01/23/2022 08:00AM	1.8	ppb			JLR-NH	02/02/2022 01:50PM
2201-03069-034	health faucet south wall	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 01:53PM
2201-03069-035	health faucet east wall	I	OT	01/23/2022 08:00AM	1.5	ppb			JLR-NH	02/02/2022 01:56PM
2201-03069-036	room 17 bubbler	I	DWF	01/23/2022 08:00AM	1.6	ppb			JLR-NH	02/02/2022 02:04PM
2201-03069-037	room 17 faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:21PM
2201-03069-038	staff bathroom faucet	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:24PM
2201-03069-039	art room utility sink	I	OT	01/23/2022 08:00AM	5.1	ppb			JLR-NH	02/02/2022 02:27PM
2201-03069-040	art room sink south wall	I	OT	01/23/2022 08:00AM	3.0	ppb			JLR-NH	02/02/2022 02:30PM
2201-03069-041	art room left sink south wall	I	OT	01/23/2022 08:00AM	11.2	ppb			JLR-NH	02/02/2022 02:33PM
2201-03069-042	art room sink north wall	I	OT	01/23/2022 08:00AM	2.1	ppb			JLR-NH	02/02/2022 02:36PM
2201-03069-043	middle level bottle fill	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:39PM
2201-03069-044	middle level bubbler	I	DWF	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:41PM
2201-03069-045	mid level boys bathroom sink	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:44PM
2201-03069-046	mid level girls bathroom sink	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 02:53PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/03/2022
CLIENT NAME: St George School

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

CLIENT ADDRESS: PO Box 153
 Tenants Harbor, ME 04860

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 01/25/2022 11:55AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 7° CELSIUS
CLIENT JOB #: 835

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-03069-047	kitchen prep sink	I	OT	01/23/2022 08:00AM	<1	ppb			JLR-NH	02/02/2022 03:02PM
2201-03069-048	kitchen hand wash sink	I	OT	01/23/2022 08:00AM	8.7	ppb			JLR-NH	02/02/2022 03:05PM
2201-03069-049	kitchen spray wand	I	OT	01/23/2022 08:00AM	1.3	ppb			JLR-NH	02/02/2022 03:08PM
2201-03069-050	locker room boys faucet	I	OT	01/23/2022 08:00AM	3.3	ppb			JLR-NH	02/02/2022 03:10PM
2201-03069-051	locker room girls bathroom sink	I	OT	01/23/2022 08:00AM	26.7	ppb			JLR-NH	02/01/2022 03:55PM
2201-03069-052	locker room boys bubbler	I	DWF	01/23/2022 08:00AM	124	ppb			JLR-NH	02/01/2022 03:58PM
2201-03069-053	locker room girls bubbler	I	DWF	01/23/2022 08:00AM	123	ppb			JLR-NH	02/01/2022 04:01PM
2201-03069-054	moduler left bathroom sink	I	OT	01/23/2022 08:00AM	6.4	ppb			JLR-NH	02/02/2022 03:13PM
2201-03069-055	moduler right bathroom sink	I	OT	01/23/2022 08:00AM	1.0	ppb			JLR-NH	02/02/2022 03:16PM

Rebecca L. Labranche
 Laboratory Director