EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Higginbotham**
Collingswood Board of Education
424 Collings Ave.
Collingswood, NJ 08108

Phone: (856) 962-5730
Fax: (856) 962-9355

1/17/2022

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/29/2021. The results are tabulated on the attached data pages for the following client designated project:

Totem School

The reference number for these samples is EMSL Order #012200284. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director

The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012200284
CustomerID:	COLL50A
CustomerPO:	
ProjectID:	

Attn: **Keith Higginbotham**
Collingswood Board of Education
424 Collings Ave.
Collingswood, NJ 08108

Phone: (856) 962-5730
Fax: (856) 962-9355
Received: 12/29/2021 01:00 PM

Project: **Totem School**

Analytical Results

Client Sample Description Totem 1 ***Collected:*** 12/29/2021 7:37:00 AM ***Lab ID:*** *012200284-0001*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 01:54	KB

Client Sample Description Totem 2 ***Collected:*** 12/29/2021 7:38:00 AM ***Lab ID:*** *012200284-0002*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	1.15	1.00 µg/L	1/13/2022	KB	1/14/2022 01:58	KB

Client Sample Description Totem 3A Bottle Filler ***Collected:*** 12/29/2021 7:39:00 AM ***Lab ID:*** *012200284-0003*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:00	KB

Client Sample Description Totem 3B Drinking Outlet ***Collected:*** 12/29/2021 7:40:00 AM ***Lab ID:*** *012200284-0004*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:04	KB

Client Sample Description Totem 4 ***Collected:*** 12/29/2021 7:42:00 AM ***Lab ID:*** *012200284-0005*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	6.39	1.00 µg/L	1/13/2022	KB	1/14/2022 02:05	KB

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012200284
CustomerID:	COLL50A
CustomerPO:	
ProjectID:	

Attn: **Keith Higginbotham**
Collingswood Board of Education
424 Collings Ave.
Collingswood, NJ 08108

Phone: (856) 962-5730
Fax: (856) 962-9355
Received: 12/29/2021 01:00 PM

Project: **Totem School**

Analytical Results

Client Sample Description Totem 5 ***Collected:*** 12/29/2021 7:43:00 AM ***Lab ID:*** *012200284-0006*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	9.01	1.00 µg/L	1/13/2022	KB	1/14/2022 02:07	KB

Client Sample Description Totem 6 ***Collected:*** 12/29/2021 7:44:00 AM ***Lab ID:*** *012200284-0007*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	2.89	1.00 µg/L	1/13/2022	KB	1/14/2022 02:08	KB

Client Sample Description Totem 7 ***Collected:*** 12/29/2021 7:45:00 AM ***Lab ID:*** *012200284-0008*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	6.78	1.00 µg/L	1/13/2022	KB	1/14/2022 02:10	KB

Client Sample Description Totem 8 ***Collected:*** 12/29/2021 7:46:00 AM ***Lab ID:*** *012200284-0009*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:11	KB

Client Sample Description Totem 9 ***Collected:*** 12/29/2021 7:47:00 AM ***Lab ID:*** *012200284-0010*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	14.6	1.00 µg/L	1/12/2022	KB	1/13/2022 15:12	JW

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012200284
CustomerID:	COLL50A
CustomerPO:	
ProjectID:	

Attn: **Keith Higginbotham**
Collingswood Board of Education
424 Collings Ave.
Collingswood, NJ 08108

Phone: (856) 962-5730
Fax: (856) 962-9355
Received: 12/29/2021 01:00 PM

Project: **Totem School**

Analytical Results

Client Sample Description Totem 10 ***Collected:*** 12/29/2021 7:48:00 AM ***Lab ID:*** *012200284-0011*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:13	KB

Client Sample Description Totem 11A Bottle Filler ***Collected:*** 12/29/2021 7:49:00 AM ***Lab ID:*** *012200284-0012*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:14	KB

Client Sample Description Totem 11B Drinking Outlet ***Collected:*** 12/29/2021 7:51:00 AM ***Lab ID:*** *012200284-0013*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:22	KB

Client Sample Description Totem 12 ***Collected:*** 12/29/2021 7:51:00 AM ***Lab ID:*** *012200284-0014*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	ND	1.00 µg/L	1/13/2022	KB	1/14/2022 02:23	KB

Client Sample Description Totem 13 ***Collected:*** 12/29/2021 7:52:00 AM ***Lab ID:*** *012200284-0015*

Method	*Parameter*	*Result*	*RL Units*	*Prep Date & Analyst*		*Analysis Date & Analyst*	
METALS							
200.8	Lead	5.04	1.00 µg/L	1/13/2022	KB	1/14/2022 02:25	KB

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (856) 303-2500 / (856) 858-4571
http://www.EMSL.com EnvChemistry2@emsl.com

EMSL Order:	012200284
CustomerID:	COLL50A
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - indicates that the analyte was not detected at the reporting limit
RL - Reporting Limit (Analytical)
D - Dilution Sample required a dilution which was used to calculate final results