

**Report For
Indoor Air Quality Testing
At The
Fowler Middle School
Maynard, MA**

Study Date:
March 23, 2022

Project# 222 183.00

STUDY CONDUCTED BY:

UNIVERSAL ENVIRONMENTAL CONSULTANTS
12 Brewster Road
Framingham, Massachusetts

March 24, 2022

Mr. Robert Savoie
Facilities Director
Maynard Public Schools
3-R Tiger Drive
Maynard, MA 01754

Reference: Indoor Air Quality Testing
Fowler Middle School

Dear Mr. Savoie:

Thank you for the opportunity for Universal Environmental Consultants (UEC) to provide professional services.

Enclosed please find the report for Indoor Air Quality Testing at the Fowler Middle School conducted on Wednesday, March 23, 2022.

Please do not hesitate to call should you have any questions.

Very truly yours,

Universal Environmental Consultants



Ammar M. Dieb
President

UEC:\222 183.00\IAQ Report-Fowler MS.DOC

Enclosure

Scope:

UEC was contracted to perform an Indoor Air Quality Testing at the Fowler Middle School, Maynard, MA. Testing was performed at select areas within the school.

Testing was performed on Wednesday, March 23, 2022.

Methodology:

Testing for Total Volatile Organic Compounds (**TVOCs**) was performed using Q-Trak XP monitor manufactured by TSI Incorporated. This is a state-of-the-art instrument capable of detecting **TVOCs** in the ppb (parts per billion) and $\mu\text{g}/\text{m}^3$ (micrograms per cubic meter) ranges. The instrument is a direct reading instrument and provides continuous results over an extended time. The unit is calibrated prior to use and serviced by an independent vendor annually.

Volatile organic compounds are a broad class of chemicals with diverse applications which are frequently emitted by new carpets, furniture, pressboards, varnishes, adhesives, and high gloss finishes. Other common products which may emit VOCs include construction materials, paints, paint strippers, other solvents, wood preservatives, aerosol sprays, cleansers, disinfectants, hand sanitizer, moth repellents, air fresheners, stored fuels, automotive products, hobby supplies, and dry-cleaned clothing. High levels of VOCs are a common Indoor Air Quality problem, especially in newly constructed, recently renovated, or currently being renovated buildings.

Carbon monoxide (**CO**), Carbon Dioxide (**CO₂**), Temperature (**°F**), and Relative Humidity (**%RH**) were measured using a Q-Trak XP monitor manufactured by TSI Incorporated. The unit is calibrated prior to use and serviced by an independent vendor annually.

Airborne particulate matter (**PM**) levels for **PM₁₀** and **PM_{2.5}** were tested using a Q-Trak XP monitor manufactured by TSI Incorporated. This is a state-of-the-art instrument capable of simultaneously detecting **PM₁₀** and **PM_{2.5}** in the microgram per cubic meter ($\mu\text{g}/\text{m}^3$) range. The instrument is a direct reading monitor and provided sampling readings at 1 second intervals over the duration of each test. The instrument was zeroed prior to testing and is serviced annually by the manufacturer or an independent vendor.

Real time **PM** Measurement is a useful comparative measure of indoor and outdoor dust levels as well as identifying indoor sources of **PM**.

Samples were collected for approximately 5 minutes at each test location. No TWA (8-hour time weighted average) or other types or methods of sampling were included in the scope of work.

Results:

TEMPERATURE, RELATIVE HUMIDITY, CARBON MONOXIDE, CARBON DIOXIDE & TOTAL VOLATILE ORGANIC COMPOUNDS by PID

Location	W	D	#	Temperature (°F)	Humidity %RH	CO (ppm)	CO ₂ (ppm)	TVOCs (µg/m ³)
Outside	-	-	0	44.6	29.9	0.0	361	0
Main Office	C	C	2	64.9	23.2	0.4	517	450
Auditorium	C	C	0	68.5	16.8	0.8	417	410
OT Room	C	O	1	68.5	19.3	0.8	488	460
Practice B	C	O	0	69.1	19.2	0.8	480	4,204
Practice E	C	O	0	69.3	19.1	0.9	486	430
Gymnasium	C	C	0	69.1	22.1	0.9	490	410
Cafeteria	C	O	0	69.3	18.8	0.9	513	400
Teacher's Lounge	C	O	0	70.5	18.1	0.8	522	420
Nurse's Office	C	O	0	70.9	17.9	0.8	517	430
Library	C	O	2	70.9	16.6	0.8	494	410
B104	C	O	0	70.9	16.1	0.8	491	400
B114	C	O	2	70.3	16.8	0.8	518	430
B104	C	O	3	70.2	17.5	0.8	496	420
A112 T. Lounge	C	O	0	70.2	16.0	0.7	454	390
A105	C	O	15	70.0	17.7	0.7	619	400
A111	C	O	1	70.0	17.4	0.7	521	410
A108	C	O	0	70.3	16.7	0.7	491	390
A209	C	O	15	70.9	18.9	0.7	616	420
A207	C	O	10	71.2	17.8	0.6	655	470
B215	C	O	1	71.1	17.6	0.6	651	410
B214	C	O	2	70.5	17.6	0.6	624	440
B212	C	O	15	70.9	18.8	0.6	726	610
C Hall T. Lounge	C	O	0	70.7	16.4	0.5	526	390
C209	C	O	0	70.9	17.0	0.5	491	400
C212	C	O	1	71.2	17.0	0.4	466	400

Total PM - PM₁₀, Respirable, PM_{2.5} and PM1

Location	PM 10 (mg/m ³)	PM 2.5 (mg/m ³)	PM1 (mg/m ³)
Main Office	0.002	0.0	0.0
Auditorium	0.004	0.001	0.001
OT Room	0.0	0.0	0.0
Practice B	0.001	0.0	0.0
Practice E	0.0	0.0	0.0
Gymnasium	0.0	0.0	0.0
Cafeteria	0.0	0.0	0.0
Teacher's Lounge	0.0	0.0	0.0

Location	PM 10 (mg/m ³)	PM 2.5 (mg/m ³)	PM1 (mg/m ³)
Nurse's Office	0.0	0.0	0.0
Library	0.0	0.0	0.0
B104	0.0	0.0	0.0
B114	0.001	0.0	0.0
B101	0.0	0.0	0.0
A112 T. Lounge	0.0	0.0	0.0
A105	0.0	0.0	0.0
A111	0.0	0.0	0.0
A108	0.0	0.0	0.0
A209	0.0	0.0	0.0
A207	0.0	0.0	0.0
B215	0.0	0.0	0.0
B214	0.003	0.0	0.0
B212	0.0	0.0	0.0
C Hall T. Lounge	0.0	0.0	0.0
C209	0.001	0.0	0.0
C212	0.0	0.0	0.0

Legend:

W: Windows; D; Doors; # Number of Occupants (e.g., 25 Occupants = 25); O = Open; C = Closed.

mg/m³ - milligrams per cubic meter; µg/m³ - micrograms per cubic meter.

ppm - parts per million.

ppb - parts per billion.

CO OSHA PEL is 30 ppm and ACGIH TLV is 25 ppm.

CO₂ - OSHA PEL is 5000 ppm, Mass DOH Guideline is 800 ppm.

TVOC – Seifert "Target Guideline Value" of 300 µg/m³

Observations and Interpretation of Results:

Temperature and Relative Humidity (T & RH)

The outside **T** and **RH** were approximately 44.6°F and 29.9%. Massachusetts Department of Public Health (MDPH) recommends that indoor **T** be maintained in a range of 70 - 78 °F and 40 to 60 % for indoor **RH** to provide for the comfort of building occupants.

Indoor **T** and **RH** were 64.9°F – 71.2°F and 16.0% – 23.2% during the test period. Indoor **T** tests were mostly within the MDPH recommended **T** range of 70 - 78 °F. Indoor **RH** tests were lower than the MDPH recommended **RH** range of 40 to 60 %.

TVOCs

TVOCs levels on this day were higher than the Seifert “Target Guideline Value” of 300-µg/m³. The Seifert Target Guideline Value (reference #3 and #8 below) is a widely recognized **TVOCs** guideline for pollutant levels based on Seifert's personal judgment, rather than on toxicological data, for long term exposure. Seifert proposed that 1 week after completion of construction or renovation **TVOC** concentration of 50 times higher be acceptable (i.e., 15,000 µg/m³.) and after 6 weeks, 10 times higher be acceptable (i.e., 3,000 µg/m³). **TVOCs** test levels were between 390 ug/m³ and 4,204 ug/m³, higher than the Seifert target guideline of 300 ug/m³, but much lower than the 1-week post-construction/renovation acceptable limit of 15,000 ug/m³.

Neither OSHA (Occupational Safety and Health Administration) nor ACGIH (American Conference of Governmental Industrial Hygienists) promulgates exposure standards for **TVOCs** that relate to protection of the general population as opposed to industrial occupational standards. Both have limits on individual VOCs, but they relate to industrial occupational standard.

Testing conducted was of short duration and did not assess representative full-day occupancy levels. Measurements were made using a real-time, portable **TVOC** monitor referenced to isobutylene and not by sample collection for individual VOC analysis by gas chromatography technique and evaluation based on Seifert's chemical classes. Møhlave of Denmark reported at INDOOR AIR '90 (reference #8 below) on low levels of indoor air VOCs and human health. Bearg summarized Møhlave's findings as follows.

Table 4.5 Tentative Dose-Response Relationship for Discomfort Resulting from Exposure to Solvent-Like VOCs

Total concentration (ug/m ³)	Irritation and discomfort	Exposure
< 200	No irritation or discomfort	The comfort range
200 – 3,000	Irritation and discomfort possible if other exposures interact	The multifactorial exposure range
3,000 – 25,000	Exposure effect and probable headache possible if other exposures interact	The discomfort range
> 25,000	Additional neurotoxic effects other than headache may occur	The toxic range

TVOCs test levels were between 390 ug/m³ and 4,204 ug/m³. The slightly elevated levels of **TVOCs** at all areas are mostly due to the heavy use of hand sanitizer, disinfectant, or cleaning supplies. The high level of **TVOCs** at Practice B is mostly due to the presence of science related products.

Carbon Monoxide

All **CO** levels were much lower than the EPA of 9 ppm, OSHA PEL of 30 ppm and the ACGIH TLV of 25 ppm based on an 8-hours TWA.

Carbon Dioxide

All **CO₂** levels were within the acceptable range. For comparative purposes, fresh outdoor air has approximately 400 ppm of **CO₂**. All areas were well below the OSHA/NIOSH limit of 5000 ppm, and below the MDPH guideline of 800 ppm for publicly occupied buildings. MDPH recommends an optimal level of below 600 ppm. Exposure to high levels of **CO₂** for prolonged periods could cause building occupants to become lethargic and generally uncomfortable. **CO₂** levels will rise over the course of the day especially in those areas which have a high occupancy. **CO₂ at these levels is a comfort as opposed to a health issue.**

Airborne Particulate Matter (Dust):


Dust monitoring is one aspect of air quality that an industrial hygienist can use to determine the amount of dust particles present in the workplace, cities or communities over a given period.

The Particulate Matter (PM) monitoring focused on measuring a range of particulate sizes in the air that are equal to or less than 10 micrometers (PM₁₀) and equal to or less than 2.5 micrometers (PM_{2.5}) in diameter (course dust and fine dust respectively), i.e., PM capable of penetrating the outer defenses of the respiratory tract, such as the mouth and nose, and can pass into the lungs based on PM size. PM air pollutants include but are not limited to soot, smoke, salts, metals, acids and soil and road dust. These pollutants are typically monitored along work site fence lines, industrial complexes, during wildfires, and high traffic areas (vehicle exhaust).

EPA's health-based National Ambient Air Quality Standard (NAAQS) for PM₁₀ is 150- $\mu\text{g}/\text{m}^3$ and for PM_{2.5} is 35- $\mu\text{g}/\text{m}^3$ (measured as a 24-hours period concentration) for outdoor (ambient) air. The OSHA Permissible Exposure Limit (PEL) for occupational exposure for respirable dust is 5- mg/m^3 (5,000- $\mu\text{g}/\text{m}^3$) for a time-weighted average (8 hour) exposure. While the EPA NAAQS is an outdoor, ambient air standard, it is a useful reference guide for acceptable air quality in general with limits far below OSHA worker compliance requirement levels.

The TSI Q-Trak XP monitor used in this survey can measure PM simultaneously as PM₁₀, PM_{2.5} and PM₁, i.e., particles in the size range categories of 10, 2.5 and 1 micrometer diameter.

Figure 1.1-Visual Particle Size Comparison Chart.



Levels of PM₁₀ recorded in areas tested during the survey ranged from **0 to 4- $\mu\text{g}/\text{m}^3$ or 0.0 to 0.004 mg/m^3** . EPA's health-based National Ambient Air Quality Standard (NAAQS) recommended level for PM₁₀ is **150- $\mu\text{g}/\text{m}^3$ or 0.150- mg/m^3** . All areas tested during the survey were below the EPA recommended level.

Levels of PM_{2.5} recorded in areas tested during the survey ranged from **0 to 1- $\mu\text{g}/\text{m}^3$ or 0.0 to 0.001- mg/m^3** . EPA's health-based National Ambient Air Quality Standard (NAAQS) recommended level for PM_{2.5} is **35- $\mu\text{g}/\text{m}^3$ or 0.035- mg/m^3** . All areas tested during the survey were below the EPA recommended level.

Direct reading PM monitors are not a reference method for OSHA compliance Respirable Dust testing. However, the direct reading instrument is useful in providing accurate order of magnitude evaluation of Respirable Dust levels.

Samples were collected for approximately 5 minutes at each test location and results/levels are not based on TWA (8-hour time weighted average).

Conclusions and Recommendations:

Indoor ***RH*** tests were lower than the MDPH recommended ***RH*** range of 40 to 60 %.

TVOCs test levels were between 390 ug/m³ and 4,204 ug/m³. The slightly elevated levels of ***TVOCs*** at all areas are mostly due to the heavy use of hand sanitizer, disinfectant, or cleaning supplies. The high level of ***TVOCs*** at Practice B is mostly due to the presence of science related products. ***TVOCs*** levels will dissipate with time.

All other IAQ parameters tested were within the acceptable ranges.

Limitations and Conditions:

This report has been completed based on visual and physical observations made and information available at the time of the site visits. This report is intended to be used as a summary of available information on existing conditions with conclusions based on a reasonable and knowledgeable review of evidence found in accordance with normally accepted industry standards, state, and federal protocols, and within the scope and budget established by the client. Any additional data obtained by further review must be reviewed by UEC and the conclusions presented herein may be modified accordingly.

This report and attachments, prepared for the exclusive use of Owner for use in an environmental evaluation of the subject site, are an integral part of the inspections and opinions should not be formulated without reading the report in its entirety. No part of this report may be altered, used, copied, or relied upon without prior written permission from UEC, except that this report may be conveyed in its entirety to parties associated with Owner for this subject study.

REFERENCES:

1. ACGIH, Threshold Limit values and Biological Exposure Indices, 2007.
2. AIHA, 2700 Prospect Ave., Fairfax, VA. IAQ Paper #130 June 23, 1999.
3. Seifert, B. Regulation Indoor Air. In: Indoor Air '90, Proceedings of the 5th International Conference on Indoor Air Quality and Climate, Volume V, p. 35. Toronto 1990.
4. American Society of Heating, Refrigeration and Air-conditioning Engineers' ANSI/ASHRAE 55-1992 **"Thermal Environmental Conditions for Human Occupancy."**
5. BOCA, 1993. The BOCA National Mechanical Code 1993 8th edition Building Officials and Code Administrators International., Inc., Country Club Hills, Ill
6. SBBRS, 1997. Mechanical Ventilation, State Board of Building Regulations and Standards Code of Massachusetts Regulations 780 CMR 1209.0
7. Field Guide for the Determination of Biological Contaminants in Environmental Samples. (2005)
8. Bearg, David W. Indoor Air Quality and HVAC Systems. (1993). Pages 76, 77 and others.