



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Telstar High School  
284 Walkers Mills Road  
Bethel, ME 04217

Date Printed: 04/07/2022  
Work Order #: 2203-00123  
Client Job #: 792  
Date Received: 03/01/2022  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20  
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;  
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507  
Nashoba Analytical, LLC: Accreditations: Massachusetts M-MA1118



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/07/2022  
CLIENT NAME: Telstar High School

CLIENT ADDRESS: 284 Walkers Mills Road  
Bethel, ME 04217

METHOD: EPA 200.8  
EPA ACTION LEVEL: 15 ppb  
MAINE GUIDELINE: 4 ppb  
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/01/2022 01:15PM  
ANALYSIS PACKAGE: Maine Schools-Lead  
RECEIPT TEMPERATURE: 20° CELSIUS  
CLIENT JOB #: 792

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00123-001	library office	I	KF	02/23/2022 06:05AM	3.3	ppb			DR-NH	04/01/2022 12:45PM
2203-00123-002	high school office lunch room	I	KF	02/23/2022 06:07AM	<1	ppb			DR-NH	04/01/2022 12:54PM
2203-00123-003	Ad Ed sink	I	KF	02/23/2022 06:08AM	1.4	ppb			DR-NH	04/01/2022 12:57PM
2203-00123-004	nurses's bathroom	I	OT	02/23/2022 06:09AM	2.4	ppb			DR-NH	04/01/2022 12:59PM
2203-00123-005	room 107-north wall-center lab	I	KF	02/23/2022 06:14AM	131	ppb			DR-NH	04/01/2022 01:02PM
2203-00123-006	room107-north wall-near closet	I	KF	02/23/2022 06:12AM	11.0	ppb			DR-NH	04/01/2022 01:11PM
2203-00123-007	room 107-north wall-near chemical closet	I	KF	02/23/2022 06:16AM	12.5	ppb			DR-NH	04/01/2022 01:14PM
2203-00123-008	room107-island lab-front of room	I	KF	02/23/2022 06:15AM	13.6	ppb			DR-NH	04/01/2022 01:17PM
2203-00123-009	room 107-right sink by windows	I	KF	02/23/2022 06:15AM	10.8	ppb			DR-NH	04/01/2022 01:20PM
2203-00123-010	room 107-center sink by windows	I	KF	02/23/2022 06:16AM	3.4	ppb			DR-NH	04/01/2022 01:31PM
2203-00123-011	room 107-left sink by windows	I	KF	02/23/2022 06:15AM	132	ppb			DR-NH	04/01/2022 01:34PM
2203-00123-012	room 107-right lab by windows	I	KF	02/23/2022 06:16AM	12.0	ppb			DR-NH	04/01/2022 01:37PM
2203-00123-013	room 110-left sink by windows	I	KF	02/23/2022 06:21AM	72.6	ppb			DR-NH	04/01/2022 01:40PM
2203-00123-014	room 110-center sink by windows	I	KF	02/23/2022 06:21AM	5.3	ppb			DR-NH	04/01/2022 01:43PM
2203-00123-015	room 110-right sink by windows	I	KF	02/23/2022 06:20AM	9.9	ppb			DR-NH	04/01/2022 01:46PM
2203-00123-016	room 110-left sink by hall	I	KF	02/23/2022 06:20AM	11.7	ppb			DR-NH	04/01/2022 01:55PM
2203-00123-017	room 110-center sink by hall	I	KF	02/23/2022 06:19AM	9.3	ppb			DR-NH	04/01/2022 01:57PM

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 04/07/2022  
CLIENT NAME: Telstar High School

CLIENT ADDRESS: 284 Walkers Mills Road  
Bethel, ME 04217

METHOD: EPA 200.8  
EPA ACTION LEVEL: 15 ppb  
MAINE GUIDELINE: 4 ppb  
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 03/01/2022 01:15PM  
ANALYSIS PACKAGE: Maine Schools-Lead  
RECEIPT TEMPERATURE: 20° CELSIUS  
CLIENT JOB #: 792

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-00123-018	room 110-right sink by hall	I	KF	02/23/2022 06:18AM	95.8	ppb			DR-NH	04/01/2022 02:06PM
2203-00123-019	bottle fill by high school bathrooms	I	DWF	02/23/2022 06:21AM	<1	ppb			DR-NH	04/01/2022 02:09PM
2203-00123-020	high school teachers lounge	I	KF	02/23/2022 06:22AM	3.0	ppb			DR-NH	04/01/2022 02:12PM
2203-00123-021	music room-bathroom sink	I	OT	02/23/2022 06:24AM	<1	ppb			DR-NH	04/01/2022 02:15PM
2203-00123-022	girls locker room-bottle fill station	I	DWF	02/23/2022 06:26AM	<1	ppb			DR-NH	04/01/2022 02:18PM
2203-00123-023	boys locker room-bottle fill station	I	DWF	02/23/2022 06:28AM	<1	ppb			DR-NH	04/01/2022 02:21PM
2203-00123-024	boys locker room-ice machine	I	DWF	02/23/2022 06:28AM	<1	ppb			DR-NH	04/06/2022 05:00PM
2203-00123-025	room 220-bottle fill station	I	DWF	02/23/2022 06:36AM	<1	ppb			DR-NH	04/01/2022 02:24PM
2203-00123-026	room 226	I	KF	02/23/2022 06:37AM	1.8	ppb			DR-NH	04/01/2022 02:27PM
2203-00123-027	bottle fill station by kitchen	I	DWF	02/23/2022 06:29AM	<1	ppb			DR-NH	04/01/2022 02:45PM
2203-00123-028	bottle fill station in cafeteria	I	DWF	02/23/2022 06:30AM	<1	ppb			DR-NH	04/01/2022 02:48PM
2203-00123-029	kitchen-food prep sink	I	KF	02/23/2022 06:31AM	<1	ppb			DR-NH	04/01/2022 02:50PM
2203-00123-030	kitchen kettle	I	KF	02/23/2022 06:31AM	11.3	ppb			DR-NH	04/01/2022 02:53PM
2203-00123-031	boosters room	I	KF	02/23/2022 06:30AM	8.8	ppb			DR-NH	04/06/2022 05:03PM

Rebecca L. Labranche  
Laboratory Director