

Water Sampling Log: Re-Test

Name of Building (see below)
Building Owner Madison Board of Education

Date Collected 10-Sep-21
Sample Collected by JS Gilbert

Sample No.	Tap No.	Sample Type	Type of Outlet	Manufacturer		Time	Results (mg/L)	
							Cu	Pb
					<u>High School</u>			
RK-091021-11	24	1 st	Sink		Snack Bar by football field	7:10	XX	0.0080
					<u>Junior School</u>			
RK-091021-12	5	1 st	Hose Filler		Kitchen - hose filler in center of room	7:19	XX	0.0028
					<u>Kings Road School</u>			
RK-091021-13	4	1 st	Fountain		2nd Floor Hallway, by Boy's Room, right side	07:30	XX	< 0.0010
					<u>TJ Sabatini School</u>			
RK-091021-14	10	1 st	Sink		Kitchen Sink	07:42	XX	0.0012

Sample Type: **1st:** First Draw sample collected after water sat in pipe between 8 and 18 hours
FL: Water flushed through tap for at least 2 minutes
<: means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0010 mg/L for Lead.