



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Paul A. Hellman
Director

Adam Fieseler
Assistant Director

PUBLIC NOTICE

July 20, 2022

NOTICE OF PROPOSED PERMITTING OF AIR CONTAMINANT EMISSIONS LOCATED WITHIN 1,000 FEET OF A SCHOOL

The Black Butte Elementary School (applicant) has submitted an application for an Authority to Construct/Permit to Operate for a diesel-fired generator to be located at 7752 Ponderosa Way, Shingletown, CA 96088. The proposed engine is a John Deere 197 horsepower diesel engine. The purpose for the emergency generator replacement is to provide electric service to the Black Butte Elementary School in the event of a commercial power outage. The Shasta County Air Quality Management District (District) is required by Section 42301.6 of the California Health and Safety Code to issue a public notice and to notify parents of students attending schools within ¼ mile and all other addresses located within 1,000 feet of a source that emits any hazardous air emissions. This notice is intended to inform you of this facility request.

The District has evaluated this project and has determined that the total potential health risk and air quality impact from the diesel emissions is insignificant. The facility's permit to operate application has been reviewed and the proposed engine and engine operation will be in compliance with all District rules and regulations. Comments on this project will be received by the District for a period of 30 days from the date of this notice and will be considered prior to taking final action on permitting the facility.

The information for the facility, supporting documents, and the analysis of the air quality impacts of this project are available for inspection at the District office located at 1855 Placer Street, Suite 101, Redding, California, during regular business hours.

For further information on this project, please call Air Pollution Inspector, Kyle Willard at 530-225-5674.

This flyer is being distributed solely for informational purposes as part of the District's limited open forum policy. The activity and organization and/or individual named herein are not sponsored by the school or District. Participation in any of the activities described herein is at the risk of the participant. The District is not responsible for the accuracy of the information contained herein.

■ Suite 101

AIR QUALITY MANAGEMENT DISTRICT
(530) 225-5674
Fax (530) 225-5237

□ Suite 102

BUILDING DIVISION
(530) 225-5761
Fax (530) 245-6468

□ Suite 103

PLANNING DIVISION
(530) 225-5532
Fax (530) 245-6468

□ Suite 201

ENVIRONMENTAL HEALTH DIVISION
(530) 225-5787
Fax (530) 225-5413

□ Suite 200

ADMINISTRATION
(530) 225-5789
Fax (530) 225-5807