

(DECC) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-2-1-HW-DWC-P-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-HW-DWC-SS-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-HW-DWC-F-01	Hallway Water Fountain w/Cooler	05/03/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-2-1-SL-SINK-P-02	Staff Lounge Sink Faucet	05/03/2023	0.0067		mg/L	0.0020	NA	NA
LAKE-2-1-SL-SINK-F-02	Staff Lounge Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM1-SINK-P-03	Room 1 Sink Faucet	05/03/2023	0.00073	J	mg/L	0.0020	NA	NA
LAKE-2-1-RM1-SINK-F-03	Room 1 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM2-SINK-P-04	Room 2 Sink Faucet	05/03/2023	0.0023		mg/L	0.0020	NA	NA
LAKE-2-1-RM2-SINK-F-04	Room 2 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-2-1-RM3-SINK-P-05	Room 3 Sink Faucet	05/03/2023	0.0052		mg/L	0.0020	NA	NA
LAKE-2-1-RM3-SINK-F-05	Room 3 Sink Faucet	05/03/2023	0.0016	J	mg/L	0.0020	NA	NA
LAKE-2-1-RM4-SINK-P-06	Room 4 Sink Faucet	05/03/2023	0.0030		mg/L	0.0020	NA	NA
LAKE-2-1-RM4-SINK-F-06	Room 4 Sink Faucet	05/03/2023	0.0034		mg/L	0.0020	NA	NA
LAKE-2-1-RM5-SINK-P-07	Room 5 Sink Faucet	05/03/2023	0.0040		mg/L	0.0020	NA	NA
LAKE-2-1-RM5-SINK-F-07	Room 5 Sink Faucet	05/03/2023	0.0059		mg/L	0.0020	NA	NA

(East Elementary) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-HW-DWC-P-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0029		mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-SS-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-F-01	Water Fountain w/Cooler in Hallway	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-NUR-SINK-P-02	Nurse's Office Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-NUR-SINK-F-02	Nurse's Office Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-P-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-SS-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-DWC-F-03	Water Fountain w/Cooler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-P-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-SS-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-WBF-F-04	Water Bottle Filler in Hallway	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-05	Kitchen Faucet	05/03/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-05	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-06	Kitchen Faucet	05/03/2023	0.0041		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-06	Kitchen Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-07	Kitchen Faucet	05/03/2023	0.0016	J	mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-F-07	Kitchen Faucet	05/03/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-3-1-KIT-KF-P-08	Kitchen Faucet	05/03/2023	0.035		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample

(East Elementary) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-KIT-ICE-P-09	Kitchen Ice Machine	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-P-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-SS-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-DWC-F-10	Water Fountain w/Cooler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-WBF-P-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-WBF-SS-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-SPEECH-WBF-F-11	Bottle Filler in Hallway by Speech Room	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-P-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-SS-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0024		mg/L	0.0020	NA	NA
LAKE-3-1-HW-RM9-DWC-F-12	Water Fountain w/Cooler by Room 9	05/03/2023	0.0026		mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-P-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.0021		mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-SS-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM11-DWC-F-13	Water Fountain w/Cooler by Room 11	05/03/2023	0.00084	J	mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-P-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0031		mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-SS-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-3-1-RM12-DWC-F-14	Water Fountain w/Cooler by Room 12	05/03/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-P-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-SS-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-DWC-F-15	Water Fountain w/Cooler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-WBF-P-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-LIB-WBF-SS-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

(East Elementary) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-3-1-HW-LIB-WBF-F-16	Bottle Filler by Library	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-P-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-SS-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM14-DWC-F-17	Water Fountain w/Cooler by Room 14	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-P-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-SS-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM13-DWC-F-18	Water Fountain w/Cooler by Room 13	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-DWC-P-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-DWC-SS-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-DWC-F-19	Water Fountain w/Cooler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-P-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-SS-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-HW-MR/WR-WBF-F-20	Bottle Filler between Men's and Women's Restroom	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM4-TL-SINK-P-21	Teacher's Lounge/Room 4 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-3-1-RM4-TL-SINK-F-21	Teacher's Lounge/Room 4 Sink Faucet	05/03/2023	0.0020	U	mg/L	0.0020	NA	NA

(W.T. Chipman) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-1-KIT-KF-P-01	Kitchen Faucet	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-01	Kitchen Faucet	05/04/2023	0.00085	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-02	Kitchen Faucet	05/04/2023	0.0015	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-02	Kitchen Faucet	05/04/2023	0.00072	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-03	Kitchen Faucet	05/04/2023	0.00097	J	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-03	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-ICE-P-04	Kitchen Ice Machine	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-P-05	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-KIT-KF-F-05	Kitchen Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-P-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.00078	J	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-SS-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-7-1-CAF-DWC-F-06	Water Fountain w/Cooler Cafeteria	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-7-1-TL-CF-P-07	Teacher's Lounge Sink Faucet	05/04/2023	0.022		mg/L	0.0020	Shut off/disconnect outlet, Post "Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample	Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
LAKE-7-1-TL-CF-F-07	Teacher's Lounge Sink Faucet	05/04/2023	0.0027		mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-P-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0014	J	mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-SS-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0035		mg/L	0.0020	NA	NA
LAKE-7-1-301-DWC-F-08	Water Fountain w/Cooler by Room 301	05/04/2023	0.0074		mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-P-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-SS-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-DWC-F-09	Water Fountain w/Cooler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-WBF-P-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-103-WBF-SS-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

(W.T. Chipman) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-1-103-WBF-F-10	Bottle Filler by Room 103	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-P-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-SS-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-102-DWC-F-11	Water Fountain w/Cooler by Room 102	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-DWC-P-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-DWC-SS-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-DWC-F-12	Water Fountain w/Cooler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-P-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-SS-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-105-WBF-F-13	Bottle Filler by Room 105	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-P-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-SS-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-109-DWC-F-14	Water Fountain w/Cooler by Room 109	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-P-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-SS-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-DWC-F-15	Water Fountain w/Cooler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-P-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-SS-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-115-WBF-F-16	Bottle Filler by Room 115	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-17	Room 117 Sink Faucet	05/04/2023	0.0035		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-17	Room 117 Sink Faucet	05/04/2023	0.00068	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-18	Room 117 Sink Faucet	05/04/2023	0.0034		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-18	Room 117 Sink Faucet	05/04/2023	0.00084	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-19	Room 117 Sink Faucet	05/04/2023	0.0041		mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-19	Room 117 Sink Faucet	05/04/2023	0.0010	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-P-20	Room 117 Sink Faucet	05/04/2023	0.0017	J	mg/L	0.0020	NA	NA
LAKE-7-1-117-CF-F-20	Room 117 Sink Faucet	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

(W.T. Chipman) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-2-203-DWC-P-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-203-DWC-SS-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-203-DWC-F-22	Second Floor Water Fountain w/Cooler by Room 203	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-P-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-SS-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-DWC-F-23	Second Floor Water Fountain w/Cooler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-WBF-P-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-WBF-SS-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-201-WBF-F-24	Second Floor Bottle Filler by Room 201	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-P-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-SS-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-2-209-WBF-F-26	Second Floor Bottle Filler by Room 209	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-P-28	Water Fountain w/Cooler Gym	05/04/2023	0.0013	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-SS-28	Water Fountain w/Cooler Gym	5/4/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-F-28	Water Fountain w/Cooler Gym	05/04/2023	0.0018	J	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-P-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-SS-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-DWC-F-29	Water Fountain w/Cooler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-P-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-SS-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-GYM-WBF-F-30	Bottle Filler Gym	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-P-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-SS-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-DWC-F-31	Water Fountain w/Cooler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-WBF-P-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

(W.T. Chipman) Sample Name	Sample Location	Date Collected	Result	Qualifier	Unit	Reporting Limit	Immediate Remedial Response	Long-Term Remedial Response
LAKE-7-1-305-WBF-SS-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-305-WBF-32	Bottle Filler by Room 305	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-P-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-SS-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA
LAKE-7-1-313-DWC-F-33	Water Fountain w/Cooler by Room 313	05/04/2023	0.0020	U	mg/L	0.0020	NA	NA

Key - Sample Name		Key - Qualifier	
P	Primary Sample	U	Not Detected in Laboratory Analysis
SS	Sequential Sample	J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit
F	Flush Sample		